



SUSANA MARTINEZ
Governor
JOHN A. SANCHEZ
Lieutenant Governor

NEW MEXICO
ENVIRONMENT DEPARTMENT

Ground Water Quality Bureau

Harold Runnels Building
1190 St. Francis Drive
PO Box 5469, Santa Fe, NM 87502-5469
Phone (505) 827-2900 Fax (505) 827-2965
www.nmenv.state.nm.us



DAVE MARTIN
Secretary
RAJ SOLOMON, P.E.
Deputy Secretary

CERTIFIED MAIL – RETURN RECEIPT REQUESTED

JUN 2011

June 21, 2011

Mr. Mark Holmes, Project Manager
Kirtland Air Force Base
2050 Wyoming Blvd. SE, Suite 124
Kirtland AFB, NM 87117-5270

RE: Response to Notice of Intent to Discharge; Discharge Permit Not Required for Kirtland Air Force Base, KAFB-106069 Equipment Decontamination and Well Development Water, AI: 2404

Dear Mr. Holmes:

The New Mexico Environment Department (NMED) received a Notice of Intent on June 13, 2011 to discharge approximately 1,250 gallons of non-hazardous drilling equipment decontamination and well development water associated with the Bulk Fuels Facility Solid Waste Management Units ST-106 and SS-111. The notice satisfies the requirements of Subsection A of 20.6.2.1201 NMAC of the New Mexico Water Quality Control Commission (WQCC) Regulations (20.6.2 NMAC). The proposed discharge is located in Section 36, Township 10 North, Range 3 East, Bulk Fuels Facility, Kirtland Air Force Base, Bernalillo County.

Based on the information (including analytical data) provided in your Notice of Intent, NMED has determined that a Discharge Permit is not required as long as the discharge is as described. A Discharge Permit is not required at this time pursuant to Subsection A of 20.6.2.3105 NMAC because the information provided indicates that the discharge will not adversely affect ground water quality.

The proposed discharge is briefly described as follows:

Approximately 1,250 gallons of non-hazardous water generated by decontamination of drilling equipment and development of ground water monitoring well KAFB-106069 will be discharged to the ground surface at the Bulk Fuels Facility site. The water will be discharged at the site in a

KAFB3761



Mark Holmes, AI: 2404

June 21, 2011

page 2

controlled manner, containing the water in the immediate area of the site and avoiding runoff into storm sewers or arroyos. The depth to ground water is approximately 500 feet.

Although a Discharge Permit is not being required for this discharge at this time, you are not relieved of liability should your operation result in actual pollution of surface or ground waters. Further, this decision by NMED does not relieve you of your responsibility to comply with any other applicable federal, state, and/or local laws and regulations, such as zoning requirements, plumbing codes and nuisance ordinances.

If at some time in the future you intend to change the amount, character or location of your discharge, or if observation or monitoring shows that the discharge is not as described in your Notice of Intent, you must file a revised Notice of Intent with the Ground Water Quality Bureau.

If you have any questions, please contact George Schuman, Program Manager of the Ground Water Pollution Prevention Section, at (505) 827-2945.

Sincerely,

A handwritten signature in black ink, appearing to read 'William C. Olson', written over a light blue horizontal line.

William C. Olson, Chief
Ground Water Quality Bureau

WO:GS

cc: Jennifer Ickes, District Manager, NMED District I
John Kieling, Acting Chief, NMED-HWB
NOI File
County File