

Darlene Goering

From: Michael Dale [mdale@lanl.gov]
Sent: Tuesday, September 17, 2002 11:56 AM
To: Darlene Goering
Cc: syanicak@lanl.gov
Subject: RE: Cyanide

General
CLA Canyon, Pueblo Canyon, Northside Canyon, Off-site Groundwater

This is the best that I could do. Is this what you were looking for? I'll try to compile the CN detection for surface water by tomorrow, that is, if you want them?

You probably already know this but the standard for drinking water (EPA) for CN is 0.2 mg/L.

**Cyanide
Detections in
Ground Water
at LANL (old
Environmental
Surveillance
data)
Unit: mg/L**

ID	DATE SAMPLED	RESULT (mg/L)
APCO-1	13-Sep-90	0.26
Indian Spring	22-Apr-91	0.12
Hamilton Bend Spring	30-Jul-74	0.11
LAO-1	31-Jul-74	0.22
LAO-2	31-Jul-74	0.15
LAO-3	31-Jul-74	0.46
MCO-3	31-Jul-74	0.18
MCO-3	24-Oct-74	0.14
MCO-5	29-Jul-74	0.35
MCO-7	29-Jul-74	0.18
Community Well New Subdivision	19-May-95	0.12
BIA Wellpoint 1	24-May-95	1.71

**DOES NOT
INCLUDE
SURFACE-
WATER
DETECTIONS.
NOTE THAT
CN WAS
DETECTED
IN SURFACE
WATER.**



13688