

2.10 PREPAREDNESS AND PREVENTION

2.10.1 Required Equipment

~~The Permittees shall maintain equipment capable of mitigating the effects of a power outage at each permitted unit (see 40 CFR §§ 270.14(b)(8)(iv) and 270.32(b)(2)). This equipment must be~~ At permitted units where equipment is necessary to mitigate the effects of a power outage, the Permittees shall maintain batteries, generators, or some other form of backup power supply ~~and must be~~ capable of operating equipment including evacuation alarms, emergency communication equipment, automatic fire suppression systems, and emergency lights ~~in buildings without daylight illumination~~. The Permittees shall ensure that it is possible to provide fuel to backup generators under adverse conditions. (See 40 CFR §§ 270.14(b)(8)(iv) and 270.32(b)(2))

3.7.1(2) Containers with Free Liquids

(Add to end of subparagraph)

Requests for extension of time for any deadline under this subparagraph may be made by e-mail.

3.7.1(4) Containers with Free Liquids

If a coating or sealant is used as a component of a secondary containment system, the Permittees shall maintain documentation in the Facility Operating Record that the coating or sealant was applied and maintained in accordance with the manufacturer's specifications. This documentation shall include a copy of the manufacturer's specifications as well as a certification stating the Permittees' installation and maintenance procedures were in accordance with the manufacturer's specifications. If the base of the containment unit has expansion or construction joints, the Permittees shall install and maintain chemically resistant water stops, which are embedded in the concrete, or equivalent external systems (e.g. sealant systems) (see 40 CFR § 270.32(b)(2)).

