

HSWA LANL 3/1082/16

To: File
Thru: John Kieling, LANL Facility Manager
From: Kim T. Hill, Environmental Engineer
Subject: Verbal Release Notifications
Record of Communication
Date: May 30, 1997

JK
TH

6/6/97
CONFIDENTIAL
5/29/97

MEMORANDUM

I was contacted by Harvey Decker of LANL at approximately 8:00 am to report the following release incident:

- TA 16: At approximately 12:45 pm, a plugged manhole backed up 75 yards southwest of Bldg. 202. The overflow came through a cleanout and released approximately 20 gallons of sewage. The area was vacuumed and disinfected. No PRSs are in the vicinity of the release.

C:\OFFICE\WPWIN\WPDOCS\LANL\VERBAL1.NOT 5/30/97

TC

