

HWB EMERGENCY / INCIDENT / COMPLAINT REPORT

Date and Time of Call 7/24/03 11:10 A HWB Emergency # _____
Call Recipient Roger Husted IDEA Entry Date _____ IDEA Incident # _____
HWB # _____

Caller's Name Mark Haugstad Affiliation _____
Address _____ Phone 665-2014

Caller Confidentiality Requested Caller Update Requested Updated: yes no

INCIDENT DATE & TIME: 7/23/03 8:00 A LOCATION: SMU 16-004(A)-99

County or Nearest Municipality _____

INCIDENT DESCRIPTION (nature of incident; quantity/type of hazardous material involved; nature of injuries, damage, threats to people, property, environment; current status and weather; responsible parties and contact information; incident responders)

Closed surge valve caused 22K gal clarifier to overflow & release into environment.

less than 1000 gal released

release stayed on SMU & little erosion

- Disinfected appropriate areas
- Valves repaired/replaced?

small area.

Circle All Media Impacted/Threatened: Ground Water Surface Water Drinking Water Soil Air None (contained)

NOTIFICATIONS: 4th Floor Other NMED Office specify J. Young

Outside NMED specify _____

Followup Priority: emergency high medium low Assignment/Referral Date _____



