

ROBERT E. MCKEE
GENERAL CONTRACTOR
LOS ALAMOS, NEW MEXICO

August 28, 1948

TA-33-Chamber 2

SF 1423-D

Re: Contract No. AT-29-1-GEN-481
Job 1186

Los Alamos Scientific Laboratory
Construction and Maintenance Group
Los Alamos, New Mexico

Gentlemen:

There is attached three prints of Robberson Steel Company Shop Drawing No. 48-599, Sheet No. 3, covering details of junction boxes A and B for Underground Chamber No. 2, above project, for your approval.

Robberson Steel Company has interpreted the architectural drawings to the effect that dimensions shown are "out to out" of plates. Robberson asks also that we verify welding shown.

"The location of mounting holes in A-3 were not given. The 8-13/16" holes in the back plate appear to be too large inasmuch as the holes are spaced 8" centers. We are wondering if this should not be the same size as the bottom holes. Also on the back plate, a dimension of 9-1/2" is shown to center line of hole for A-3, with another dimension to the same place as 8-1/2". Please advise us.

"Referring to box B-3, the dimensions for cap screws did not add to 5'6". We have changed accordingly."

We would appreciate receiving your approval and information on the above as soon as possible.

Very truly yours,

ROBERT E. MCKEE, GENERAL CONTRACTOR

NJR/ml
Encs.
cc: EP
Mr. Hardie

By:

COPY



4608