

TA54



BILL RICHARDSON
GOVERNOR

State of New Mexico
ENVIRONMENT DEPARTMENT
DOE OVERSIGHT BUREAU
134 State Road 4, Suite A
TA-00-1313
White Rock, New Mexico 87544
Telephone (505) 672-0443 Fax (505) 672-0466



RON CURRY
SECRETARY

CINDY PADILLA
DEPUTY SECRETARY

December 12, 2007

Richard Powell
New Mexico Environment Department
Surface Water Quality Bureau
1190 St. Francis Dr
Suite N4050
Santa Fe, NM 87505

SUBJECT: Spill Response Assessment and Suggestion for Close-Out of Dry Fire Suppression Water System Water Release at TA-54, Building 412, LANL Report # 183, on October 11, 2007

Dear Mr. Powell:

On October 12, 2007, the New Mexico Environment Department (NMED) was notified of a potable water release from a failed valve on a dry fire suppression water system at TA-54, Building 412, located at Los Alamos National Laboratory, Los Alamos, New Mexico. This spill was reported to the Emergency Spill Hotline as required by 20.6.2.1203 NMAC of the Water Quality Control Commission. The amount of the discharge was approximately 2,200 gallons with a portion of water flowing to a nearby shaft field. The water flowed around waste shafts 205 and 214 and then infiltrated into the nearby soil. Follow-up site investigation showed that the sandbags placed by facility staff at the time of the spill were very effective at diverting the release around the shafts, thus no infiltration or erosion occurred. At approximately 2:30 p.m. the dry line fire suppression system was repaired and then placed back into service.

The DOE Oversight Bureau has reviewed the spill discharge notification report from October 12, 2007 and has found that the inspection and follow-up repair program is sufficient to protect the environment of New Mexico. The Oversight Bureau believes the response and clean-up has been adequate and recommends that no further action is required at this time under this discharge notification. However, this letter does not relieve the United States Department of Energy or the Los Alamos National Security, LLC, of its obligation to comply with any other applicable laws and regulations.

30500



Mr. Richard Powell
Page 2
12/12/2007

If you have any questions regarding this recommendation, please contact Erik Galloway of our Santa Fe office at (505) 476-6024.

Sincerely,



Stephen Yanicak
Staff Manager/POC

xc: Gene Turner, DOE/AIP/POC MS A316
Mark Haagenstad, LANS/ENV-RCRA/WQ MS K490
Tina Sandoval, LANS/ENV-RCRA/WQ MS K490
Robert George, NMED/GWQB
Stephen Connolly, NMED/HWB
~~John Young, NMED/HWB~~
Jake Knatson, NMED/GWQB
Jenn Montoya, NMED/GWQB
Barry Birch, NMED/DOE OB
Erik Galloway, NMED/DOE OB
Spill File