

*Info required by  
Fire Dept.*

**Safety Kl:**

Post-It™ brand fax transmittal memo 7671		# of pages ▶
To	NAME	From
Co.	SAFETY FLEET	Co.
Dept.		Phone #
Fax #	214 612 1244	Fax # 504 213 5912

**MEMO**  
8/16/90

From:  
To:

**Re: Plan Check of 2720 Girard N.E.:**

The information required for plan check to be completed was forwarded to code administration personnel.

The attached photo copies indicate the requirements of the code with regard to this structure. Briefly they include:

- [1] graphic representation of adequate access for the fire department.
  - [2] verification of fire hydrant within 450' of the furthest point of the building.
  - [3] one 2A 10 BC fire extinguisher.
  - [4] fire protection in the form of a sprinkler system. This will have to be water or water-based aqueous foam, because the pre-engineered dry-chemical type we suggested is not acceptable according to I.C.B.O.
  - [5] in addition to the <sup>6"</sup> pan system to contain any spills, a drainage system is required to remove the spill and the sprinkler system discharge from the building.
  - [6] the drainage system must run to a safe place of containment, which must be remote from property lines and other structures.
  - [7] smoke and heat vents must be provided.
  - [8] mechanical ventilation must be provided or it must be shown that natural ventilation is sufficient.
  - [9] explosion venting must be provided.
  - [10] ~~an~~ EXIT (PERSONNEL DOOR) MUST BE PROVIDED - (CODE ADMIN SAYS 2 BUT THIS IS H-2 REQUIREMENT & WE ARE H-3)
- There are no exceptions to these requirements, which are clearly documented in the code. I have met with Fire Chief