

<input checked="checked" type="checkbox"/> TELEPHONE	<input type="checkbox"/> PERSONAL	TIME: 8:28	DATE: 04/25/91
ORIGINATING PARTY		OTHER PARTIES	
Wendel Yine		AGordon	
TEP		ED/H+RW Bureau	
SUBJECT Safety Kleen ABQ			
DISCUSSION			
<p>set of drawings certified of mg tank all of tank system & return & fill station certified partial site plan for flammable shed, return + fill station + tank plan section for flammable shelter - what we need as regulators not final drawings nor connection details between water & culing calculations for containment for water + fire water for 20" ventilation</p>			
CONCLUSIONS OR AGREEMENTS			
<p>NFPA 30 code</p> <p>set of notes on concrete classification for electrical system again submitted wrong specs; TERA in cover letter will go over these not given authorization for "permit mod" but</p>			
DISTRIBUTION		SIGNED	
Phy leg fed exp		AGordon	
Receive Monday			

Safety-Kleen file
David Engfert