


Ed/pmw

SPARTON

SPARTON TECHNOLOGY



November 13, 1991

Red
11.13.91

Technical Section (6H-CD)
RCRA Enforcement Branch
Hazardous Waste Management Division
U.S. Environmental Protection Agency
1445 Ross Avenue
Dallas, Texas 75202-2733

Attention: Mr. Keith Phillips, Chief

Reference: Monthly Report
Sparton Technology, Inc.

See Magazine FILE:

"~~WSMR FIF~~ QUARTERLY

REPORTS"

"SPARTON QUARTERLY

REPORTS"

Gentlemen:

This is the monthly progress report for Sparton Technology, Inc.'s Coors Road Facility, located in Albuquerque, New Mexico, as required in Section IV.C of the Consent Order. This report summarizes activities during the month of October 1991.

1. The bi-weekly water level measurements taken to date, as required in Section IV.A.1 of the Consent Order, are included in Attachment 1.
2. Air stripper removal efficiencies continue to average over 99 percent for the measured indicator parameters. During the month, 49,200 gallons of recovered groundwater were treated, bringing the total volume treated to date to 1,892,400 gallons. Air stripper performance data is included in Attachment 2.

Enclosure
not
Found

002707