

**METRIC**  
Corporation ENVIRONMENTAL ENGINEERING AND SCIENCE

8429 WASHINGTON PLACE NE, SUITE A  
ALBUQUERQUE, NEW MEXICO 87113  
Phone: (505) 828-2801  
Fax: (505) 828-2803

June 23, 1994


Technical Section (6H-CD)  
RCRA Enforcement Branch  
Hazardous Waste Management Division  
U.S. Environmental Protection Agency  
1445 Ross Avenue  
Dallas, Texas 75202-2733

Attention: Mr. Keith Phillips, Chief

Reference: Monthly Report for May, 1994  
Sparton Technology, Inc.

*Folk*

*Ren #  
mark ✓  
Barbara ✓*



Gentlemen:

Enclosed is the monthly progress report for Sparton Technology, Inc.'s Coors Road Facility in Albuquerque, New Mexico, on Sparton Technology letterhead. This was originally inadvertently printed on Metric Corporation letterhead.

We apologize for any inconvenience this caused. Please discard the first copy and retain this copy for your records.

Very truly yours,

METRIC CORPORATION

Gary Richardson

Attachments: (as stated)

cc: NMEID  
J. Appel  
P. Chandler  
J. DeWitt  
J. Wakefield  
G. Richardson

002772

# SPARTON

---

## SPARTON TECHNOLOGY

June 15, 1994

Technical Section (6H-CD)  
RCRA Enforcement Branch  
Hazardous Waste Management Division  
U.S. Environmental Protection Agency  
1445 Ross Avenue  
Dallas, Texas 75202-2733

Attention: Mr. Keith Phillips, Chief

Reference: Monthly Report  
Sparton Technology, Inc.

Gentlemen:

This is the monthly progress report for Sparton Technology, Inc.'s Coors Road Facility, located in Albuquerque, New Mexico, as required in Section IV.C of the Consent Order. This report summarizes activities performed at the site during the month of May 1994.

### Site Activities

1. Air stripper removal efficiencies continue to average about 99 percent for the measured indicator parameters. During the month, 27,100 gallons of recovered groundwater were treated, bringing the total volume treated to date to 2,895,100 gallons. Air stripper performance data is included in Attachment 1.

002773

June 15, 1994  
Technical Section (6H-CD)  
RCRA Enforcement Branch  
Hazardous Waste Management Division  
U.S. Environmental Protection Agency  
Page 2

This concludes our progress report for the month of May 1994.  
If you have any questions, please contact the undersigned.

Very truly yours,

SPARTON TECHNOLOGY, INC.

A handwritten signature in cursive script that reads "Gary Z. Richardson (for)".

Richard D. Mico  
Vice President/General Manager

Attachments: (as stated)

cc: NMEID  
J. Appel  
P. Chandler  
J. DeWitt  
J. Wakefield  
G. Richardson

002774

ATTACHMENT 1

Air Stripper Performance Data

002775

AIR STRIPPER PERFORMANCE

Sparton Technology, Inc.  
Albuquerque, New Mexico

(all concentrations in micrograms per liter (ppb) )

DATE SAMPLED	1,1-Dichloroethylene [-----]			Methylene Chloride [-----]			1,1,1-Trichloroethane [-----]			Trichloroethylene [-----]		
	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION
12/12/88	21	0.32	98.5	293	5.4	98.2	95	1.9	98.0	328	6.3	98.1
12/14/88	170	1.1	99.4	2230	26.5	98.8	1090	9.7	99.1	2490	22.4	99.1
12/19/88	87	0.4	99.5	1320	13.6	99.0	862	6.0	99.3	2200	14.8	99.3
12/27/88	89	0.5	99.4	1250	2.4	99.8	648	3.3	99.5	1300	7.2	99.4
01/06/89	64	0.2	99.7	581	3.3	99.4	340	1.7	99.5	712	4.1	99.4
01/23/89	82	0.2	99.8	545	7.4	98.6	570	2.6	99.5	1220	7.5	99.4
02/02/89	83	0.3	99.6	514	0.1	100.0	389	2.2	99.4	1550	8.6	99.4
03/06/89	107	1.5	98.6	38	0.4	98.9	708	11.0	98.4	1300	21.0	98.4
04/03/89	79	1	98.7	84	1	98.9	371	0	99.7	880	1.5	99.8
05/01/89	94	1	98.9	14	1	92.9	243	0	99.6	632	1	99.8
06/05/89	28	1	96.4	148	1	99.3	198	0	99.5	685	1	99.9
07/05/89	20	0.1	99.5	2.4	0.1	95.8	154	0.1	99.9	452	0.14	100.0
08/07/89	27	0.1	99.6	2.4	0.1	95.8	152	0.18	99.9	477	0.19	100.0
09/05/89	53	0.1	99.8	8.5	0.1	98.8	310	0.1	100.0	785	0.2	100.0
10/02/89	62	0.1	99.8	2.6	0.1	96.2	286	0.1	100.0	905	0.1	100.0
11/06/89	20.9	0.1	99.5	140.0	0.3	99.8	87.5	0.1	99.9	392	0.25	99.9
12/04/89	23.0	0.1	99.6	131.0	0.2	99.8	71	0.1	99.9	378	0.40	99.9
01/08/90	19.7	0.1	99.5	140.0	0.4	99.7	90.3	0.18	99.8	359	0.91	99.7
02/05/90	34.0	0.1	99.7	44.0	0.2	99.5	250	0.47	99.8	670	1.8	99.7
03/05/90	45.0	0.1	99.8	35.0	0.2	99.4	240	0.19	99.9	780	0.91	99.9
04/02/90	64.0	0.1	99.8	10.0	0.4	96.0	310	0.1	100.0	1300	0.32	100.0
05/07/90	43.0	0.1	99.8	8.7	0.1	98.9	190	0.1	99.9	720	0.18	100.0
06/04/90	70.0	0.1	99.9	1.0	0.1	90.0	180	0.1	99.9	820	0.1	100.0
07/02/90	30.0	0.1	99.7	1.0	1.0	----	140	0.1	99.9	625	0.1	100.0
08/06/90	40.0	0.1	99.8	21.0	0.1	99.5	140	0.1	99.9	550	0.59	99.9
09/10/90	44.0	0.1	99.8	5.9	0.1	98.3	150	1.0	99.9	880	1.0	99.9
10/01/90	93.0	1.0	98.9	6.7	1.0	85.1	290	1.0	99.7	1200	1.0	99.9
11/05/90	64.0	1.0	98.4	10.0	1.0	90.0	200	1.0	99.5	1200	1.0	99.9
12/19/90	26.0	1.0	96.2	1.0	1.0	----	120	1.0	99.2	460	1.0	99.8
01/08/91	68.0	1.0	98.5	22.0	1.0	95.5	490	1.0	99.8	1620	3.5	99.8
02/04/91	82.0	1.0	98.8	1.0	1.0	----	396	1.0	99.7	1500	1.6	99.9
03/18/91	330.0	1.0	99.7	1.0	1.0	----	210	1.0	99.5	550	1.0	99.8

002776

AIR STRIPPER PERFORMANCE  
(CONTINUED)  
Sparton Technology, Inc.  
Albuquerque, New Mexico

(all concentrations in micrograms per liter (ppb) )

DATE SAMPLED	1,1-Dichloroethylene [-----]			Methylene Chloride [-----]			1,1,1-Trichloroethane [-----]			Trichloroethylene [-----]		
	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION
04/01/91	72.0	1.0	98.6	1.0	1.0	----	150.0	1.0	----	820.0	1.0	99.9
05/06/91	22.0	1.0	95.5	1.0	1.0	----	140.0	1.0	99.3	770.0	1.0	99.9
06/03/91	180.0	1.0	99.4	31.0	1.0	96.8	620.0	1.0	99.8	2100.0	1.7	99.9
06/30/91	41.0	1.0	97.6	1.0	1.0	----	110.0	1.0	99.1	360.0	1.2	99.7
08/02/91	88.0	1.0	98.9	5.0	1.0	80.0	340.0	1.0	99.7	1200.0	1.0	99.9
09/09/91	10.0	1.0	90.0	10.0	1.0	90.0	390.0	1.0	99.7	1700.0	1.0	99.9
10/7/91	74.0	1.0	98.6	1.0	1.0	----	320.0	1.0	99.7	1100.0	1.0	99.9
11/04/91	130.0	1.0	99.2	1.0	1.0	----	290.0	1.0	99.7	1400.0	1.0	99.9
12/02/91	62.0	1.0	98.4	1.0	1.0	----	270.0	1.0	99.6	1000.0	1.0	99.9
01/06/92	100.0	1.0	99.0	1.0	1.0	----	250.0	1.0	99.6	2000.0	1.1	99.9
02/03/92	150.0	1.7	98.9	77.0	1.0	98.7	390.0	4.0	99.0	1900.0	1.3	99.9
03/02/92	160.0	1.0	99.4	4.9	1.0	79.6	420.0	1.0	99.8	1300.0	1.0	99.9
04/01/92	100.0	1.0	99.0	1.0	1.0	----	490.0	1.0	99.8	2800.0	1.0	100.0
05/06/92	35.0	1.0	97.1	2.0	1.0	50.0	210.0	1.0	99.5	1400.0	1.0	99.9
06/01/92	61.1	1.0	98.4	1.0	1.0	----	185.0	1.0	99.5	530.0	1.0	99.8
07/01/92	76.0	1.0	98.7	1.3	1.0	23.1	156.0	1.0	99.4	776.0	1.0	99.9
08/10/90	28.0	1.0	96.4	33.0	1.0	97.0	211.0	1.0	99.5	830.0	1.0	99.9
09/11/92	67.0	1.0	98.5	112.0	1.0	99.1	185.0	1.0	99.5	747.0	1.0	99.9
10/01/92	58.0	1.0	98.3	1.0	1.0	----	164.0	1.0	99.4	964.0	1.0	99.9
11/02/92	114.0	1.0	99.1	18.0	1.0	94.4	261.0	1.0	99.6	1140.0	1.0	99.9
12/01/92	70.0	1.0	98.6	1.0	1.0	----	194.0	1.0	99.5	875.0	1.0	99.9
01/04/93	74.0	1.0	98.6	24.0	1.0	95.8	220.0	1.9	99.1	1020.0	1.0	99.9
02/01/93	46.0	1.0	97.8	1.0	1.0	----	140.0	1.0	99.3	860.0	1.0	99.9
03/01/93	1.0	1.0	----	328	1.0	96.9	180.0	1.0	99.4	1200.0	1.0	99.9
04/06/93	35.0	1.0	97.1	268	1.0	96.2	120.0	1.0	99.2	630.0	3.8	99.4
05/05/93	30.0	1.0	96.7	568	1.0	98.2	86.0	1.0	98.8	520.0	1.0	99.8
06/08/93	64.0	1.0	98.4	528	1.0	98.1	161.0	1.0	99.4	710.0	1.0	99.9
07/12/93	18.0	1.0	94.4	13.0	1.0	92.3	140.0	6.7	95.2	750.0	39.0	94.8
08/13/93	37.0	1.0	97.3	1.0	1.0	----	150.0	1.0	99.3	840.0	1.0	99.9
08/13/93*	45.0	0.2	99.6	10.0	2.0	80.0	170.0	0.2	99.9	840.0	0.2	100.0
09/15/93	35.0	1.0	97.1	1.0	1.0	----	160.0	1.0	99.4	940.0	1.0	99.9
10/14/93	58.0	1.0	98.3	1.0	1.0	----	200.0	1.0	99.5	940.0	1.0	99.9

Note: Influent detection limits for 08/02/81 and 09/09/91 are 5.0 ug/l and 10.0 ug/l, respectively which is higher than previous detection limits.  
B indicates analyte was detected in the laboratory blank.

\*: Duplicate analysis

002777

AIR STRIPPER PERFORMANCE  
(CONTINUED)  
Sparton Technology, Inc.  
Albuquerque, New Mexico

(all concentrations in micrograms per liter (ppb) )

DATE SAMPLED	1,1-Dichloroethylene [-----]			Methylene Chloride [-----]			1,1,1-Trichloroethane [-----]			Trichloroethylene [-----]		
	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION
11/03/93	88.0	1.0	98.9	49.0	1.0	98.0	280.0	1.0	99.6	1400.0	1.2	99.9
12/20/93	42.0	1.0	97.6	1.0	1.0	----	170.0	1.0	99.4	1000.0	1.0	99.9
01/04/94	58.0	1.0	98.3	1.0	1.0	----	210.0	1.0	99.5	1200.0	1.5	99.9
02/09/94	90.0	1.0	98.9	1.0	1.0	----	250.0	1.0	99.6	1200.0	2.6	99.8
03/04/94	53.0	1.0	98.1	1.0	1.0	----	200.0	1.0	99.5	1100.0	1.0	99.9
04/08/94	1.0	1.0	----	1.0	1.0	----	120.0	1.0	99.2	690.0	1.0	99.9
05/02/94	78.0	1.5	98.1	418	1.78	95.9	250.0	1.0	99.6	760.0	1.0	99.9
AVERAGES	66.4	0.8	98.8	115.9	1.6	98.6	266.5	1.3	99.5	1017.4	2.7	99.7

002778