


SPARTON

SPARTON TECHNOLOGY

July 21, 1995



Technical Section (6H-CD)
RCRA Enforcement Branch
Hazardous Waste Management Division
U.S. Environmental Protection Agency
1445 Ross Avenue
Dallas, Texas 75202-2733

Attention: Mr. Ronald Crossland

Reference: Monthly Report
Sparton Technology, Inc.

Gentlemen:

This is the monthly progress report for Sparton Technology, Inc.'s Coors Road Facility, located in Albuquerque, New Mexico, as required in Section IV.C of the Consent Order. This report summarizes activities performed at the site during the month of June 1995.

Site Activities

1. Air stripper removal efficiencies continue to average about 99 percent for the measured indicator parameters. During the month, 45,500 gallons of recovered groundwater were treated, bringing the total volume treated to date to 3,307,600 gallons. Air stripper performance data is included in Attachment 1.

002839

July 21, 1995
Technical Section (6H-CD)
RCRA Enforcement Branch
Hazardous Waste Management Division
U.S. Environmental Protection Agency
Page 2

This concludes our progress report for the month of June 1995.
If you have any questions, please contact the undersigned.

Very truly yours,

SPARTON TECHNOLOGY, INC.

A handwritten signature in cursive script, appearing to read "Richard D. Mico (for)".

Richard D. Mico
Vice President/General Manager

Attachments: (as stated)

cc: NMED
J. Appel
P. Chandler
J. Wakefield
G. Richardson

002840

ATTACHMENT 1

Air Stripper Performance Data

002841

AIR STRIPPER PERFORMANCE

Sparton Technology, Inc.
Albuquerque, New Mexico

(all concentrations in micrograms per liter (ppb))

| DATE SAMPLED | 1,1-Dichloroethylene [-----] | | | Methylene Chloride [-----] | | | 1,1,1-Trichloroethane [-----] | | | Trichloroethylene [-----] | | |
|-----------------|---------------------------------|----------|----------------------|-------------------------------|----------|----------------------|----------------------------------|----------|----------------------|------------------------------|----------|----------------------|
| | INFLUENT | EFFLUENT | PERCENT REDUCTION | INFLUENT | EFFLUENT | PERCENT REDUCTION | INFLUENT | EFFLUENT | PERCENT REDUCTION | INFLUENT | EFFLUENT | PERCENT REDUCTION |
| 12/12/88 | 21 | 0.32 | 98.5 | 293 | 5.4 | 98.2 | 95 | 1.9 | 98.0 | 328 | 6.3 | 98.1 |
| 12/14/88 | 170 | 1.1 | 99.4 | 2230 | 26.5 | 98.8 | 1090 | 9.7 | 99.1 | 2490 | 22.4 | 99.1 |
| 12/19/88 | 87 | 0.4 | 99.5 | 1320 | 13.6 | 99.0 | 862 | 6.0 | 99.3 | 2200 | 14.8 | 99.3 |
| 12/27/88 | 89 | 0.5 | 99.4 | 1250 | 2.4 | 99.8 | 648 | 3.3 | 99.5 | 1300 | 7.2 | 99.4 |
| 01/06/89 | 64 | 0.2 | 99.7 | 581 | 3.3 | 99.4 | 340 | 1.7 | 99.5 | 712 | 4.1 | 99.4 |
| 01/23/89 | 82 | 0.2 | 99.8 | 545 | 7.4 | 98.6 | 570 | 2.6 | 99.5 | 1220 | 7.5 | 99.4 |
| 02/02/89 | 83 | 0.3 | 99.6 | 514 | 0.1 | 100.0 | 389 | 2.2 | 99.4 | 1550 | 8.6 | 99.4 |
| 03/06/89 | 107 | 1.5 | 98.6 | 38 | 0.4 | 98.9 | 708 | 11.0 | 98.4 | 1300 | 21.0 | 98.4 |
| 04/03/89 | 79 | 1 | 98.7 | 84 | 1 | 98.9 | 371 | 0 | 99.7 | 880 | 1.5 | 99.8 |
| 05/01/89 | 94 | 1 | 98.9 | 14 | 1 | 92.9 | 243 | 0 | 99.6 | 632 | 1 | 99.8 |
| 06/05/89 | 28 | 1 | 96.4 | 148 | 1 | 99.3 | 198 | 0 | 99.5 | 685 | 1 | 99.9 |
| 07/05/89 | 20 | 0.1 | 99.5 | 2.4 | 0.1 | 95.8 | 154 | 0.1 | 99.9 | 452 | 0.14 | 100.0 |
| 08/07/89 | 27 | 0.1 | 99.6 | 2.4 | 0.1 | 95.8 | 152 | 0.18 | 99.9 | 477 | 0.19 | 100.0 |
| 09/05/89 | 53 | 0.1 | 99.8 | 8.5 | 0.1 | 98.8 | 310 | 0.1 | 100.0 | 785 | 0.2 | 100.0 |
| 10/02/89 | 62 | 0.1 | 99.8 | 2.6 | 0.1 | 96.2 | 286 | 0.1 | 100.0 | 905 | 0.1 | 100.0 |
| 11/06/89 | 20.9 | 0.1 | 99.5 | 140.0 | 0.3 | 99.8 | 87.5 | 0.1 | 99.9 | 392 | 0.25 | 99.9 |
| 12/04/89 | 23.0 | 0.1 | 99.6 | 131.0 | 0.2 | 99.8 | 71 | 0.1 | 99.9 | 378 | 0.40 | 99.9 |
| 01/08/90 | 19.7 | 0.1 | 99.5 | 140.0 | 0.4 | 99.7 | 90.3 | 0.18 | 99.8 | 359 | 0.91 | 99.7 |
| 02/05/90 | 34.0 | 0.1 | 99.7 | 44.0 | 0.2 | 99.5 | 250 | 0.47 | 99.8 | 670 | 1.8 | 99.7 |
| 03/05/90 | 45.0 | 0.1 | 99.8 | 35.0 | 0.2 | 99.4 | 240 | 0.19 | 99.9 | 780 | 0.91 | 99.9 |
| 04/02/90 | 64.0 | 0.1 | 99.8 | 10.0 | 0.4 | 96.0 | 310 | 0.1 | 100.0 | 1300 | 0.32 | 100.0 |
| 05/07/90 | 43.0 | 0.1 | 99.8 | 8.7 | 0.1 | 98.9 | 190 | 0.1 | 99.9 | 720 | 0.18 | 100.0 |
| 06/04/90 | 70.0 | 0.1 | 99.9 | 1.0 | 0.1 | 90.0 | 180 | 0.1 | 99.9 | 820 | 0.1 | 100.0 |
| 07/02/90 | 30.0 | 0.1 | 99.7 | 1.0 | 1.0 | ---- | 140 | 0.1 | 99.9 | 625 | 0.1 | 100.0 |
| 08/06/90 | 40.0 | 0.1 | 99.8 | 21.0 | 0.1 | 99.5 | 140 | 0.1 | 99.9 | 550 | 0.59 | 99.9 |
| 09/10/90 | 44.0 | 0.1 | 99.8 | 5.9 | 0.1 | 98.3 | 150 | 1.0 | 99.9 | 880 | 1.0 | 99.9 |
| 10/01/90 | 93.0 | 1.0 | 98.9 | 6.7 | 1.0 | 85.1 | 290 | 1.0 | 99.7 | 1200 | 1.0 | 99.9 |
| 11/05/90 | 64.0 | 1.0 | 98.4 | 10.0 | 1.0 | 90.0 | 200 | 1.0 | 99.5 | 1200 | 1.0 | 99.9 |
| 12/19/90 | 26.0 | 1.0 | 96.2 | 1.0 | 1.0 | ---- | 120 | 1.0 | 99.2 | 460 | 1.0 | 99.8 |
| 01/08/91 | 68.0 | 1.0 | 98.5 | 22.0 | 1.0 | 95.5 | 490 | 1.0 | 99.8 | 1620 | 3.5 | 99.8 |
| 02/04/91 | 82.0 | 1.0 | 98.8 | 1.0 | 1.0 | ---- | 396 | 1.0 | 99.7 | 1500 | 1.6 | 99.9 |
| 03/18/91 | 330.0 | 1.0 | 99.7 | 1.0 | 1.0 | ---- | 210 | 1.0 | 99.5 | 550 | 1.0 | 99.8 |

002842

AIR STRIPPER PERFORMANCE
(CONTINUED)
Sparton Technology, Inc.
Albuquerque, New Mexico

(all concentrations in micrograms per liter (ppb))

| DATE SAMPLED | 1,1-Dichloroethylene [-----] | | | Methylene Chloride [-----] | | | 1,1,1-Trichloroethane [-----] | | | Trichloroethylene [-----] | | |
|-----------------|---------------------------------|----------|----------------------|-------------------------------|----------|----------------------|----------------------------------|----------|----------------------|------------------------------|----------|----------------------|
| | INFLUENT | EFFLUENT | PERCENT REDUCTION | INFLUENT | EFFLUENT | PERCENT REDUCTION | INFLUENT | EFFLUENT | PERCENT REDUCTION | INFLUENT | EFFLUENT | PERCENT REDUCTION |
| 04/01/91 | 72.0 | 1.0 | 98.6 | 1.0 | 1.0 | ---- | 150.0 | 1.0 | ---- | 820.0 | 1.0 | 99.9 |
| 05/06/91 | 22.0 | 1.0 | 95.5 | 1.0 | 1.0 | ---- | 140.0 | 1.0 | 99.3 | 770.0 | 1.0 | 99.9 |
| 06/03/91 | 180.0 | 1.0 | 99.4 | 31.0 | 1.0 | 96.8 | 620.0 | 1.0 | 99.8 | 2100.0 | 1.7 | 99.9 |
| 06/30/91 | 41.0 | 1.0 | 97.6 | 1.0 | 1.0 | ---- | 110.0 | 1.0 | 99.1 | 360.0 | 1.2 | 99.7 |
| 08/02/91 | 88.0 | 1.0 | 98.9 | 5.0 | 1.0 | 80.0 | 340.0 | 1.0 | 99.7 | 1200.0 | 1.0 | 99.9 |
| 09/09/91 | 10.0 | 1.0 | 90.0 | 10.0 | 1.0 | 90.0 | 390.0 | 1.0 | 99.7 | 1700.0 | 1.0 | 99.9 |
| 10/7/91 | 74.0 | 1.0 | 98.6 | 1.0 | 1.0 | ---- | 320.0 | 1.0 | 99.7 | 1100.0 | 1.0 | 99.9 |
| 11/04/91 | 130.0 | 1.0 | 99.2 | 1.0 | 1.0 | ---- | 290.0 | 1.0 | 99.7 | 1400.0 | 1.0 | 99.9 |
| 12/02/91 | 62.0 | 1.0 | 98.4 | 1.0 | 1.0 | ---- | 270.0 | 1.0 | 99.6 | 1000.0 | 1.0 | 99.9 |
| 01/06/92 | 100.0 | 1.0 | 99.0 | 1.0 | 1.0 | ---- | 250.0 | 1.0 | 99.6 | 2000.0 | 1.1 | 99.9 |
| 02/03/92 | 150.0 | 1.7 | 98.9 | 77.0 | 1.0 | 98.7 | 390.0 | 4.0 | 99.0 | 1900.0 | 1.3 | 99.9 |
| 03/02/92 | 160.0 | 1.0 | 99.4 | 4.9 | 1.0 | 79.6 | 420.0 | 1.0 | 99.8 | 1300.0 | 1.0 | 99.9 |
| 04/01/92 | 100.0 | 1.0 | 99.0 | 1.0 | 1.0 | ---- | 490.0 | 1.0 | 99.8 | 2800.0 | 1.0 | 100.0 |
| 05/06/92 | 35.0 | 1.0 | 97.1 | 2.0 | 1.0 | 50.0 | 210.0 | 1.0 | 99.5 | 1400.0 | 1.0 | 99.9 |
| 06/01/92 | 61.1 | 1.0 | 98.4 | 1.0 | 1.0 | ---- | 185.0 | 1.0 | 99.5 | 530.0 | 1.0 | 99.8 |
| 07/01/92 | 76.0 | 1.0 | 98.7 | 1.3 | 1.0 | 23.1 | 156.0 | 1.0 | 99.4 | 776.0 | 1.0 | 99.9 |
| 08/10/90 | 28.0 | 1.0 | 96.4 | 33.0 | 1.0 | 97.0 | 211.0 | 1.0 | 99.5 | 830.0 | 1.0 | 99.9 |
| 09/11/92 | 67.0 | 1.0 | 98.5 | 112.0 | 1.0 | 99.1 | 185.0 | 1.0 | 99.5 | 747.0 | 1.0 | 99.9 |
| 10/01/92 | 58.0 | 1.0 | 98.3 | 1.0 | 1.0 | ---- | 164.0 | 1.0 | 99.4 | 964.0 | 1.0 | 99.9 |
| 11/02/92 | 114.0 | 1.0 | 99.1 | 18.0 | 1.0 | 94.4 | 261.0 | 1.0 | 99.6 | 1140.0 | 1.0 | 99.9 |
| 12/01/92 | 70.0 | 1.0 | 98.6 | 1.0 | 1.0 | ---- | 194.0 | 1.0 | 99.5 | 875.0 | 1.0 | 99.9 |
| 01/04/93 | 74.0 | 1.0 | 98.6 | 24.0 | 1.0 | 95.8 | 220.0 | 1.9 | 99.1 | 1020.0 | 1.0 | 99.9 |
| 02/01/93 | 46.0 | 1.0 | 97.8 | 1.0 | 1.0 | ---- | 140.0 | 1.0 | 99.3 | 860.0 | 1.0 | 99.9 |
| 03/01/93 | 1.0 | 1.0 | ---- | 328 | 1.0 | 96.9 | 180.0 | 1.0 | 99.4 | 1200.0 | 1.0 | 99.9 |
| 04/06/93 | 35.0 | 1.0 | 97.1 | 268 | 1.0 | 96.2 | 120.0 | 1.0 | 99.2 | 630.0 | 3.8 | 99.4 |
| 05/05/93 | 30.0 | 1.0 | 96.7 | 568 | 1.0 | 98.2 | 86.0 | 1.0 | 98.8 | 520.0 | 1.0 | 99.8 |
| 06/08/93 | 64.0 | 1.0 | 98.4 | 528 | 1.0 | 98.1 | 161.0 | 1.0 | 99.4 | 710.0 | 1.0 | 99.9 |
| 07/12/93 | 18.0 | 1.0 | 94.4 | 13.0 | 1.0 | 92.3 | 140.0 | 6.7 | 95.2 | 750.0 | 39.0 | 94.8 |
| 08/13/93 | 37.0 | 1.0 | 97.3 | 1.0 | 1.0 | ---- | 150.0 | 1.0 | 99.3 | 840.0 | 1.0 | 99.9 |
| 08/13/93* | 45.0 | 0.2 | 99.6 | 10.0 | 2.0 | 80.0 | 170.0 | 0.2 | 99.9 | 840.0 | 0.2 | 100.0 |
| 09/15/93 | 35.0 | 1.0 | 97.1 | 1.0 | 1.0 | ---- | 160.0 | 1.0 | 99.4 | 940.0 | 1.0 | 99.9 |
| 10/14/93 | 58.0 | 1.0 | 98.3 | 1.0 | 1.0 | ---- | 200.0 | 1.0 | 99.5 | 940.0 | 1.0 | 99.9 |

Note: Influent detection limits for 08/02/81 and 09/09/91 are 5.0 ug/l and 10.0 ug/l, respectively which is higher than previous detection limits.
B indicates analyte was detected in the laboratory blank.

*: Duplicate analysis

002843

AIR STRIPPER PERFORMANCE
(CONTINUED)
Sparton Technology, Inc.
Albuquerque, New Mexico

(all concentrations in micrograms per liter (ppb))

| DATE SAMPLED | 1,1-Dichloroethylene [-----] | | | Methylene Chloride [-----] | | | 1,1,1-Trichloroethane [-----] | | | Trichloroethylene [-----] | | |
|-----------------|---------------------------------|----------|----------------------|-------------------------------|----------|----------------------|----------------------------------|----------|----------------------|------------------------------|----------|----------------------|
| | INFLUENT | EFFLUENT | PERCENT REDUCTION | INFLUENT | EFFLUENT | PERCENT REDUCTION | INFLUENT | EFFLUENT | PERCENT REDUCTION | INFLUENT | EFFLUENT | PERCENT REDUCTION |
| 11/03/93 | 88.0 | 1.0 | 98.9 | 49.0 | 1.0 | 98.0 | 280.0 | 1.0 | 99.6 | 1400.0 | 1.2 | 99.9 |
| 12/20/93 | 42.0 | 1.0 | 97.6 | 1.0 | 1.0 | ---- | 170.0 | 1.0 | 99.4 | 1000.0 | 1.0 | 99.9 |
| 01/04/94 | 58.0 | 1.0 | 98.3 | 1.0 | 1.0 | ---- | 210.0 | 1.0 | 99.5 | 1200.0 | 1.5 | 99.9 |
| 02/09/94 | 90.0 | 1.0 | 98.9 | 1.0 | 1.0 | ---- | 250.0 | 1.0 | 99.6 | 1200.0 | 2.6 | 99.8 |
| 03/04/94 | 53.0 | 1.0 | 98.1 | 1.0 | 1.0 | ---- | 200.0 | 1.0 | 99.5 | 1100.0 | 1.0 | 99.9 |
| 04/08/94 | 1.0 | 1.0 | ---- | 1.0 | 1.0 | ---- | 120.0 | 1.0 | 99.2 | 690.0 | 1.0 | 99.9 |
| 05/02/94 | 78.0 | 1.5 | 98.1 | 41B | 1.7B | 95.9 | 250.0 | 1.0 | 99.6 | 760.0 | 1.0 | 99.9 |
| 06/06/94 | 30.0 | 1.0 | 96.7 | 1.0 | 1.0 | ---- | 93.0 | 1.0 | 98.9 | 570.0 | 1.0 | 99.8 |
| 07/14/94 | 34.0 | 1.0 | 97.1 | 1.0 | 1.0 | ---- | 120.0 | 1.0 | 99.2 | 620.0 | 1.0 | 99.8 |
| 08/01/94 | 22.0 | 1.0 | 95.5 | 35.0 | 1.2 | 96.6 | 110.0 | 1.0 | 99.1 | 670.0 | 1.0 | 99.9 |
| 09/01/94 | 53.0 | 5.0 | 90.6 | <100 | <10 | ---- | 130.0 | 5.0 | 96.2 | 740.0 | 5.0 | 99.3 |
| 10/03/94 | 1.0 | 1.0 | ---- | 1.0 | 1.0 | ---- | 99.0 | 1.0 | 99.0 | 630.0 | 1.0 | 99.8 |
| 11/01/94 | 75.0 | 1.0 | 98.7 | 10.0 | 2.0 | 80.0 | 240.0 | 1.0 | 99.6 | 1300.0 | 1.0 | 99.9 |
| 12/02/94 | 25.0 | 1.0 | 96.0 | 25.0 | 1.0 | 96.0 | 280.0 | 1.0 | 99.6 | 1500.0 | 1.5 | 99.9 |
| 01/03/95 | 54.0 | 1.0 | 98.1 | <40 | 1.0 | ---- | 210.0 | 1.0 | 99.5 | 1200.0 | 1.0 | 99.9 |
| 02/02/95 | <25.0 | 1.0 | ---- | <25.0 | 1.0 | ---- | 140.0 | 1.0 | 99.3 | 900.0 | 1.0 | 99.9 |
| 03/01/95 | 8.8 | 1.0 | 88.6 | 1.0B | 1.0 | ---- | 33.0 | 1.0 | 97.0 | 220.0 | 1.0 | 99.5 |
| 04/03/95 | 26.0 | 1.0 | 96.2 | 1.2 | 1.5 B | ---- | 91.0 | 1.0 | 98.9 | 630.0 | 1.0 | 99.8 |
| 05/01/95 | 39.0 | 1.0 | 97.4 | <25.0 | 1.0 | ---- | 100.0 | 1.0 | 99.0 | 760.0 | 1.0 | 99.9 |
| 06/01/95 | 13.0 | 1.0 | 92.3 | 10B | 2.2B | ---- | 35.0 | 1.0 | 97.1 | 240.0 | 1.0 | 99.6 |
| <hr/> | | | | | | | | | | | | |
| AVERAGES | 62.3 | 0.9 | 98.6 | 101.2 | 1.6 | 98.4 | 245.3 | 1.3 | 99.5 | 978.7 | 2.5 | 99.7 |

002844