

**SPARTON**

**SPARTON TECHNOLOGY**

March 27, 1996



*RnK x*  
*Barbara*  
*FILE-ST/kes*

Technical Section (6H-CD)  
RCRA Enforcement Branch  
Hazardous Waste Management Division  
U.S. Environmental Protection Agency  
1445 Ross Avenue  
Dallas, Texas 75202-2733

Attention: Mr. Ronald Crossland

Reference: Monthly Report  
Sparton Technology, Inc.

Gentlemen:

This is the monthly progress report for Sparton Technology, Inc.'s Coors Road Facility, located in Albuquerque, New Mexico, as required in Section IV.C of the Consent Order. This report summarizes activities performed at the site during the month of February 1996

Site Activities

1. Air stripper removal efficiencies continue to average about 99 percent for the measured indicator parameters. During the month, 22,400 gallons of recovered groundwater were treated, bringing the total volume treated to date to 3,559,300 gallons. Air stripper performance data is included in Attachment 1.


002886

March 27, 1996  
Technical Section (6H-CD)  
RCRA Enforcement Branch  
Hazardous Waste Management Division  
U.S. Environmental Protection Agency  
Page 2

This concludes our progress report for the month of February 1996. If you have any questions, please contact the undersigned.

Very truly yours,

SPARTON TECHNOLOGY, INC.



*for*  
Richard D. Mico  
Vice President/General Manager

Attachments: (as stated)

cc: NMED  
J. Appel  
P. Chandler  
J. Wakefield  
G. Richardson

002887

**ATTACHMENT 1**

**Air Stripper Performance Data**

**002888**

AIR STRIPPER PERFORMANCE  
(CONTINUED)  
Sparton Technology, Inc.  
Albuquerque, New Mexico

(all concentrations in micrograms per liter (ppb) )

DATE SAMPLED	1,1-Dichloroethylene			Methylene Chloride			1,1,1-Trichloroethane			Trichloroethylene		
	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION
04/01/91	72.0	1.0	98.6	1.0	1.0	—	150.0	1.0	—	820.0	1.0	99.9
05/06/91	22.0	1.0	95.5	1.0	1.0	—	140.0	1.0	99.3	770.0	1.0	99.9
06/03/91	180.0	1.0	99.4	31.0	1.0	96.8	620.0	1.0	99.8	2100.0	1.7	99.9
06/30/91	41.0	1.0	97.6	1.0	1.0	—	110.0	1.0	99.1	360.0	1.2	99.7
08/02/91	88.0	1.0	98.9	5.0	1.0	80.0	340.0	1.0	99.7	1200.0	1.0	99.9
09/09/91	10.0	1.0	90.0	10.0	1.0	90.0	390.0	1.0	99.7	1700.0	1.0	99.9
10/7/91	74.0	1.0	98.6	1.0	1.0	—	320.0	1.0	99.7	1100.0	1.0	99.9
11/04/91	130.0	1.0	99.2	1.0	1.0	—	290.0	1.0	99.7	1400.0	1.0	99.9
12/02/91	62.0	1.0	98.4	1.0	1.0	—	270.0	1.0	99.6	1000.0	1.0	99.9
01/06/92	100.0	1.0	99.0	1.0	1.0	—	250.0	1.0	99.6	2000.0	1.1	99.9
02/03/92	150.0	1.7	98.9	77.0	1.0	98.7	390.0	4.0	99.0	1900.0	1.3	99.9
03/02/92	160.0	1.0	99.4	4.9	1.0	79.6	420.0	1.0	99.8	1300.0	1.0	99.9
04/01/92	100.0	1.0	99.0	1.0	1.0	—	490.0	1.0	99.8	2800.0	1.0	100.0
05/06/92	35.0	1.0	97.1	2.0	1.0	50.0	210.0	1.0	99.5	1400.0	1.0	99.9
06/01/92	61.1	1.0	98.4	1.0	1.0	—	185.0	1.0	99.5	530.0	1.0	99.8
07/01/92	76.0	1.0	98.7	1.3	1.0	23.1	156.0	1.0	99.4	776.0	1.0	99.9
08/10/90	28.0	1.0	96.4	33.0	1.0	97.0	211.0	1.0	99.5	830.0	1.0	99.9
09/11/92	67.0	1.0	98.5	112.0	1.0	99.1	185.0	1.0	99.5	747.0	1.0	99.9
10/01/92	58.0	1.0	98.3	1.0	1.0	—	164.0	1.0	99.4	964.0	1.0	99.9
11/02/92	114.0	1.0	99.1	18.0	1.0	94.4	261.0	1.0	99.6	1140.0	1.0	99.9
12/01/92	70.0	1.0	98.6	1.0	1.0	—	194.0	1.0	99.5	875.0	1.0	99.9
01/04/93	74.0	1.0	98.6	24.0	1.0	95.8	220.0	1.9	99.1	1020.0	1.0	99.9
02/01/93	46.0	1.0	97.8	1.0	1.0	—	140.0	1.0	99.3	860.0	1.0	99.9
03/01/93	1.0	1.0	—	32B	1.0	96.9	180.0	1.0	99.4	1200.0	1.0	99.9
04/06/93	35.0	1.0	97.1	26B	1.0	96.2	120.0	1.0	99.2	630.0	3.8	99.4
05/05/93	30.0	1.0	96.7	56B	1.0	98.2	86.0	1.0	98.8	520.0	1.0	99.8
06/08/93	64.0	1.0	98.4	52B	1.0	98.1	161.0	1.0	99.4	710.0	1.0	99.9
07/12/93	18.0	1.0	94.4	13.0	1.0	92.3	140.0	6.7	95.2	750.0	39.0	94.8
08/13/93	37.0	1.0	97.3	1.0	1.0	—	150.0	1.0	99.3	840.0	1.0	99.9
08/13/93*	45.0	0.2	99.6	10.0	2.0	80.0	170.0	0.2	99.9	840.0	0.2	100.0
09/15/93	35.0	1.0	97.1	1.0	1.0	—	160.0	1.0	99.4	940.0	1.0	99.9
10/14/93	58.0	1.0	98.3	1.0	1.0	—	200.0	1.0	99.5	940.0	1.0	99.9

Note: Influent detection limits for 08/02/81 and 09/09/91 are 5.0 ug/l and 10.0 ug/l, respectively which is higher than previous detection limits.

B indicates analyte was detected in the laboratory blank.

\*: Duplicate analysis

002889

Sparton Technology, Inc.  
Albuquerque, New Mexico

(all concentrations in micrograms per liter (ppb) )

DATE SAMPLED	1,1-Dichloroethylene			Methylene Chloride			1,1,1-Trichloroethane			Trichloroethylene		
	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION	INFLUENT	EFFLUENT	PERCENT REDUCTION
11/03/93	88.0	1.0	98.9	49.0	1.0	98.0	280.0	1.0	99.6	1400.0	1.2	99.9
12/20/93	42.0	1.0	97.6	1.0	1.0	—	170.0	1.0	99.4	1000.0	1.0	99.9
01/04/94	58.0	1.0	98.3	1.0	1.0	—	210.0	1.0	99.5	1200.0	1.5	99.9
02/09/94	90.0	1.0	98.9	1.0	1.0	—	250.0	1.0	99.6	1200.0	2.6	99.8
03/04/94	53.0	1.0	98.1	1.0	1.0	—	200.0	1.0	99.5	1100.0	1.0	99.9
04/08/94	1.0	1.0	—	1.0	1.0	—	120.0	1.0	99.2	690.0	1.0	99.9
05/02/94	78.0	1.5	98.1	41B	1.7B	95.9	250.0	1.0	99.6	760.0	1.0	99.9
06/06/94	30.0	1.0	96.7	1.0	1.0	—	93.0	1.0	98.9	570.0	1.0	99.8
07/14/94	34.0	1.0	97.1	1.0	1.0	—	120.0	1.0	99.2	620.0	1.0	99.8
08/01/94	22.0	1.0	95.5	35.0	1.2	96.6	110.0	1.0	99.1	670.0	1.0	99.9
09/01/94	53.0	5.0	90.6	<100	<10	—	130.0	5.0	96.2	740.0	5.0	99.3
10/03/94	1.0	1.0	—	1.0	1.0	—	99.0	1.0	99.0	630.0	1.0	99.8
11/01/94	75.0	1.0	98.7	10.0	2.0	80.0	240.0	1.0	99.6	1300.0	1.0	99.9
12/02/94	25.0	1.0	96.0	25.0	1.0	96.0	280.0	1.0	99.6	1500.0	1.5	99.9
01/03/95	54.0	1.0	98.1	<40	1.0	—	210.0	1.0	99.5	1200.0	1.0	99.9
02/02/95	<25.0	1.0	—	<25.0	1.0	—	140.0	1.0	99.3	900.0	1.0	99.9
03/01/95	8.8	1.0	88.6	1.0B	1.0	—	33.0	1.0	97.0	220.0	1.0	99.5
04/03/95	26.0	1.0	96.2	1.2	1.5 B	—	91.0	1.0	98.9	630.0	1.0	99.8
05/01/95	39.0	1.0	97.4	<25.0	1.0	—	100.0	1.0	99.0	760.0	1.0	99.9
06/01/95	13.0	1.0	92.3	10B	2.2B	—	35.0	1.0	97.1	240.0	1.0	99.6
07/05/95	10.0	1.0	90.0	5.4	1.0	81.5	25.0	1.0	96.0	200.0	1.0	99.5
08/03/95	9.4	1.0	89.4	3.8	1.0	73.7	24.0	1.0	95.8	210.0	1.0	99.5
09/01/95	9.4	1.0	89.4	3.3	1.1	66.7	24.0	1.0	95.8	200.0	1.0	99.5
10/02/95	9.8	1.0	89.8	1.0	1.0	—	27.0	1.0	96.3	260.0	1.0	99.6
11/01/95	10.0	1.0	90.0	2.3	1.0	56.5	28.0	1.0	96.4	230.0	1.0	99.6
12/01/95	10.0	1.0	90.0	2.2	1.0	54.5	28.0	1.0	96.4	280.0	1.0	99.6
01/02/96	22.0	1.0	95.5	8.9B	1.4B	84.2	60.0	1.0	98.3	520.0	1.0	99.8
02/01/96	18.0	1.0	94.4	1.0	1.0	—	52.0	1.0	98.1	520.0	1.0	99.8
AVERAGES	62.4	0.9	98.6	92.7	1.6	98.3	226.9	1.3	99.4	919.9	2.4	99.7

002890