

Dennis McCulla



GARY E. JOHNSON
GOVERNOR

State of New Mexico
ENVIRONMENT DEPARTMENT
Ground Water Quality Bureau
Harold Runnels Building
1190 St. Francis Drive, P.O. Box 26110
Santa Fe, New Mexico 87502
(505) 827-2918 phone
(505) 827-2965 fax



PETER MAGGIORE
Secretary

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

RECEIVED

January 27, 1999

JAN 28 1999

Mr. Richard D. Mico, V.P. & General Manager
Sparton Technology, Inc.
4901 Rockaway Boulevard SE
Rio Rancho, New Mexico 87124-4469

GROUND WATER BUREAU

RE: Approval of Revised Infiltration Gallery Plans, DP-1184, Sparton Technology, Inc. - Coors Road Facility.

Dear Mr. Mico:

The New Mexico Environment Department (NMED) is in receipt of the revised infiltration gallery plans for discharge plan DP-1184, Sparton Technology, Inc. - Coors Road Facility (Sparton). The discharge plan application was originally submitted by Mr. Richard D. Mico for the discharge of up to 864,000 gallons per day (gpd) of treated contaminated ground water from the Sparton Facility ground water remediation system. The discharge plan was approved on June 26, 1998. The facility is located in northwest Albuquerque in projected Section 7, T11N, R3E, Bernalillo County.

Specific Requirement #4 of the approved discharge plan, DP-1184 stated the following:

Sparton will design and construct the infiltration gallery for a discharge of 200 gallons per minute (gpm). However, if the infiltration gallery must be sized greater than 200 gpm, Sparton will submit revised plans and specifications for system modification to NMED for approval prior to discharging more than 200 gpm.

On January 15, 1998, Mr. Gary Richardson, P.E. of METRIC Corporation (METRIC) submitted revised plans for an infiltration gallery proportioned to accept up to 300 gpm of treated contaminated water. NMED has reviewed the revised infiltration gallery plans for DP-1184, and hereby approves the revised plans.

DP-1184
Mr. Mico
January 27, 1999
Page 2

If you have any questions regarding this approval, please contact Vickie Maranville at (505) 827-0652 or Karen McCormack at (505) 827-2900.

Sincerely,



Marcy Leavitt, Chief
Ground Water Quality Bureau

ML:VM

Enclosures: NMED Monitor Well Construction and Abandonment Guidelines, DP Summary

xc: Dennis McQuillan, NMED/GWQB
Ana Marie Ortiz, Assistant General Counsel, NMED Office of General Counsel
L. William Bartels, Dist. Manager, NMED Dist. 1
NMED Albuquerque Field Office
Gary O'Dea, Esq., City of Albuquerque
Michael Donnellan, Esq., US Department of Justice
Charlie DeSaillan, Esq., NM Office of Attorney General and ONRT, P.O. Box. 1508, Santa Fe, New Mexico 87504
Gary Richardson, P.E., METRIC Corporation, 8429 Washington Place NE., Albuquerque, NM 87113