

HURST ENGINEERING SERVICES

1915 Fairfax St • Denver, CO 80220

Email: tonyhurst@earthlink.net

MONTHLY PROGRESS REPORT
For month ending December 31st, 2006**CV-97-0206 (D.N.M)**
Albuquerque v. Sparton Technology, Inc.

01/09/07

Tasks Completed:

- A. Groundwater Monitoring Plan
 - Continued to evaluate Monitoring Wells replacement needs.
 - Completed the 4th Quarter GWMP sampling QA/QC in November.

- B. Public Involvement Plan
 - Approval of the 2002-2004 combined Fact is an ongoing action item with Chuck Barnes (EPA) pursuant to May 11th 2006 on-site meeting and agreements.

- C. Deep Flow Zone System
 - Continued with the implementation of the MW-79 Work-Plan.
 - Continued with the analysis of the MW-79 pump test data (SSP) and analysis of the water samples collected during the test.

- D. Assessment of Aquifer Restoration
 - Formal approvals of the 2003 and 2004 Annual reports are an ongoing action item with Chuck Barnes (EPA) (pursuant to May 11th 2006 on-site meeting and agreements).

- E. Offsite-Containment System
 - The system ran 93.54 % of the time and pumped 10,306,400 (average of 210.6 gpm). On December 14th the system was shut down for 0.08 hours to allow testing of the shut off floats. On December 30th there was a power outage for 8.6 hours. On 16.33 on January 2nd the system shut down for 43.98 hours (until 12.33 on January 4th) as a result of a battery voltage drop in the infiltration gallery signaling a high water level (false reading).

- F. Source Containment System
 - The system ran 100.0 % of the time and pumped 2,176,410 gallons (average of 44.4 gpm).
 - Resolution of high water levels experienced in the discharge sump achieved by limiting flows to Ponds 3 & 4 as of December 1st.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@earthlink.net

G. Other

- Please note a change of address for Sparton Coordinator Tony Hurst

New Address:1915 Fairfax St.
Denver, CO 80220**New Phone Number:**

303-388-8613

Cell remains 719-649-1944

Tasks Planned:**H. Groundwater Monitoring Plan**

- Continue to evaluate Monitoring Wells replacement needs.

I. Public Involvement Plan

- Continue to seek approval of the 2002-2004 combined Fact by Chuck Barnes (EPA) pursuant to May 11th on-site meeting and agreements.

J. Deep Flow Zone System

- Continue with the implementation of the MW-79 Work-Plan.
- Continue with the analysis of the MW-79 pump test data (SSP) and analysis of the water samples collected during the test.

K. Assessment of Aquifer Restoration

- Continue to seek formal approvals of the 2003 and 2004 Annual reports by Chuck Barnes (EPA) pursuant to May 11th on-site meeting and agreements.
- Work will begin on the 2006 Annual Report.

L. Offsite-Containment System**M. Source Containment System**

- Continue to research the reason for the high water levels being experienced in the discharge sump.

N. Other**O. Problems Encountered or Anticipated:**

By:



Tony Hurst

Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Barnes (EPA: 214-665-7264)
Mr. John Kieling (NMED: 505-476-6030)

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@earthlink.net

FAX : 505-476-6030

To: John E. Kieling

3 Pages including this

*****Please note new address and Phone number *****

-Monthly report for December 2006 (CV-97-0206 (D.N.M - Albuquerque v. Sparton Technology, Inc.)

From:
Tony Hurst
Project Coordinator for Sparton.

Phone and Fax: (303) 388-8613 ♦ Cell: (719) 649-1944