

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@earthlink.net

MONTHLY PROGRESS REPORT
For month ending May 31st, 2007**CV-97-0206 (D.N.M)**
Albuquerque v. Sparton Technology, Inc.

06/09/07

Tasks Completed:**A. Groundwater Monitoring Plan**

- Continued to evaluate Monitoring Wells replacement needs.
- Completed the 1st Quarter GWMP sampling QA/QC.
- Performed the 2nd Quarter GWMP sampling May 15th - 25th.
-

B. Public Involvement Plan

-

C. Deep Flow Zone System

- Continued with the implementation of the MW-79 Work-Plan.
- Continued with the analysis of the MW-79 pump test data (SSP) and analysis of the water samples collected during the test.

D. Assessment of Aquifer Restoration

- Completed and distributed the 2006 Annual Report.

E. Offsite-Containment System

- Working on replacing of the radio signal transmitter for the infiltration gallery.
- The system ran 100.0 % of the time and pumped 10,028,700 (average of 224.6 gpm).

F. Source Containment System

- Rodgers Drilling replaced CW2 pump. Although it was found to be worn, the replacement pump is not pumping according to the specified performance curve.
- The system ran 82.9 % of the time and pumped 1,608,700 gallons (average of 36.0 gpm). One outage occurred (May 11th to May 16th) for 127.4 hours. CW2 pump was replaced by Rodgers Drilling.

G. Other

-

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@earthlink.net

Tasks Planned:**H. Groundwater Monitoring Plan**

- Continue to evaluate Monitoring Wells replacement needs.

I. Public Involvement Plan

- Determine a course of action with Nick Stone (EPA - pursuant to approving a Fact Sheet for distribution) that is sufficient to bring the project up to date with the Public Involvement Plan requirements.
-

J. Deep Flow Zone System

- Continue with the implementation of the MW-79 Work-Plan.
- Continue with the analysis of the MW-79 pump test data (SSP) and analysis of the water samples collected during the test.
-

K. Assessment of Aquifer Restoration

- Determine with Nick Stone a process for EPA (and then NMED) approval of recent Annual reports.

L. Offsite-Containment System

- Continue to work on the replacement of the radio signal transmitter for the infiltration gallery.

M. Source Containment System

- During June the flow meter filter on CW2 pump will be removed to determine whether clogging is the cause for reduced pump output.

N. Other

-

O. Problems Encountered or Anticipated:

-

By:



Tony Hurst
Project Coordinator for Sparton.

Cc: By fax to Mr. Nick Stone (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)

ST07

FAX

To: John Kieling (505 476 6030)

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M) Albuquerque v. Sparton Technology, Inc.

Date	No of Pages	Month
4/10/07	(3 total)	Attached is the March 2007 Monthly Report
5/9/07	✓	" " " APRIL " " "
6/9/07	✓	" " " MAY " " "

Please call me at 719-649-1944 if you have any questions

Thanks
Tony Hurst
Project Coordinator for Sparton Technology, Inc.

