

ST

ENTERED

# FAX

To: John Kieling (505 476 6030)


From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M) Albuquerque v. Sparton Technology, Inc.

Date	No of Pages	Month
2/7/08	(3 total)	Attached is the January 2008 Monthly Report
3/5/08	"	" " " February " " "
4/5/08	"	" " " March " " "
5/8/08	"	" " " April " " "
6/7/08	"	" " " MAY " " "

Please call me at 719-649-1944 if you have any questions

Thanks  
Tony Hurst  
Project Coordinator for Sparton Technology, Inc.



**HURST ENGINEERING SERVICES**

1915 Fairfax St\* Denver, CO 80220

Email: tonyhurst@earthlink.net

**MONTHLY PROGRESS REPORT**For month ending May 31<sup>st</sup>, 2008**CV-97-0206 (D.N.M)****Albuquerque v. Sparton Technology, Inc.**

06/07/08

***Tasks Completed:*****A. Groundwater Monitoring Plan**

- Reported on evaluation of Monitoring Wells replacement needs in the 2007 Annual Report.
- Continued to coordinate with the Contractor that is installing a new fire hydrant adjacent to MW-37R.
- Performed the 2<sup>nd</sup> quarter data collection (sampling) for the GWMP - May 13<sup>th</sup> through 15<sup>th</sup>.
- Worked on the 1st quarter QA/QC for the GWMP.
- Completed the evaluation of the 1998 through 2007 dissolved oxygen and oxidation reduction potential data for all the monitoring wells sampled. Reported in the 2007 Annual Report the recommendation to discontinue collection of this data.

**B. Public Involvement Plan**

-

**C. Deep Flow Zone System**

- Reported on the completion of the implementation of the MW-79 Work-Plan in Appendix C of the 2007 Annual Report.

**D. Assessment of Aquifer Restoration**

- Completed and distributed the 2007 Annual report.

**E. Offsite-Containment System**

- The system ran 96.05% of the time and pumped 9,877,600 gallons (average of 214.3 gpm). There were two outages: The first was on May 5<sup>th</sup> for 2.5 hours and was caused by a power outage. The second on May 27<sup>th</sup>, 28<sup>th</sup> for 27.83 hours was to allow for replacement of the discharge check valve on CW-1 air stripper.

**F. Source Containment System**

- Continued with the development of a work-plan to achieve clean closure of the pond and sump area.
- The system ran 100.0 % of the time and pumped 2,289,200 gallons (average of 49.7 gpm).

**HURST ENGINEERING SERVICES**

1915 Fairfax St\* Denver, CO 80220

Email: tonyhurst@earthlink.net

G. Other**Tasks Planned:**H. Groundwater Monitoring Plan

- Coordinate with the Contractor that is installing a new fire hydrant adjacent to MW-37R.
- Complete the 1st quarter QA/QC for the GWMP.
- The evaluation of Monitoring Wells replacement needs includes plug and abandon MW-33 and monitor wells 9, 13, 48, 53, 57 and 58 for possible replacement. Annual Report Paragraph 7-2.

I. Public Involvement Plan

- Continue work on the 5-year summary Fact sheet.
- Distribute the Fact Sheet following EPA approval. Collected names and addresses for the affected parties.

J. Deep Flow Zone System

-

K. Assessment of Aquifer Restoration

- Pursue approval of the 2006 (and earlier if necessary) Annual Report.

L. Offsite-Containment System

-

M. Source Containment System

- Continue with the development of a work-plan to achieve clean closure of the pond and sump area.

N. Other

-

O. Problems Encountered or Anticipated:

-

By:



Tony Hurst  
Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)  
Mr. John Kieling (NMED: 505-476-6030)