

ENTERED

FAX

To: John Kieling (505 476 6030)

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M) Albuquerque v. Sparton Technology, Inc.

Date	No of Pages (3 total)	Month
2/7/08	"	Attached is the January 2008 Monthly Report
3/5/08	"	" " " February " " "
4/5/08	"	" " " March " " "
5/8/08	"	" " " April " " "
6/7/08	"	" " " MAY " " "
7/9/08	"	" " " June " " "
8/6/08	"	" " " JULY " " "
9/6/08	"	" " " August " " "
10/7/08	"	" " " September " " "
11/8/08	"	" " " October " " "
12/8/08	"	" " " November " " "
01/09/09	"	" " " December " " "

Please call me at 719-649-1944 if you have any questions

Thanks
Tony Hurst
Project Coordinator for Sparton Technology, Inc.



HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@earthlink.net

MONTHLY PROGRESS REPORT
For month ending December 31st, 2008**CV-97-0206 (D.N.M)**
Albuquerque v. Sparton Technology, Inc.

01/08/09

Tasks Completed:**A. Groundwater Monitoring Plan**

- QA/QC for the 4th quarter GWMP sampling started in December.
- Deepened MW-53 in December (17th through the 19th).
- Continued to evaluate Monitoring Wells replacement needs. See Annual Report Paragraph 7-2.

B. Public Involvement Plan

-

C. Deep Flow Zone System

-

D. Assessment of Aquifer Restoration

-

E. Offsite-Containment System

- Completed the reprogramming of the infiltration gallery solar panel and radio system but the system continued to exhibit communication errors December 25th - 29th. A temporary solution was implemented and the issue appears to be resolved as of January 5th.
- The system ran 90.1 % of the time and pumped 8,259,600 gallons (average of 205.6 gpm). There were 8 outages totaling 66.03 hours.
 - o 3 were power outages (December 1st, 22nd and 29th) totaling 4.0 hours.
 - o 4 were infiltration gallery radio communication failures (December 26th, 27th, 28th and 29th) totaling 53.15 hours.
 - o 1 was the gallery float switch failure (December 25th) for 8.88 hours.

F. Source Containment System

- Sampled scale December 11th from the air strippers, tested, and advised NMED HWB the waste was non-hazardous.
- Continued with the development of a work-plan to achieve clean closure of the pond and sump area.
- The system ran 100.00 % of the time and pumped 1,898,220 gallons (average of 47.1 gpm).

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@earthlink.net

G. Other***Tasks Planned:*****H. Groundwater Monitoring Plan**

- Continue to evaluate Monitoring Wells replacement needs. See Annual Report Paragraph 7-2.
- QA/QC for the 4th quarter GWMP sampling will be completed in January.
- Complete and mail the 2008 3rd and 4th quarters Ground Water Monitoring Plan semi annual progress report.
- Perform the 4th quarters sampling of the deepened MW-53.

I. Public Involvement Plan

- Continue work on the 5-year summary Fact sheet.
- Distribute the Fact Sheet following EPA approval. Collected names and addresses for the affected parties.

J. Deep Flow Zone System

-

K. Assessment of Aquifer Restoration

- Pursue approval of the 2007 (and earlier if necessary) Annual Report.

L. Offsite-Containment System

- Troubleshoot the reprogramming of the infiltration gallery solar panel and radio system (completed January 5th).

M. Source Containment System

- Continue with the development of a work-plan to achieve clean closure of the pond and sump area.
- Work on the program for the CW-1 monitoring software.

N. Other

-

O. Problems Encountered or Anticipated:

-

By:



Tony Hurst

Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)