



FAX

To: John Kieling (505 476 6030)

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M) Albuquerque v. Sparton Technology, Inc.

Date	No of Pages (3 total)	Month
3/6/09	(3 total)	Attached is the February 2009 Monthly Report
4/3/09	"	" " " March " " "
5/8/09	"	" " " April " " "
6/7/09	"	" " " MAY " " "
7/9/09	"	" " " June " " "

Please call me at 719-649-1944 if you have any questions

Thanks
Tony Hurst
Project Coordinator for Sparton Technology, Inc.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@earthlink.net

MONTHLY PROGRESS REPORT
For month ending June 30th, 2009**CV-97-0206 (D.N.M)**
Albuquerque v. Sparton Technology, Inc.

07/09/09

Tasks Completed:**A. Groundwater Monitoring Plan**

- Continued to evaluate Monitoring Wells replacement needs.
- The plugging plan for MW-33 was approved by the State Engineers office on June 27th. It will be plugged during July.

B. Public Involvement Plan

- Distributed the 5-year summary Fact sheet (2002 through 2006) on June 27th.

C. Deep Flow Zone System

-

D. Assessment of Aquifer Restoration

- Completed work on the 2008 Annual Report and submitted to EPA-NMED June 12th 2009.
- Continuing to work on closing out the Dispute Resolution following agreement on issues relating to location of a proposed new monitoring well. Continuing to work on finding a lot (to lease) to store the equipment.

E. Offsite-Containment System

- The system ran 99.91% of the time and pumped 9,605,900 gallons (average of 221.9 gpm). There was one outage on June 8th for 0.67hours – the discharge pump needed readjustment.

F. Source Containment System

- Continued with the development of a work-plan to achieve clean closure of the pond and sump area.
- The system ran 98.84% of the time and pumped 2,182,500 gallons (average of 50.6 gpm). There was one outage on June 2nd for 8.33 hours that was the result of a power outage.

G. Other

-

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@earthlink.net***Tasks Planned:*****H. Groundwater Monitoring Plan**

- Continue to evaluate Monitoring Wells replacement needs.
- Perform the 3rd quarter GWMP sampling starting August 10th.
- MW-33 will be plugged during July

I. Public Involvement Plan

- Continue to respond to inquiries relating to any Fact Sheet issues.

J. Deep Flow Zone System

-

K. Assessment of Aquifer Restoration

- Close out the Dispute Resolution following agreement on issues relating to location of a proposed new monitoring well.

L. Offsite-Containment System

-

M. Source Containment System

- Continue with the development of a work-plan to achieve clean closure of the pond and sump area.
- During July clean the four discharge meters on CW-2.


N. Other

-

O. Problems Encountered or Anticipated:

-

By:



Tony Hurst
Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)