



FAX

To: John Kieling (505 476 6030)

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M) Albuquerque v. Sparton Technology, Inc.

Date	No of Pages	Month
Date	No of Pages	Month
(3 total)		Attached is the <u>MARCH</u> 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report
(total)		Attached is the _____ 2010 Monthly Report

Please call me at 719-649-1944 if you have any questions

Thanks
Tony Hurst

Project Coordinator for Sparton Technology, Inc

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

**MONTHLY PROGRESS REPORT
For month ending March 31st, 2010****CV-97-0206 (D.N.M)****Albuquerque v. Sparton Technology, Inc.**

04/07/10

Tasks Completed:

- A. Groundwater Monitoring Plan
 - Continued to evaluate Monitoring Wells replacement needs.
 - Completed the 4th quarter GWMP QA/QC.

- B. Public Involvement Plan
 -

- C. Deep Flow Zone System
 - EPA/NMED approved augmenting CW-1 pumping rate from 225 gpm to 300 gpm and requested a work plan for the installation of MW-80 (letter of 3/26/2010). Additionally EPA/NMED set out design parameters for the well that are currently the subject of further discussion/negotiation with Sparton.

- D. Assessment of Aquifer Restoration
 - Worked on the 2009 Annual Report.

- E. Offsite-Containment System
 - The system ran 99.93 % of the time and pumped 9,809,600 gallons (average of 219.6 gpm). There were two outages for routine maintenance on the system. The first on March 15th for 0.33 hours, and the second on March 29th for 0.17 hours.
 - Submitted the Annual air permit report to the City of Albuquerque and County of Bernalillo on March 15th.

- F. Source Containment System
 - Continued with the development of a work-plan to achieve clean closure of the pond and sump area.
 - The system ran 100% of the time and pumped 1,976,600 gallons (average of 44.3 gpm).

- G. Other
 - Notified NMED Post Closure Care Permit interested parties of Sparton address change.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

Tasks Planned:

H. Groundwater Monitoring Plan

-

I. Public Involvement Plan

-

J. Deep Flow Zone System

- Resolve work plan and design parameter issues for MW-80 with EPA/NMED.

K. Assessment of Aquifer Restoration

- Begin work on MW-80 after agreement on proposed completion recommendations.
- Continue to work on the 2009 Annual Report.

L. Offsite-Containment System

-

M. Source Containment System

- Continue with the development of a work-plan to achieve clean closure of the pond and sump area.

N. Other

-

O. Problems Encountered or Anticipated:

-

By:



Tony Hurst

Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)