



FAX

To: John Kieling (505 476 6030)

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M)Albuquerque v. Sparton Technology, Inc.

Date	No of Pages	Month
2/9/11	(3 total)	Attached is the <u>January</u> 2011 Monthly Report
3/5/11	(3 total)	Attached is the <u>February</u> 2011 Monthly Report
4/8/11	(3 total)	Attached is the <u>March</u> 2011 Monthly Report
(total)		Attached is the _____ 2011 Monthly Report
(total)		Attached is the _____ 2011 Monthly Report
(total)		Attached is the _____ 2011 Monthly Report
(total)		Attached is the _____ 2011 Monthly Report
(total)		Attached is the _____ 2011 Monthly Report
(total)		Attached is the _____ 2011 Monthly Report
(total)		Attached is the _____ 2011 Monthly Report
(total)		Attached is the _____ 2011 Monthly Report
(total)		Attached is the _____ 2011 Monthly Report
(total)		Attached is the _____ 2011 Monthly Report
(total)		Attached is the _____ 2011 Monthly Report
(total)		Attached is the _____ 2011 Monthly Report

Please call me at 719-649-1944 if you have any questions

Thanks

Tony Hurst

Project Coordinator for Sparton Technology, Inc.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

MONTHLY PROGRESS REPORT

For month ending March 31st, 2011

CV-97-0206 (D.N.M)

Albuquerque v. Sparton Technology, Inc.

04/08/11

Tasks Completed:

- A. Groundwater Monitoring Plan
 - Continued to evaluate Monitoring Wells replacement needs.
 - Applications were submitted to the State Engineer, and the EPA/NMED for deepening MW-57 and closing down and abandoning MW-13 and MW-48.

- B. Public Involvement Plan
 -

- C. Deep Flow Zone System
 -

- D. Assessment of Aquifer Restoration
 -

- E. Offsite-Containment System
 - The system ran 100.0 % of the time and pumped 13,369,700 gallons (average of 296.7 gpm).
 - Sampled air stripper on March 1st.

- F. Source Containment System
 - The system ran 100.0 % of the time and pumped 2,575,100 gallons (average of 57.6 gpm).
 - Sampled air stripper on March 1st.
 - **The flow data reported for February, 2011 of 86.41 % flow time, pumped 1,992,000 gallons and average of 49.9 gpm were incorrect. The correct values are 86.45 % flow time, pumping 1,992,000 gallons remains the same, but at an average of 49.7 gpm.**
 - **The replacement Franklin motor used for CW-2 last month was in fact a new motor, not, as reported, a rebuilt one.**

- G. Other
 -

HURST ENGINEERING SERVICES

1915 Fairfax St• Denver, CO 80220

Email: tonyhurst@q.com

Tasks Planned:

- H. Groundwater Monitoring Plan
 - Continue to evaluate Monitoring Wells replacement needs.
 - Following approvals being received from the State Engineer, and the EPA/NMED, MW-57 will be deepened and MW-13 and MW-48 will be closed down.
- I. Public Involvement Plan
 -
- J. Deep Flow Zone System
 -
- K. Assessment of Aquifer Restoration
 -
- L. Offsite-Containment System
 -
- M. Source Containment System
 - Continue with the development of a work-plan to achieve clean closure of the pond and sump area.
- N. Other
 -
- O. Problems Encountered or Anticipated:
 -

By:



Tony Hurst
Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)