

ST



FAX

To: John Kieling (505 476 6030)

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M)Albuquerque v. Sparton Technology, Inc.

Date	No of Pages	Month
2/9/11	(3 total)	Attached is the <u>January</u> 2011 Monthly Report
3/5/11	(3 total)	Attached is the <u>February</u> 2011 Monthly Report
4/8/11	(3 total)	Attached is the <u>March</u> 2011 Monthly Report
5/9/11	(3 total)	Attached is the <u>APRIL</u> 2011 Monthly Report
6/9/11	(3 total)	Attached is the <u>MAY</u> 2011 Monthly Report
7/9/11	(3 total)	Attached is the <u>June</u> 2011 Monthly Report
8/6/11	(3 total)	Attached is the <u>JULY</u> 2011 Monthly Report
()	(total)	Attached is the _____ 2011 Monthly Report
()	(total)	Attached is the _____ 2011 Monthly Report
()	(total)	Attached is the _____ 2011 Monthly Report
()	(total)	Attached is the _____ 2011 Monthly Report
()	(total)	Attached is the _____ 2011 Monthly Report
()	(total)	Attached is the _____ 2011 Monthly Report
()	(total)	Attached is the _____ 2011 Monthly Report

Please call me at 719-649-1944 if you have any questions

Thanks

Tony Hurst

Project Coordinator for Sparton Technology, Inc.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

**MONTHLY PROGRESS REPORT
For month ending July 31st, 2011****CV-97-0206 (D.N.M)
Albuquerque v. Sparton Technology, Inc.**

08/06/11

Tasks Completed:

- A. Groundwater Monitoring Plan
- The semi-annual GWMP Report (for January through June 2011) was distributed in July.
 - MW-57 was sampled on the 11th July.
- B. Public Involvement Plan
-
- C. Deep Flow Zone System
-
- D. Assessment of Aquifer Restoration
-
- E. Offsite-Containment System
- The system ran 99.71 % of the time and pumped 13,088,500 gallons (average of 293.2 gpm). There was a power outage on July 7th for 2 hours 10 minutes.
- F. Source Containment System
- The system ran 99.98 % of the time and pumped 2,298,700 gallons (average of 51.5 gpm). There was a power outage on July 26th for 10 minutes.
 - Discharge to Ponds 1 and 2 were switched in July to Ponds 2, 3 and 4.
- G. Other
-

Tasks Planned:

- H. Groundwater Monitoring Plan
- The 3rd quarter GWMP sampling will be performed starting the week of August 15th and being completed the week of August 22nd.
 - Cuttings from MW-57 are being dried and, since they are non-hazardous, will be used as road fill.
- I. Public Involvement Plan
-

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email. tonyhurst@q.com

- J. Deep Flow Zone System
-
- K. Assessment of Aquifer Restoration
-
- L. Offsite-Containment System
-
- M. Source Containment System
- Discharge to Ponds 2, 3 and 4 will be switched in August to Ponds 1 and 4.

- N. Other
-
- O. Problems Encountered or Anticipated:
-

By:



Tony Hurst
Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)