



FAX

To: John Kieling (505 476 6030)

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M)Albuquerque v. Sparton Technology, Inc.

Date	No of Pages	Month
2/9/11	(3 total)	Attached is the <u>January</u> 2011 Monthly Report
3/5/11	(3 total)	Attached is the <u>February</u> 2011 Monthly Report
4/8/11	(3 total)	Attached is the <u>March</u> 2011 Monthly Report
5/9/11	(3 total)	Attached is the <u>APRIL</u> 2011 Monthly Report
6/9/11	(3 total)	Attached is the <u>MAY</u> 2011 Monthly Report
7/8/11	(3 total)	Attached is the <u>June</u> 2011 Monthly Report
8/6/11	(3 total)	Attached is the <u>JULY</u> 2011 Monthly Report
9/7/11	(3 total)	Attached is the <u>August</u> 2011 Monthly Report
	(total)	Attached is the _____ 2011 Monthly Report
	(total)	Attached is the _____ 2011 Monthly Report
	(total)	Attached is the _____ 2011 Monthly Report
	(total)	Attached is the _____ 2011 Monthly Report
	(total)	Attached is the _____ 2011 Monthly Report
	(total)	Attached is the _____ 2011 Monthly Report

Please call me at 719-649-1944 if you have any questions

Thanks

Tony Hurst

Project Coordinator for Sparton Technology, Inc.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

**MONTHLY PROGRESS REPORT
For month ending August 31st, 2011****CV-97-0206 (D.N.M)
Albuquerque v. Sparton Technology, Inc.**

09/07/11

Tasks Completed:**A. Groundwater Monitoring Plan**

- Continued to evaluate Monitoring Wells replacement needs.
- The 3rd quarter GWMP sampling was performed the week of August 15th and was completed the week of August 22nd.
- Cuttings from MW-57 being dried in preparation for disposal as road fill.

B. Public Involvement Plan

-

C. Deep Flow Zone System

-

D. Assessment of Aquifer Restoration

-

E. Offsite-Containment System

- Discharge to Ponds 1 and 2 were switched in July to Ponds 1, 2, and 3.
- The system ran 100.0 % of the time and pumped 13,172,300 gallons (average of 294.0 gpm).

F. Source Containment System

- The system ran 99.4 % of the time and pumped 2,322,600 gallons (average of 51.8 gpm). There was two power outage:
 - o On August 27th for 3 hours, 20 minutes.
 - o On August 29th for 1 hour, 10 minutes.

G. Other

-

Tasks Planned:**H. Groundwater Monitoring Plan**

- Continue to evaluate Monitoring Wells replacement needs.
- Install a new sampling pump in MW-57
- Sample MW-65 following the repair of the sampling pump.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

I. Public Involvement Plan

-

J. Deep Flow Zone System

-

K. Assessment of Aquifer Restoration

-

L. Offsite-Containment System

-

M. Source Containment System

- Develop a work-plan to achieve clean closure of the pond and sump area.
- CW-2 pipe cleaning residue to be tested for toxic residues following the drying (in progress). Method of disposal to be determined following testing.
- Discharge control valves to evaporation ponds to be inspected by Rodgers and maintenance performed as necessary.


N. Other

-

O. Problems Encountered or Anticipated:

-

By:



Tony Hurst

Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)