

FAX

To: John Kieling (505 476 6030)

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M)Albuquerque v. Sparton Technology, Inc.

Date	No of Pages	Month	
2/9/11	(3 total)	Attached is the brund	2011 Monthly Report
3/5/11	(Stotal)	Attached is the Firm	2011 Monthly Report
4/8/11	(3 total)	Attached is the Kerl	2011 Monthly Report
5/91 11	(3total)	Attached is the APRIL	2011 Monthly Report
6/9/11	(3total)	Attached is the MAY	2011 Monthly Report
7/8/11	(3total)	Attached is the June	2011 Monthly Report
જીદી!!	(3total)	Attached is the July	2011 Monthly Report
9/7/11	(3total)	Attached is the August	2011 Monthly Report
1019 IN	(3total)	Attached is the sales	2011 Monthly Report
, , , ,	(total)	Attached is the	2011 Monthly Report
	(total)	Attached is the	2011 Monthly Report
	(total)	Attached is the	2011 Monthly Report
	(total)	Attached is the	2011 Monthly Report
	(total)	Attached is the	2011 Monthly Report

Please call me at 719-649-1944 if you have any questions

Thanks

Tony Hurst

Project Coordinator for Sparton Technology, Inc.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220 Email: tonyhurst@ q.com

MONTHLY PROGRESS REPORT For month ending September 30th, 2011

CV-97-0206 (D.N.M) Albuquerque v. Sparton Technology, Inc.

10/09/11

Tasks Completed:

- A. Groundwater Monitoring Plan
- Continued to evaluate Monitoring Wells replacement needs.
- Installed a new bladder sampling pump in MW-57
- Pulled MW-65 bladder sampling pump to complete the repair.
- Cuttings from MW-57 being dried in preparation for disposal as road fill.
 - B. Public Involvement Plan
 - C. Deep Flow Zone System
 - D. Assessment of Aquifer Restoration
- Approval of the 2010 Annual report (subject to specified modifications) was received.
 - E. Offsite-Containment System
- The system ran 100.0 % of the time and pumped 13,447,900 gallons (average of 290.0 gpm).
 - F. Source Containment System
- The Discharge control valves to the evaporation ponds cleaned.
- The system ran 98.76 % of the time and pumped 2,301,000 gallons (an average of 50.1 gpm). There was five power outage:
 - o On September 1st for 30 minutes.
 - o On September 19th for 4 hours, 50 minutes.
 - o On September 20th for 50 minutes.
 - o On September 21st for 1 hour, 40 minutes.
 - o On September 22nd for 1 hour, 40 minutes.
 - G. Other

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220 Email: tonyhurst@ q.com

Tasks Planned:

- H. Groundwater Monitoring Plan
- Continue to evaluate Monitoring Wells replacement needs.
- Sample MW-65 following the repair and installation of the sampling pump.
- Prepare a Work Plan for abandoning wells MW-58 and MW-61 and for the deepening or replacement of well MW-47 and submit to agencies for review and approval.
- Prepare a Renewal Application for Discharge Permit DP-1184.
 - I. Public Involvement Plan
- Prepare the 2010 Fact Sheet and submit to agencies for review and approval prior to distribution.
 - J. Deep Flow Zone System
 - K. Assessment of Aquifer Restoration
- Complete the modifications to the 2010 Annual report and submit to the agencies.
 - L. Offsite-Containment System
 - M. Source Containment System
- Develop a work-plan to achieve clean closure of the pond and sump area.
- CW-2 pipe cleaning residue to be tested for toxic residues following the drying (in progress). Method of disposal to be determined following testing.
 - N. Other
 - O. Problems Encountered or Anticipated:

By:

Tony Hurst

Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)

Mr. John Kieling (NMED: 505-476-6030)