



FAX COVER SHEET

TO

COMPANY

FAX NUMBER 15054766030

FROM Tony Hurst

DATE 2012-07-09 17:11:13 GMT

RE Monthly Report for June 2012

COVER MESSAGE

FAX

To: John Kieling 505 476 6030

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M) Albuquerque v. Sparton Technology, Inc.

| Date | No of Pages | Month |
|--------|-------------|--|
| | (-_ total) | Attached is the January 2012 Monthly Report |
| | (-_ total) | Attached is the February 2012 Monthly Report |
| | (-_ total) | Attached is the March 2012 Monthly Report |
| | (-_ total) | Attached is the April 2012 Monthly Report |
| | (-_ total) | Attached is the May 2012 Monthly Report |
| | (-_ total) | Attached is the June 2012 Monthly Report |
| | (-_ total) | Attached is the July 2012 Monthly Report |
| | (-_ total) | Attached is the August 2012 Monthly Report |
| | (-_ total) | Attached is the September 2012 Monthly |
| Report | (-_ total) | Attached is the October 2012 Monthly Report |
| | (-_ total) | Attached is the November 2012 Monthly Report |
| | (-_ total) | Attached is the December 2012 Monthly Report |

Please call me at 719-649-1944 if you have any questions

Thanks

Tony Hurst

Project Coordinator for Sparton Technology, Inc.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

MONTHLY PROGRESS REPORT
For month ending June 30th, 2012CV-97-0206 (D.N.M)
Albuquerque v. Sparton Technology, Inc.

07/09/12

Tasks Completed:

- A. Groundwater Monitoring Plan
 - Continued to evaluate Monitoring Wells replacement needs.
 - Completed the plugging and abandonment of MW-47, MW-58 and MW-61.
 - Performed QA/QC for the 2nd Quarter data.

- B. Public Involvement Plan
 -

- C. Deep Flow Zone System
 -

- D. Assessment of Aquifer Restoration
 - Completed and submitted to the EPA and the NMED the 2011 Annual Report.

- E. Offsite-Containment System
 - The system ran 99.82 % of the time and pumped 12,980,100 gallons (an average of 299.7 gpm). There were four brief outages.
 - o On June 4th the system was down for 41 minutes as a result of a power outage.
 - o On June 24th the system was down for 24 minutes as a result of a power interruption.
 - o On June 24th the system was down for 10 minutes when the pump required resetting.
 - o On June 29th the system was down for 5 minutes as a result of an overloaded sump water level.

- F. Source Containment System
 - The system ran 97.44 % of the time and pumped 1,809,300 gallons (an average of 41.8 gpm). There were multiple power outages.
 - o On June 30th the system was down for 238 minutes as a result of a power outage.
 - o On July 1st the system was down for 870 minutes as a result of a power outage.

- G. Other
 -

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

Tasks Planned:**H. Groundwater Monitoring Plan**

- Continue to evaluate Monitoring Wells replacement needs.
- Work on the preparation of the semi-annual GWMP for the 1st and 2nd quarters, 2011.
- Begin installation of MW-47R on city owned right-of-way (tentatively planned for week of July 15th).

I. Public Involvement Plan

-

J. Deep Flow Zone System

-

K. Assessment of Aquifer Restoration

-

L. Offsite-Containment System

-

M. Source Containment System

- Develop a work-plan to achieve clean closure of the pond and sump area.

N. Other

-

O. Problems Encountered or Anticipated:

-

By:

Tony Hurst
Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)