



FAX

To: John Kieling 505 476 6030

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M) Albuquerque v. Sparton Technology, Inc.

Date	No of Pages	Month
	(_ total)	Attached is the January 2012 Monthly Report
	(_ total)	Attached is the February 2012 Monthly Report
	(_ total)	Attached is the March 2012 Monthly Report
	(_ total)	Attached is the April 2012 Monthly Report
	(_ total)	Attached is the May 2012 Monthly Report
	(_ total)	Attached is the June 2012 Monthly Report
8/9/12	(3 total)	Attached is the July 2012 Monthly Report
	(_ total)	Attached is the August 2012 Monthly Report
	(_ total)	Attached is the September 2012 Monthly Report
	(_ total)	Attached is the October 2012 Monthly Report
	(_ total)	Attached is the November 2012 Monthly Report
	(_ total)	Attached is the December 2012 Monthly Report

Please call me at 719-649-1944 if you have any questions

Thanks

Tony Hurst

Project Coordinator for Sparton Technology, Inc.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

MONTHLY PROGRESS REPORT
For month ending July 31st, 2012**CV-97-0206 (D.N.M)**
Albuquerque v. Sparton Technology, Inc.

08/09/12

Tasks Completed:**A. Groundwater Monitoring Plan**

- Continued to evaluate Monitoring Wells replacement needs.
- Completed the First and Second Quarter 2012 Semi-Annual Report on the Groundwater Monitoring Program and submitted it to the EPA and NMED.
- Worked on the plugging and abandoning of MW-47, MW-58, and MW-61.
- Worked on the installation of replacement well MW-47R.

B. Public Involvement Plan

-

C. Deep Flow Zone System

-

D. Assessment of Aquifer Restoration

-

E. Offsite-Containment System

- Monthly sampling of the Air Strippers discharge data was sent to the Office of the State Engineer.
- The system ran 99.9 % of the time and pumped 12,207,100 gallons (an average of 283.9 gpm). There was one power outage on July 9th for 44 minutes.
- The system pumping data for June was incorrectly calculated. The flow rate was 290.0 gpm (not 299.7 gpm) and it ran 99.82% of the time.

F. Source Containment System

- Monthly sampling of the Air Strippers discharge data was sent to the Office of the State Engineer.
- The system ran 99.49 % of the time and pumped 1792,200 gallons (an average of 41.7 gpm). There was two power outage
 - o On July 9th for 1 hour 20 minutes.
 - o On July 10th for 2 hours 19 minutes.
- The system pumping data for June was incorrectly calculated. The system ran 97.52% of the time (not 97.44 %) at an average of 40.4 gpm (not 41.8 gpm).

G. Other

-

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

Tasks Planned:**H. Groundwater Monitoring Plan**

- Continue to evaluate Monitoring Wells replacement needs.
- Will complete the plugging and abandoning of MW-47, MW-58, and MW-61.
- The installation of the replacement well MW-47R to be completed in early August.
- Complete the installation of replacement well MW-47R 8/8/12.
- Conduct the Third Quarter round of water-level monitoring and sampling for all wells identified for quarterly sampling under the Groundwater Monitoring Plan from 8/13/12 through 8/22/12..
- Survey MW-47R for location coordinates and measuring point elevation.

I. Public Involvement Plan

-

J. Deep Flow Zone System

-

K. Assessment of Aquifer Restoration

-

L. Offsite-Containment System

- Plan to clean pipe line connecting CW-2 pump to CW-2 stripper on the 8/23.

M. Source Containment System

- Develop a work-plan to achieve clean closure of the pond and sump area.
- Plan to clean the stripper trays on CW-2 starting on the 28th of Aug.


N. Other

-

O. Problems Encountered or Anticipated:

-

By:



Tony Hurst
Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)