

ENTERED

FAX

To: John Kieling 505 476 6030

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M) Albuquerque v. Sparton Technology, Inc.

Date	No of Pages	Month
	() total	Attached is the January 2012 Monthly Report
	() total	Attached is the February 2012 Monthly Report
	() total	Attached is the March 2012 Monthly Report
	() total	Attached is the April 2012 Monthly Report
	() total	Attached is the May 2012 Monthly Report
	() total	Attached is the June 2012 Monthly Report
8/1/12	(3) total	Attached is the July 2012 Monthly Report
7/5/12	(3) total	Attached is the August 2012 Monthly Report
10/9/12	(3) total	Attached is the September 2012 Monthly Report
	() total	Attached is the October 2012 Monthly Report
	() total	Attached is the November 2012 Monthly Report
	() total	Attached is the December 2012 Monthly Report

Please call me at 719-649-1944 if you have any questions

Thanks

Tony Hurst



Project Coordinator for Sparton Technology, Inc.

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

MONTHLY PROGRESS REPORT
For month ending July 31st, 2012CV-97-0206 (D.N.M)
Albuquerque v. Sparton Technology, Inc.

09/08/12

Tasks Completed:A. Groundwater Monitoring Plan

- Continued to evaluate Monitoring Wells replacement needs.
- Received and reviewed NMED comments on the Draft Renewal Discharge Permit DP-1184.
- Conducted the 3rd quarter water-level monitoring and sampling.
- Completed replacement well MW-47R.
- Completed the plugging and abandoning of MW-47, MW-58, and MW-61.

B. Public Involvement Plan

-

C. Deep Flow Zone System

-

D. Assessment of Aquifer Restoration

- Received approval of 2011 Annual Report

E. Offsite-Containment System

- The system ran 100.0 % of the time and pumped 13,272,500 gallons (an average of 297.3 gpm).

F. Source Containment System

- Cleaned the pipeline between the well and CW-2 Stripper.
- Cleaned the CW-2 stripper.
- The system ran 95.51 % of the time and pumped 1,780,800 gallons (an average of 39.9 gpm). There were two outages
 - o On August 24th a power outage for 5 hour 4 minutes.
 - o On August 28th-29th the system was down for 28 hours 20 minutes to allow for cleaning the stripper trays.

G. Other

HURST ENGINEERING SERVICES

1915 Fairfax St* Denver, CO 80220

Email: tonyhurst@q.com

Tasks Planned:**H. Groundwater Monitoring Plan**

- Continue to evaluate Monitoring Wells replacement needs.
- Install a sampling pump in MW-47R.
- Replace the purge and sample pumps at MW-45 before 4th quarter sampling.
- Survey MW-47R for location coordinates and measuring point elevation.

I. Public Involvement Plan

- Begin preparation of the 2011 Fact sheet.

J. Deep Flow Zone System

-

K. Assessment of Aquifer Restoration

-

L. Offsite-Containment System

- Plan to clean the stripper trays on CW-1 Stripper

M. Source Containment System

- Develop a work-plan to achieve clean closure of the pond and sump area.
- Monitor the evaporation of the pipeline clean up water


N. Other

- Replace the drum pump.

O. Problems Encountered or Anticipated:

-

By:



Tony Hurst

Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)