



Sparton
Monthly Report
4/8/13

FAX

To: John Kieling 505 476 6030

From: Tony Hurst: (303 388 8613)

RE: Monthly Reports: CV-97-0206 (D.N.M) Albuquerque v. Sparton Technology, Inc.

Date	No of Pages	Month
1/9/13	(3 total)	Attached is the January 2013 Monthly Report
2/9/13	(3 total)	Attached is the February 2013 Monthly Report
3/9/2013	(3 total)	Attached is the March 2013 Monthly Report
4/8/2013	(3 total)	Attached is the April 2013 Monthly Report
	(_ total)	Attached is the May 2013 Monthly Report
	(_ total)	Attached is the June 2013 Monthly Report
	(_ total)	Attached is the July 2013 Monthly Report
	(_ total)	Attached is the August 2013 Monthly Report
	(_ total)	Attached is the September 2013 Monthly Report
	(_ total)	Attached is the October 2013 Monthly Report
	(_ total)	Attached is the November 2013 Monthly Report
	(_ total)	Attached is the December 2013 Monthly Report

Please call me at 719-649-1944 if you have any questions

Thanks

Tony Hurst

Project Coordinator for Sparton Technology, Inc.

HURST ENGINEERING SERVICES
1022 Monaco St Pkwy* Denver, CO 80220
Email: tonyhurst@q.com

MONTHLY PROGRESS REPORT
For month ending March 31st, 2013

CV-97-0206 (D.N.M)
Albuquerque v. Sparton Technology, Inc.

04/08/13

Tasks Completed:

- A. Groundwater Monitoring Plan
 - Continued to evaluate Monitoring Wells replacement needs.

- B. Public Involvement Plan
 -

- C. Deep Flow Zone System
 -

- D. Assessment of Aquifer Restoration
 - Continued working on the 2012 data for the preparation of the 2012 Annual Report.

- E. Offsite Containment System
 - Sampled air-stripper.
 - Repaired leaks at the off-site air-stripper.
 - The system ran 99.4 % of the time and pumped 12,861,900 gallons (an average of 287.8 gpm). There was three outages:
 - o On 12th March for 2 hours 46 minutes to allow leak repairs to the stripper to be performed.
 - o A power outage on 15th March for 19 minutes.
 - o A power outage on 23rd March for 1 hour 21 minutes.

- F. Source Containment System
 - Completed RCRA Permit Renewal Application and submitted to NMED on March 29.
 - Sampled air-stripper.
 - The system ran 99.45 % of the time and pumped 1,882,700 gallons (an average of 42.1 gpm). There was three outages:
 - o A power outage on 1st March for 44 minutes.
 - o A power outage on 12th March for 1 hour 22 minutes.
 - o A power outage on 23rd March for 1 hour 54 minutes.

- G. Other
 -

HURST ENGINEERING SERVICES

1022 Monaco St Plwy* Denver, CO 80220

Email: tonyhurst@q.com

Tasks Planned:**H. Groundwater Monitoring Plan**

- Continue to evaluate Monitoring Wells replacement needs.
- Dispose of cuttings from MW-47R upon receipt of approval from the agencies.

I. Public Involvement Plan

-

J. Deep Flow Zone System

-

K. Assessment of Aquifer Restoration

- Continued on 2012 data evaluation in preparation of the 2012 Annual Report;

L. Offsite-Containment System

- Paint wood and metal surfaces at treatment facility.

M. Source Containment System

- Develop a work-plan to achieve clean closure of the pond and sump area.
- Paint wood and metal surfaces at treatment facility.


N. Other

-

O. Problems Encountered or Anticipated:

-

By:



Tony Hurst

Project Coordinator for Sparton.

Cc: By fax to Mr. Chuck Hendrickson (EPA: 214-665-7263)
Mr. John Kieling (NMED: 505-476-6030)