



EA Engineering, Science,
and Technology, Inc., PBC



MONTHLY PROGRESS REPORT
For month ending October 31, 2022

CV-97-0206 (D.N.M)
Albuquerque v. Sparton Technology, Inc.

11/04/2022

Tasks Completed:

- A. Groundwater Monitoring Plan
- None.
- B. Public Involvement Plan
- None.
- C. Deep Flow Zone System
- None.
- D. Assessment of Aquifer Restoration
- None.
- E. Offsite-Containment System (CW-1)
- The system operated 100% of the time and pumped 13,220,977 gallons (an average of 296.2 gallons per minute [gpm]). There were no system shutdowns.
 - Collected the monthly influent and effluent samples and measured the water level in the infiltration gallery piezometer.
 - Filed the monthly discharge report with the Office of the State Engineer as required under Permit-RG-69659.
 - The Aqua-Mag tank was replenished the following time(s):
 - o On 10/01/22 with 22.8 gallons.
 - o On 10/15/22 with 17.9 gallons
- F. Source Containment System (CW-2)
- The system operated 100% of the time and pumped 2,152,293 gallons (an average of 48.2 gpm). There were no system shutdowns.
 - Collected the monthly influent and effluent samples from the treatment system.
 - Filed the monthly discharge report with the Office of the State Engineer as required under Permit-RG-73531.
 - The Aqua-Mag tank was replenished the following time(s):
 - o On 10/08/22 with 11.1 gallons.
- G. Other
- All field activities were performed by EA personnel and subcontractors following standard operating procedures, including health and safety requirements, outlined in the Operation and Maintenance Manuals of the On-Site and Off-Site Containment Systems.
- H. Problems Encountered or Anticipated
- None.



Tasks Planned:

- I. Groundwater Monitoring Plan
 - Complete the 4th quarter groundwater sampling event. Groundwater sampling activities began on 11/01/2022.
- J. Public Involvement Plan
 - Upon approval of the 2020 and 2021 Annual Reports, a combined 2022 Fact Sheet on remedial activities during 2020 and 2021 will be prepared and submitted to the Agencies for approval before distribution.
- K. Deep Flow Zone System
 - None.
- L. Assessment of Aquifer Restoration
 - None.
- M. Offsite-Containment System (CW-1)
 - The monthly influent and effluent samples will be collected, and the water level will be measured in the infiltration gallery piezometer.
 - The required discharge report will be filed with the Office of the State Engineer.
- N. Source Containment System (CW-2)
 - The monthly influent and effluent samples will be collected.
 - The required discharge report will be filed with the Office of the State Engineer.
- O. Other
 - None.
- P. Problems Anticipated or that May Be Encountered:
 - None.

By:

A handwritten signature in black ink that reads 'Bob Marley'. The signature is written in a cursive, slightly slanted style.

Bob Marley

EA Project Manager on behalf of Sparton

Cc: Mr. Greg Lyssy (EPA: 214-665-8317)
Mr. Dave Cobrain (NMED: 505-476-6030)

04 November 2022

Mr. Charles Palmer
Office of the State Engineer
5550 San Antonio Dr. NE
Albuquerque, New Mexico
Dist1.meterreadings@state.nm.us

RE: Permit RG-69659, RG-73531T

Dear Mr. Palmer:

Below is the meter report for the month of October 2022. A total of 13,220,977 gallons of water was discharged through the CW-1 treatment system to an infiltration gallery located in the Calabacillas Arroyo. A total of 2,152,293 gallons of water was discharged through the CW-2 treatment system to rapid infiltration pond number three located north of the treatment building.

Date	CW-1		CW-2	
	Meter Reading	Discharge	Meter Reading	Discharge
01/01/2022	757,679,827	0	131,306,918	0
01/31/2022	771,114,259	13,434,432	133,639,167	2,332,249
02/28/2022	782,853,247	11,738,988	135,700,562	2,061,395
03/31/2022	795,290,585	12,437,338	138,063,872	2,363,310
04/30/2022	808,206,712	12,916,127	140,463,355	2,399,483
05/31/2022	821,520,316	13,313,604	142,749,312	2,285,957
06/30/2022	834,388,493	12,868,177	144,691,505	1,942,193
07/31/2022	847,670,725	13,282,232	146,940,788	2,249,283
08/31/2022	860,952,113	13,281,388	149,272,556	2,331,768
09/30/2022	873,801,760	12,849,647	151,282,715	2,010,159
10/31/2022	887,022,737	13,220,977	153,435,008	2,152,293
Total (gallons)	-	129,342,910	-	22,128,090

Sincerely,

EA ENGINEERING, SCIENCE,
AND TECHNOLOGY, INC., PBC



Bob Marley
Project Manager