


ENRON OPERATIONS CORP.

P. O. Box 1188 Houston, Texas 77251-1188 (713) 853-6161

July 5, 1995

Ms. Barbara Hoditschek
New Mexico Environment Department
Hazardous & Radioactive Materials Bureau
525 Camino de Los Marquez
P.O. Box 26110
Santa Fe, NM 87502



RE: Report of Interim Corrective Measures
Transwestern Pipeline Company Roswell Compressor Station
Reporting Period: April 1, 1995 through June 30, 1995

Dear Ms. Hoditschek,

This letter report of interim corrective measures at the Roswell Station covers the calendar quarter of April 1995 through June 1995. A copy of the monthly operations and maintenance reports generated by TPC's local contractor responsible for routine O&M are attached.

| I. Volume of Liquids Recovered (gallons) | <u>During Reporting Period</u> | <u>To Date</u> |
|---|--------------------------------|----------------|
| 1. Phase Separated Hydrocarbons (PSH) | 420 | 7,097 |
| 2. Ground Water | 144 | 6,115 |
| 3. PSH and Ground Water Combined | 563 | 13,212 |

II. Accumulation Time for Recovered Liquids

| | |
|--|----------------|
| 1. Date liquids last removed from recovery tank | April 11, 1995 |
| 2. Last day of reporting period | June 30, 1995 |
| 3. Accumulation time to last day of reporting period | 80 days |

III. General Comments

On May 18, 1995, during the daily inspection of the recovery system it was noted that there was a minor leak at the pressure gauge connection on the pump #3 (MW-2) discharge line. This had resulted in a minor release of recovered hydrocarbon liquid to the ground surface. The pump was immediately shut down and all visibly contaminated soil placed into a container for disposal. Because the recovery rate for well MW-2 is less than 2.0 gallons per day, and since the leak was discovered within 24 hours, only a very small quantity of soil (approximately 0.2 cubic foot) was impacted. The discharge line was repaired the following day and the recovery pump placed back in service.

No other events of concern occurred during this reporting period.

If you have any questions regarding the content of this report, please contact me at (713) 646-7644 or George Robinson at (713) 646-7327.

Sincerely,



Bill Kendrick
Projects Group Manager
EOC Environmental Affairs

gcr/BK

cp w/enclosures:

Roger Anderson

NMOCD

Santa Fe, NM

