

Subject: Semi-Annual Discharge Monitoring Report for January 1 through June 30, 2011

Dear Mr. Marshall:

Santa Fe, NM 87502

The purpose of this letter is to transmit to you the Waste Isolation Pilot Plant Discharge Monitoring Report for the period of January 1 through June 30, 2011. This report is required by Discharge Permit 831.

If you have any questions about this report or require any additional information, please contact me at (575) 234-8128.

Sincerely,

Daniel J. Ferguson, Site Regulatory Specialist Carlsbad Field Office

Enclosure

cc: w/o enclosure J. Kieling, NMED \*ED M. Menetrey, NMED ED CBFO M&RC \*ED denotes electronic distribution



## **SPECIFIC REPORTING REQUIREMENTS OF DP-831**

## 1.0 WIPP SEWAGE TREATMENT FACILITY AND H-19 EVAPORATION POND MONITORING AND REPORTING

Table 1						
Monthly Discharge Volumes to Facultative Lagoon System						
Month	Volume* (gallons)					
January	283,377					
February	280,135					
March	280,819					
April	266,722					
May	339,634					
June	340,466					
40 1 1 1						

\*Based on total domestic water use

Facultative Lagoon System Evaporation Pond B: None Facultative Lagoon System Evaporation Pond C: None

Table 2Monthly Discharge Volumes to H-19 Evaporation Pond				
Month	Volume (gallons)			
January	None			
February	None			
March	1,050			
April	1,200			
May	1,275			
June	None			

Table 3 contains a summary of the analytical results for the Sewage Treatment System and the H-19 Evaporation Pond. Miscellaneous non-hazardous water disposed of in the H-19 Evaporation Pond was purged water from groundwater monitoring activities and Waste Shaft sump water.

Table 3   Sewage Treatment Facility and H-19 Analytical Data Summary								
Analyte	Sample Date	Influent Pond 2A	Pond B	Pond C	H-19			
Nitrate (mg/L)	4/19/11	ND	NA	NA	NA			
TKN (mg/L)	4/19/11	92	NA	NA	NA			
TDS (mg/L)	4/19/11	490	609,000	NS	NS			
Sulfate (mg/L)	4/19/11	60	63,000	NS	NS			
Chloride (mg/L)	4/19/11	540	280,000	NS	NS			

ND: Not detected, analyte below the detection limit

NA: Not analyzed, parameters not required

NS: Not Sampled, pond was dry.

Bold: Concentration exceeds the standards listed in 20.6.2.3103 NMAC for Human Health and Domestic Water Supply

## 2.0 INFILTRATION CONTROL ACTIVITIES

Due to extreme drought conditions, water levels have been low in all infiltration control ponds and no maintenance has been necessary due to the lack of water erosion. The Salt Pile Evaporation Pond, Evaporation Basin A, and Pond 1 are all dry.

## 3.0 <u>SUMMARY OF ACTIVITIES RELATED TO THE SHALLOW SUBSURFACE WATER (SSW)</u> <u>MONITORING AND SAMPLING PROGRAM</u>

Water levels in the shallow wells (PZ-1 through PZ-15, C-2811, C-2505, C-2506, and C-2507), Figure 1, were obtained March 2-3, 2011, and June 8, 2011, and are included in Table 4. These were taken on the quarterly milestones outlined in the Ground Water Monitoring Schedule, in the September 9, 2008, DP-831 Modification. Total rainfall in the area of WIPP for this reporting period was 0.17 inches compared to 5.81 inches for the same time period in 2010, a difference of 5.64 inches more in 2010. Total rainfall in 2010 was slightly more than the average annual rainfall for the region of 12.92 inches reported by the National Oceanic and Atmospheric Administration.

In the shallow wells monitored 16 of 19 showed decreasing water levels during the reporting period. The largest decrease in water level over this time was 0.94 feet identified in PZ-10, next to Evaporation Basin A. An increase was shown in C-2811, PZ-2, and PZ-3 (average of +0.27 feet); this may be attributed to the lag time from rainfall in 2010. The average groundwater decrease around the lined ponds (PZ-7, PZ-10, PZ-11, and PZ-12) was 0.46 feet for this reporting period.

WQSP-6A was sampled during May 2011. WQSP-6A sampling results are provided in Table 4. Sulfate, nitrate, chloride, and total dissolved solids were detected in WQSP-6A samples at concentrations exceeding standards of 20.6.2.3103 NMAC, *Standards for Ground Water of 10,000 mg/L TDS Concentration or Less for Human Health and Domestic Water Supply*. Although the concentrations were higher than the standards, they are less than background concentrations established in the *Waste Isolation Pilot Plant RCRA Background Groundwater Quality Baseline Report* (DOE/WIPP 98-2285). Total Kjeldahl nitrogen was below the detection limit of one mg/L. The shallow subsurface water (SSW) identified at the WIPP site has not impacted the Dewey Lake groundwater in WQSP-6A based on the consistency of analyzed parameters in WQSP-6A.

The SSW piezometers were sampled for field and general chemistry parameters in May 2011, as required by the September 9, 2008, modification to DP-831. Five piezometers were sampled on May 23, 2011, and six on May 24, 2011. Results for the field sampling parameters and laboratory analyses are presented in Table 4. Chloride concentrations exceeded values listed in 20.6.2.3103 NMAC for Human Health and Domestic Water Supply in all shallow piezometers sampled. The maximum chloride concentration was 150,000 mg/L in PZ-13, while the minimum concentration was 310 mg/L in PZ-10. Total dissolved solids concentrations exceeded 20.6.2.3103 NMAC values for Human Health and Domestic Water Supply in all shallow piezometers sampled, with the maximum concentration of 248,000 mg/L in PZ-13. Sulfate concentrations exceeded 20.6.2.3103 NMAC values for Human Health and Domestic Water Supply in 9 of 11 piezometers sampled with a maximum concentration of 4,300 mg/L in PZ-9 and a minimum concentration of 350 mg/L in C-2811.

٠

-

Figure 1 WIPP Site Map



Table 4 Shallow Subsurface Water Monitoring Program											
	Water Leve (Ft A	l Monitoring MSL)	Field Parameters			General Chemistry Parameters				Other	
Monitoring Site	3/2-3/3/11	6/8/11	pH (SU)	Temp. ( <sup>0</sup> C)	Specific Conductivity @25 °C (µS/cm)	Sample Date	Nitrate (mg/L)	Sulfate (mg/L)	Chloride (mg/L)	TDS (mg/L)	TKN (mg/L)
PZ-1	3,371.60	3,371.22	6.22	29.6	111,000	05/24/11	NA	2,000	51,000	85,200	NA
PZ-2	3,371.04	3,370.67	NS	NS	NS	NS	NS	NS	NS	ŃS	NS
PZ-3	3,372.29	3,371.99	NS	NS	NS	NS	NS	NS	NS	NS	NS
PZ-4	3,366.06	3,365.42	NS	NS	NS	NS	NS	NS	NS	NS	NS
PZ-5	3,372.79	3,372.38	6.67	28.1	30,330	05/24/11	NA	1,200	10,000	18,400	NA
PZ-6	3,370.23	3,369.72	6.33	29.9	92,400	05/24/11	NA	1,700	37,000	67,700	NA
PZ-7	3,376.91	3,376.71	6.26	29.6	127,000	05/23/11	NA	2,700	60,000	101,000	NA
PZ-8	3,355.61	3,355.57	NA	NA	NA	NS	NA	NS	NS	NS	NS
PZ-9	3,363.74	3,363.60	6.08	26.4	169,900	05/24/11	NA	4,300	83,000	147,000	NA
PZ-10	3,367.62	3,366.90	7.19	27.2	2,464	05/23/11	NA	400	310	1,620	NA
PZ-11	3,374.48	3,374.33	6.44	26.9	104,400	05/23/11	NA	2,000	45,000	80,500	NA
PZ-12	3,357.27	3,356.59	6.80	25.6	17,640	05/23/11	NA	900	5,600	10,900	NA
PZ-13	3,356.28	3,356.16	Bailed			05/24/11	NA	2,700	150,000	248,000	NA
PZ-14	3,353.22	3,353.17	NS	NS	NS	NS	NA	NS	NS	NS	NS
PZ-15	3,383.33	3,382.99	NS	NS	NS	NS	NA	NS	NS	NS	NS
C-2811	3,346.85	3346.52	7.24	23.7	3,958	05/23/11	NA	350	960	2,370	NA
C-2505	3,367.63	3,367.08	NS	NS	NS	NS	NA	NS	NS	NS	NS
C-2506	3,368.18	3,367.62	NS	NS	NS	NS	NA	NS	NS	NS	NS
C-2507	3,364.73	3,364.34	6.75	25.7	10,820	05/24/11	NA	790	3,200	6,190	NA
WQSP-6a	3,196.81	3,196.99	7.48	23.2	3,838	05/26/11	6.5	2,100	270	3,480	<1.0

Explanation: NA: Not Analyzed, parameter not required, per permit conditions

NS: Not Sampled, not required per permit conditions

PZ-13 Field Parameters were not measured since a bailer was used to collect the sample due to difficulty using Low-Flow pumps

"Bold" concentrations exceed standards listed in 20.6.2.3103 NMAC for Human Health and Domestic Water Supply

.