



Allen, Pam, NMENV

From: Maestas, Ricardo, NMENV
Sent: Wednesday, August 13, 2014 9:54 AM
To: Allen, Pam, NMENV
Subject: FW: WIPP Information - For Call Today, Number 1 888 413 3490, Code 7175394
Attachments: 1300 Meeting Action Items 041114.xlsx; 41-b-857 WHT dp Daily Averages_4-12-14.pdf; 41-b-856 WHT dp Daily Averages_4-12-14.pdf; Station A and B Filter Readings for Public Release 4-12-14.xlsx

April

From: Kliphuis, Trais, NMENV
Sent: Monday, April 14, 2014 1:20 PM
To: Flynn, Ryan, NMENV; Kendall, Jeff, NMENV
Cc: Tongate, Butch, NMENV; Winchester, Jim, NMENV; Blaine, Tom, NMENV; Schwender, Erika, NMENV; Skibitski, Thomas, NMENV; Kieling, John, NMENV; LucasKamat, Susan, NMENV; Ines Triay (triyin@fiu.edu); Nelson, Morgan, NMENV; Holmes, Steve, NMENV; Smith, Coleman, NMENV; Maestas, Ricardo, NMENV
Subject: FW: WIPP Information - For Call Today, Number 1 888 413 3490, Code 7175394

NMED notes in blue.

From: Oba Vincent [<mailto:oba.vincent@cbfo.doe.gov>]
Sent: Monday, April 14, 2014 10:41 AM
To: Kliphuis, Trais, NMENV; 'peake.tom@epa.gov'; 'Edwards, Jonathan'; 'Walsh, Jonathan'; 'Perrin, Alan'; 'Bob.Kehrman@wipp.ws'; 'Rick.Chavez@wipp.ws'; 'Stone.Nick@epa.gov'; Smith, Coleman, NMENV; 'brozowski.george@epa.gov'; 'Fraass, Ron'; 'Russell Hardy'; 'Veal.Lee@epamail.epa.gov'; 'Economy, Kathleen (Economy.Kathleen@epa.gov)'; 'Poppell, Sam W. (Poppell.Sam@epa.gov)'; Maestas, Ricardo, NMENV
Cc: George Basabilvazo - WIPPNet; 'Reynolds, Tammy - NWP (Tammy.Reynolds@wipp.ws)'; 'Pace, Berry (Berry.Pace@wipp.ws)'; 'Alton.Harris@em.doe.gov'; Susan McCauslin; 'Joe Harvill (jharvill@portageinc.com)'; 'Kennedy, Scott - NWP (Scott.Kennedy@wipp.ws)'; 'Jones, Stewart - RES'; 'Berta Oates'; 'schultheisz.daniel@epa.gov'; Philip Theisen - ORISE; Russ Patterson - WIPPNet; 'Kouba, Steve - WRES (Steve.Kouba@wipp.ws)'; Roger Nelson - WIPPNet; 'Bignell, Dale - CTAC'
Subject: WIPP Information - For Call Today, Number 1 888 413 3490, Code 7175394

Attached is the list of action items, filter performance data and station A/B data.

Below is a summary of the discussion points for today: (Please note, activities and dates are subject to change. Please verify the most current dates of any information provided).

- Station A and B Sampling: The CAM at Station B is functioning. Discussions are continuing regarding the CAM set point. The system is expected to go into service on 4/18. NWP hopes to return approximately 90 additional workers to the site on 4/21. (No change)
- SS and AIS Shaft/Rope Inspections: The weekly MSHA compliance inspection are due on 4/16.
- Contamination survey to the waste face (Phase 3): This has been broken into multiple activities. A decision was made to not require the level B suits for these entries. Causes more of a hazard than protection it provides. Based on observed conditions, this may allow all activities to be accomplished during one entry.
 - Activity 1: Survey and proceed to airlock between W30 & E140 and to E140/S2000. Survey and proceed to airlock between W30 & E140 and to E140/S2000. Task completed on 4/12. No contamination was found. The mine ground conditions observed during the entry were good. 46 bolts were observed to be



broken during the distance of the entry, which is below the acceptance criteria of 10 bolts/per 25 linear feet. (Entry covered approximately 1,900 linear feet.) Results were better than anticipated.

- Activity 2: Survey and proceed to E140/S2520 to evaluate future safe operating base at the Waste Handling Lunchroom; Survey to S2750 and shine light to Panel 6 entrance; Survey to W170/S2520. The diesel generator PM has been delayed until May. This entry is planned for Wednesday or Thursday.
- Activity 3: Establish safe operating base in WH lunchroom and survey to W170/S2520
- Activity 4: Identify source at Panel 7 Waste Face or Identify source at Panel 6 Note: Activities 2, 3 and 4 may be performed during the same entry, depending on contamination conditions. Work plan for these activities will be given to us tomorrow.
- The filter change mock-up is planned for April 15 and 16. Photos will be shared when done.
- NWP has completed a critical review the filter replacement schedule and determined that they can be task ready on 5/12 (ten days earlier). Additional filters are expected on 4/17. (No Change) The current Mod filter DPs are: 856 HEPA Bank – 2.24; 857 HEPA Bank – 1.74. The alarm set point is 2.5. NWP is evaluating making an adjustment to the Mod filter alarm point this week. May go up to 3.0. Close monitoring of the mod filter dp's is being performed while continuing to prepare for filter replacement.
- Shipments of TRU waste from LANL to WCS are continuing: 7 shipments are expected this week due to the holiday.
- Action Items – Item 17 – They will get to us tomorrow.
- Item 30 – They will share paper on calculations.
- Trais Kliphuis asked for pictures of Panel 7 Room 7.
- Steve Holmes asked about VOC sampling now that the contingency plan is invoked. They will check and get back to us.

NOTE CALL-IN NUMBER: 1 888 413 3490, Code 7175394

Thanks

Oba