

Allen, Pam, NMENV

From: Maestas, Ricardo, NMENV
Sent: Wednesday, August 13, 2014 9:58 AM
To: Allen, Pam, NMENV
Subject: FW: Updated workplan for entry tomorrow

April

From: Oba Vincent [<mailto:oba.vincent@cbfo.doe.gov>]
Sent: Tuesday, April 15, 2014 1:44 PM
To: Kliphuis, Trais, NMENV; 'peake.tom@epa.gov'; 'Edwards, Jonathan'; 'Walsh, Jonathan'; 'Perrin, Alan'; 'Bob.Kehrman@wipp.ws'; 'Rick.Chavez@wipp.ws'; 'Stone.Nick@epa.gov'; Smith, Coleman, NMENV; 'brozowski.george@epa.gov'; 'Fraass, Ron'; 'Russell Hardy'; 'Veal.Lee@epamail.epa.gov'; 'Economy, Kathleen (Economy.Kathleen@epa.gov)'; 'Poppell, Sam W. (Poppell.Sam@epa.gov)'; Maestas, Ricardo, NMENV
Cc: George Basabilvazo - WIPPNet; 'Reynolds, Tammy - NWP (Tammy.Reynolds@wipp.ws)'; 'Pace, Berry (Berry.Pace@wipp.ws)'; 'Alton.Harris@em.doe.gov'; Susan McCauslin; 'Joe Harvill (jharvill@portageinc.com)'; 'Kennedy, Scott - NWP (Scott.Kennedy@wipp.ws)'; 'Jones, Stewart - RES'; 'Berta Oates'; 'schultheisz.daniel@epa.gov'; Philip Theisen - ORISE; Russ Patterson - WIPPNet; 'Kouba, Steve - WRES (Steve.Kouba@wipp.ws)'; Roger Nelson - WIPPNet; 'Bignell, Dale - CTAC'
Subject: Updated workplan for entry tomorrow

On the portal, I just posted the updated workplan for tomorrow.

Thanks

Oba

From: Oba Vincent
Sent: Tuesday, April 15, 2014 11:00 AM
To: 'Kliphuis, Trais'; 'peake.tom@epa.gov'; 'Edwards, Jonathan'; 'Walsh, Jonathan'; 'Perrin, Alan'; 'Bob.Kehrman@wipp.ws'; 'Rick.Chavez@wipp.ws'; 'Stone.Nick@epa.gov'; 'coleman.smith@state.nm.us'; 'brozowski.george@epa.gov'; 'Fraass, Ron'; 'Russell Hardy'; 'Veal.Lee@epamail.epa.gov'; 'Economy, Kathleen (Economy.Kathleen@epa.gov)'; 'Poppell, Sam W. (Poppell.Sam@epa.gov)'; 'Maestas, Ricardo, NMENV <Ricardo.Maestas@state.nm.us> (Ricardo.Maestas@state.nm.us)'
Cc: George Basabilvazo - WIPPNet; 'Reynolds, Tammy - NWP (Tammy.Reynolds@wipp.ws)'; 'Pace, Berry (Berry.Pace@wipp.ws)'; 'Alton.Harris@em.doe.gov'; Susan McCauslin; 'Joe Harvill (jharvill@portageinc.com)'; 'Kennedy, Scott - NWP (Scott.Kennedy@wipp.ws)'; 'Jones, Stewart - RES'; 'Berta Oates'; 'schultheisz.daniel@epa.gov'; Philip Theisen - ORISE; Russ Patterson - WIPPNet; 'Kouba, Steve - WRES (Steve.Kouba@wipp.ws)'; Roger Nelson - WIPPNet; 'Bignell, Dale - CTAC'
Subject: WIPP Information - For Call Today, Number 1 888 413 3490, Code 7175394

Attached is the list of action items, filter performance data, underground map and station A/B data.

Below is a summary of the discussion points for today: (Please note, activities and dates are subject to change. Please verify the most current dates of any information provided).

- Station A and B Sampling: The CAM at Station B is functioning. A reading was reported this morning at 0.37 DAC-hrs. The alarm will be set at 40 DAC-hrs. The system is expected to go into service on 4/28. NWP hopes to return approximately 90 additional workers to the site after the system is fully functioning.
- SS and AIS Shaft/Rope Inspections: The weekly MSHA compliance inspections are due on 4/16.



- Contamination survey to the waste face (Phase 3): This has been broken into multiple activities.
 - Activity 1: Survey and proceed to airlock between W30 & E140 and to E140/S2000. Survey and proceed to airlock between W30 & E140 and to E140/S2000. Task completed on 4/12.
 - Activity 2, 3 & 4: Survey and proceed to E140/S2520; Survey from S2750 west to W170. If contamination is found, return to E-140/S-2520 and survey to S-2750, then west towards Panel 6 for assessment of event or until turn-back limits are reached. If no contamination is found at W-170/S-2520, enter Panel 7 and survey to waste face or until turn-back limits are reached. The entry is planned for 4/16.
- The filter change mock-up is planned for April 15 thru 17. NWP has completed a critical review the filter replacement schedule and determined that they can be task ready on 5/12 (ten days earlier). Additional filters are expected on 4/17.
- The current Mod filter DPs are: 856 HEPA Bank – 2.44; 857 HEPA Bank – 1.94. (The fan speed was increased overnight due to the low temperatures.) The alarm set point is 2.5. A set point change to 3.0 is being implemented on 4/15. Close monitoring of the mod filter dp's is being performed while continuing to prepare for filter replacement.
- Shipments of TRU waste from LANL to WCS are continuing: 7 shipments are expected this week due to the holiday. (No change)

NOTE CALL-IN NUMBER: 1 888 413 3490, Code 7175394

Thanks

Oba