



Allen, Pam, NMENV

From: Maestas, Ricardo, NMENV
Sent: Wednesday, August 13, 2014 10:05 AM
To: Allen, Pam, NMENV
Subject: FW: WIPP Information - For Call Today, Number 1 888 413 3490, Code 7175394
Attachments: 41-b-857 WHT dp Daily Averages_4-15-14.pdf; 41-b-856 WHT dp Daily Averages_4-15-14.pdf; Station A and B Filter Readings for Public Release 4-15-14.xlsx; Environmental Sampling 2014-04-15 0730_dg_bw.xlsx; 1300 Meeting Action Items 041514.xlsx

April

From: Kliphuis, Trais, NMENV
Sent: Wednesday, April 16, 2014 11:22 AM
To: Flynn, Ryan, NMENV; Kendall, Jeff, NMENV
Cc: Tongate, Butch, NMENV; Winchester, Jim, NMENV; Blaine, Tom, NMENV; Schwender, Erika, NMENV; Skibitski, Thomas, NMENV; Kieling, John, NMENV; LucasKamat, Susan, NMENV; Ines Triay (triayin@fiu.edu); Nelson, Morgan, NMENV; Holmes, Steve, NMENV; Smith, Coleman, NMENV; Maestas, Ricardo, NMENV
Subject: FW: WIPP Information - For Call Today, Number 1 888 413 3490, Code 7175394

NOTE CALL-IN NUMBER: 1 888 413 3490, Code 7175394

From: Oba Vincent [<mailto:oba.vincent@cbfo.doe.gov>]
Sent: Wednesday, April 16, 2014 11:21 AM
To: Kliphuis, Trais, NMENV; 'peake.tom@epa.gov'; 'Edwards, Jonathan'; 'Walsh, Jonathan'; 'Perrin, Alan'; 'Bob.Kehrman@wipp.ws'; 'Rick.Chavez@wipp.ws'; 'Stone.Nick@epa.gov'; Smith, Coleman, NMENV; 'brozowski.george@epa.gov'; 'Fraass, Ron'; 'Russell Hardy'; 'Veal.Lee@epamail.epa.gov'; 'Economy, Kathleen (Economy.Kathleen@epa.gov)'; 'Poppell, Sam W. (Poppell.Sam@epa.gov)'; Maestas, Ricardo, NMENV
Cc: George Basabilvazo - WIPPNet; 'Reynolds, Tammy - NWP (Tammy.Reynolds@wipp.ws)'; 'Pace, Berry (Berry.Pace@wipp.ws)'; 'Alton.Harris@em.doe.gov'; Susan McCauslin; 'Joe Harvill (jharvill@portageinc.com)'; 'Kennedy, Scott - NWP (Scott.Kennedy@wipp.ws)'; 'Jones, Stewart - RES'; 'Berta Oates'; 'schultheisz.daniel@epa.gov'; Philip Theisen - ORISE; Russ Patterson - WIPPNet; 'Kouba, Steve - WRES (Steve.Kouba@wipp.ws)'; Roger Nelson - WIPPNet; 'Bignell, Dale - CTAC'
Subject: RE: WIPP Information - For Call Today, Number 1 888 413 3490, Code 7175394

Attached is the list of action items, environmental data, filter performance data, underground map and station A/B data.

Below is a summary of the discussion points for today: (Please note, activities and dates are subject to change. Please verify the most current dates of any information provided).

- Station A and B Sampling: The CAM at Station B is functioning. A reading was reported this morning at 0.13 DAC-hrs. The alarm will be set at 40 DAC-hrs. The system is expected to go into service on 4/28. NWP hopes to return approximately 90 additional workers to the site after the system is fully functioning.
- SS and AIS Shaft/Rope Inspections: The weekly MSHA compliance inspections are due on 4/16.
- Contamination survey to the waste face (Phase 3): This has been broken into multiple activities.
 - Activity 1: Survey and proceed to airlock between W30 & E140 and to E140/S2000. Survey and proceed to airlock between W30 & E140 and to E140/S2000. Task completed on 4/12.



- Activity 2, 3 & 4: Survey and proceed to E140/S2520; Survey from S2750 west to W170. If contamination is found, return to E-140/S-2520 and survey to S-2750, then west towards Panel 6 for assessment of event or until turn-back limits are reached. If no contamination is found at W-170/S-2520, enter Panel 7 and survey to waste face or until turn-back limits are reached. The entry is underway today..
- The filter change mock-up is on-going April 15 thru 17. NWP has completed a critical review the filter replacement schedule and determined that they can be task ready on 5/12 (ten days earlier). Additional filters are expected on 4/17.
- The current Mod filter DPs are: 856 HEPA Bank – 2.42; 857 HEPA Bank – 1.90. The alarm set point is 3.0. Close monitoring of the mod filter dp's is being performed while continuing to prepare for filter replacement.
- Shipments of TRU waste from LANL to WCS are continuing: Five of Seven shipments have been completed for the week (22 total).
- The AIB report on the radiological release may be released tomorrow and briefed at the town hall meeting (pending resolution of HQ questions).

NOTE CALL-IN NUMBER: 1 888 413 3490, Code 7175394

Thanks

Oba