

**ATTACHMENT O**  
**WIPP MINE VENTILATION RATE MONITORING PLAN**

(This page intentionally blank)

## ATTACHMENT O

### WIPP MINE VENTILATION RATE MONITORING PLAN

#### TABLE OF CONTENTS

O-1	Definitions .....	3
O-2	Objective .....	3
O-3	Design and Procedures .....	4
O-3a	Test and Balance .....	4
O-3a(1)	Test and Balance Process .....	4
O-3a(2)	Test and Balance Schedule .....	5
O-3b	Active Disposal Room Minimum Airflow .....	6
O-3b(1)	Verification of Active Disposal Room Minimum Airflow .....	6
O-3b(2)	Measurement and Calculation of the Active Waste Disposal Room Airflow .....	6
O-4	Equipment Calibration and Maintenance .....	7
O-5	Reporting and Recordkeeping .....	7
O-5a	Reporting .....	7
O-5b	Recordkeeping .....	8
O-5c	Standard Operating Procedure Applicable to Abnormal Operating Conditions for the Active Room .....	7
O-6	Quality Assurance .....	8

### List of Tables

<b>Table</b>	<b>Title</b>
O-1	Mine Ventilation Rate Testing Equipment

1 **ATTACHMENT O**

2 **WIPP MINE VENTILATION RATE MONITORING PLAN**

3 O-1 Definitions

4 Compliance with the mine ventilation requirements set forth in Permit Part 4 and Permit  
5 Attachment A2 requires the use and definition of the following terms:

6 **Actual cubic feet per minute (acfm):** The volume of air passing a fixed point in an excavation,  
7 normally determined as the product of the cross section of the excavation and the mean velocity  
8 of the air.

9 **Standard cubic feet per minute (scfm):** The actual cubic feet per minute passing a fixed point  
10 adjusted to standard conditions. In the Imperial measurement system, the standard condition for  
11 pressure is 14.7 pounds per square inch (**psi**) (sea level) and the standard condition for  
12 temperature is 492 degrees Rankine (freezing point of water or 32 degrees Fahrenheit). The  
13 greatest difference between acfm and scfm occurs in the summer when the pressure at the  
14 repository horizon is about 14.2 psi and the temperature is about 560 degrees Rankine (100  
15 degrees Fahrenheit). Then

16 
$$1 \text{ scfm} \times (560/492) \times (14.7/14.2) = 1.2 \text{ acfm}$$

17 A reasonably conservative conversion factor, therefore, is 1.2. Using this factor, 35,000 scfm is  
18 very nearly  $35,000 \times 1.2$  or 42,000 acfm.

19 **Restricted Access:** If the required ventilation rate in an active room when waste disposal is  
20 taking place cannot be achieved or cannot be supported due to operational needs, access is  
21 restricted by the use of barriers, signs and postings, or individuals stationed at the entrance to  
22 the active disposal room when ventilation rates are below 35,000 scfm unless measures as  
23 described in Section O-3c(1) are implemented. Note: As provided in Section O-3c(2) entry to  
24 restricted access active rooms for the purpose of establishing normal ventilation is allowed.

25 **Shift:** Those work shifts when there is normal access to the Waste Isolation Pilot Plant (**WIPP**)  
26 underground.

27 **Worker:** Anyone who has normal access to the WIPP underground.

28 O-2 Objective

29 The objective of this plan is to describe how the ventilation requirements in the Permit will be  
30 met. This plan achieves this objective and documents the process by which the Permittees  
31 demonstrate compliance with the ventilation requirements by:

- 32
- 33 • Maintaining a minimum of 35,000 scfm of air through the active rooms when waste disposal is taking place and when workers are present in the rooms
  - 34 • If an active room ventilation rate of 35,000 scfm cannot be met, actions as described in  
35 Section O-3c(1) shall be taken during waste disposal operations when workers are  
36 present.

1 This plan contains the following elements: Objective; Design and Procedures; Equipment  
2 Calibration and Maintenance; Reporting and Record Keeping; Quality Assurance.

3 O-3 Design and Procedures

4 This section describes the four basic processes that make up the mine ventilation rate  
5 monitoring plan:

- 6 • Test and Balance, a periodic re-verification of the satisfactory performance of the entire  
7 underground ventilation system and associated components
- 8 • Monitoring of active room(s) to ensure a minimum flow of 35,000 scfm whenever waste  
9 disposal is taking place and workers are present in the room
- 10 • If an active room ventilation rate of 35,000 scfm cannot be met, actions as described in  
11 Section O-3b(1) shall be taken during waste disposal operations when workers are  
12 present.

13 O-3a Test and Balance

14 O-3a(1) Test and Balance Process

15 The WIPP ventilation system and the underground ventilation modes of operation are described  
16 in Permit Application A2-2a(3). The Permittees shall verify underground ventilation system  
17 performance by conducting a periodic Test and Balance. The Test and Balance is a  
18 comprehensive series of measurements and adjustments designed to ensure that the system is  
19 operating within acceptable design parameters. The Test and Balance is an appropriate method  
20 of verifying system flow because it provides consistent results based on good engineering  
21 practices. The testing of underground ventilation systems is described in McPherson, 1993.  
22 Once completed, the Test and Balance data become the baseline for underground ventilation  
23 system operation until the next Test and Balance is performed.

24 The "Test" portion of the process shall involve measuring the pressure drop and air quantity of  
25 every underground entry excluding alcoves or other dead end drifts. In addition, the tests shall  
26 verify resistance curves for each of the main regulators, measure shaft resistance, and measure  
27 main fan pressure and quantity. This is done at the highest achievable airflow to facilitate  
28 accurate measurements. From these measurements the frictional resistance of the system is  
29 determined.

30 Pressure shall be measured using the gage and tube method, which measures the pressure  
31 drop between two points using a calibrated pressure recording device and pitot tubes. Pressure  
32 drops across the shafts shall be measured by either calibrated barometers at the top and  
33 bottom of shafts or the gage and tube method. Airflow shall be measured using a calibrated  
34 vane anemometer to take a full entry traverse between system junctions. Fan pressure shall be  
35 measured using a calibrated pressure recording device and pitot tube to determine both static  
36 and velocity pressure components.

37 Multiple measurements shall be taken at each field location to ensure accurate results.  
38 Consecutive field values must fall within  $\pm 5\%$  to be acceptable. These data shall be verified  
39 during the testing process by checking that:

- 1 • the sum of airflows entering and leaving a junction is equal to zero; and,
- 2 • the sum of pressure drops around any closed loop is equal to zero.

3 Once the measurements are taken, data shall be used to calculate the resistance of every  
4 underground drift, as well as shafts and regulators using Atkinson's Square Law

$$5 \quad P=R \times Q^2$$

6 where the pressure drop of an entry (P) is equal to a resistance (R) times the square of the  
7 quantity of air flowing (Q) through the circuit.

8 The "Balance" portion of the process shall involve adjusting the settings of the system fans and  
9 regulators to achieve the desired airflow distribution in all parts of the facility for each mode of  
10 operation. The system baseline settings for the current Balance shall be established from the  
11 previous Test and Balance. Adjustments shall then be made to account for changes in system  
12 resistance due to excavation convergence due to salt creep, approved system modifications, or  
13 operational changes.

14 The Permittees shall use a commercially available ventilation simulator to process Test and  
15 Balance field data. The simulator uses the Hardy-Cross Iteration Method (McPherson, 1993) to  
16 reduce field data into a balanced ventilation network, including the appropriate regulator settings  
17 necessary to achieve proper airflow distribution for the various operating modes. Once  
18 balanced, the same simulator shall be used to evaluate changes such as future repository  
19 development and potential system modification before they are implemented.

20 The Test and Balance process culminates in a final report which is retained on site. Following  
21 receipt of the Test and Balance Report, the Permittees shall revise the WIPP surface and  
22 underground ventilation system procedures to incorporate any required changes to the  
23 ventilation system configuration. The Test and Balance data shall be used to adjust the  
24 operating range of fan controls, waste tower pressure, auxiliary air intake tunnel regulator  
25 settings, underground regulator settings, and door configurations. The model data and  
26 procedure changes shall be used to establish normal configuration settings to achieve the  
27 desired airflow in the underground. These settings shall then be modified by operations  
28 personnel throughout the year to compensate for system fluctuations caused by seasonal  
29 changes in psychrometric properties, and to meet specific operational needs. This ensures that  
30 the facility is operated at the design airflow rate for each ventilation mode.

### 31 O-3a(2) Test and Balance Schedule

32 The Test and Balance is generally conducted on a 12- to 18-month interval, but in no case shall  
33 the interval between consecutive Test and Balance performances exceed 18 months. This  
34 interval is sufficient to account for changes in the mine configuration since over this period the  
35 ventilated volume changes very little. The quality and maintenance of ventilation control  
36 structures (e.g., bulkheads) is excellent, so leakage is small and relatively constant. Historic test  
37 and balance results confirm that changes between test and balances fall within anticipated  
38 values.

1 O-3b Active Room Minimum Airflow

2 O-3b(1) Verification of Active Room Minimum Airflow

3 Whenever workers are present, the Permittees shall verify the minimum airflow through active  
4 room(s) when waste disposal is taking place of 35,000 scfm at the start of each shift, any time  
5 there is an operational mode change, or if there is a change in the ventilation system  
6 configuration. If an active room ventilation rate of 35,000 scfm cannot be met, measures such  
7 as those described below shall be taken during waste disposal operations when workers are  
8 present.

9 Measures to allow waste emplacement in an active room when, under abnormal conditions,  
10 35,000 scfm cannot be achieved will be prescribed in standard operating procedure(s)  
11 described in Section O-5c. These measures may include, but are not limited to, the following: the  
12 adjustment of the volatile organic compound (**VOC**) immediately dangerous to life or health  
13 (**IDLH**)-based action levels in the Permit, Section 4.6.3.2 (these adjustments are directly  
14 proportional to the actual flow rate that is less than 35,000 scfm); or the use of personal  
15 protective equipment (**PPE**) as described in Occupational Safety and Health Administration  
16 (**OSHA**) Standard 29 CFR 1910.134.

17 Implementing measures taken at the WIPP facility regarding the 35,000 scfm ventilation rate  
18 and associated details (i.e., date, start time, end time, and reason) will be recorded in the  
19 Central Monitoring Room Operator's (**CMRO**) Log and reported to the New Mexico Environment  
20 Department (**NMED**) as required by Section O-5a.

21 O-3b(2) Measurement and Calculation of the Active Room Airflow

22 The Permittees shall measure the airflow rate and use the room cross-sectional area to  
23 calculate the volume of air flowing through a disposal room. The measurement of airflow shall  
24 use a calibrated anemometer and a moving traverse (McPherson, 1993). Airflow measurements  
25 shall be collected at an appropriate location, chosen by the operator to minimize airflow  
26 disturbances, near the entrance of each active room. The excavation dimensions at the  
27 measurement location are taken and the cross-sectional area is calculated. The flow rate is the  
28 product of the air velocity and the cross-section area. The value shall be entered on a log sheet  
29 and compared to the required minimum. The format and content of the log sheet may vary, but  
30 will always contain the following data and information as applicable:

31

- 32 • Date
- 33 • Time
- 34 • Ventilation flow rate reading
- 35 • If the required minimum ventilation rate was achieved
- 36 • If the room was restricted

- 1 • If Section O-3b(1) measures will be implemented (implementing procedure and revision  
2 number, if applicable)
- 3 • The reason for waste emplacement under 35,000 scfm ventilation rate, if applicable
- 4 • Signature

5 Working values are in acfm and the conversion to scfm is described in section O-1 above.  
6 Measurements shall be collected, recorded, and verified by qualified operators.

7 The operator shall compare the recorded acfm value with the minimum acfm value provided at  
8 the top of the log sheet. The airflow shall be re-checked and recorded whenever there is an  
9 operational mode change or a change in ventilation system configuration. Once the ventilation  
10 rate has been recorded and verified to be at least the required minimum, personnel access to  
11 the room is unrestricted in accordance with normal underground operating procedures. If the  
12 required ventilation rate cannot be achieved, or cannot be supported due to operational needs,  
13 access to the room shall be restricted. Those periods when active disposal room access is  
14 restricted shall be documented on the log sheet for that active disposal room. Entry to restricted  
15 access active rooms for the purpose of establishing normal ventilation or for emplacing waste  
16 under the conditions identified in Section O-3b(1) is allowed. Such entry shall be documented  
17 on the log sheet including a reference to the SOP used.

#### 18 O-4 Equipment Calibration and Maintenance

19 Equipment used for the periodic Test and Balance, and daily verification of active disposal room  
20 flow rate shall be calibrated in accordance with appropriate WIPP calibration and data collection  
21 procedures. Work performed by subcontractors shall also be calibrated to an equivalent  
22 standard. Equipment shall be inspected before each use to ensure that it is functioning properly  
23 and that the equipment calibration is current. Maintenance of equipment shall be completed by  
24 qualified individuals or by qualified off-site service vendors.

25 Equipment used to conduct the Test and Balance, and to determine the airflow through the  
26 active disposal room(s) are provided in Table O-1.

#### 27 O-5 Reporting and Recordkeeping

##### 28 O-5a Reporting

29 The Permittees shall submit an annual report to NMED presenting the results of the data and  
30 analysis of the Mine Ventilation Rate Monitoring Plan. In the years that the Test and Balance is  
31 performed, the Permittees will provide a summary of the results in the annual report.

32 The Permittees shall evaluate compliance with the minimum ventilation rate for an active room  
33 specified in Permit Section 4.5.3.2 on a monthly basis. The Permittees shall report to the  
34 Secretary in the annual report specified in Permit Section 4.6.4.2 whenever the evaluation of the  
35 mine ventilation monitoring program data identifies that the ventilation rate specified in Permit  
36 Section 4.5.3.2 has not been achieved. The Permittees will identify the implementing measures  
37 as described in Section O-3c(1) used to allow waste handling activities to proceed when the  
38 35,000 scfm ventilation rate is not achieved. These implementing measures and associated  
39 details (i.e., date, start time, end time, and reason) will be reported to NMED in the annual Mine  
40 Ventilation Rate Monitoring Report required by this section.

1 The Permittees shall also notify NMED by e-mail within 15 calendar days of commencement of  
2 waste emplacement operations taking place below 35,000 scfm. The notification shall include  
3 the date, start time, end time, reason and implementing measure taken, as applicable. If the  
4 Permittees have not completed the waste emplacement activity by the time of this notification, a  
5 follow-up e-mail shall be provided within 15 calendar days to notify NMED of the end of the  
6 waste emplacement activity and other relevant information not previously provided.

7 O-5b Recordkeeping

8 The Permittees shall retain the following information in the Operating Record:

- 9 • The CMRO Log documenting the ventilation system operating mode.
- 10 • Active disposal room log sheet documenting the ventilation flow rate readings and  
11 applicable information listed in Section O-3c(2).
- 12 • The flow verification check and associated documentation.

13 These records will be maintained in the facility Operating Record until closure of the WIPP  
14 facility.

15 O-5c Standard Operating Procedure Applicable to Abnormal Operating Conditions for Active  
16 Room Ventilation Flow Rate

17 The abnormal operating conditions procedure provides instructions necessary to evaluate VOC  
18 concentrations in an adjacent filled room prior to commencing waste emplacement operations in  
19 an active disposal room when workers are present at a reduced active room ventilation flow  
20 rate. Abnormal conditions that may prevent 35,000 scfm from being met, may include, but are  
21 not limited to, barometric pressure changes, maintenance activities, and equipment  
22 malfunctions. VOC data in the adjacent filled room are collected and analyzed in accordance  
23 with Permit Part 4, Section 4.6.3. Adjusted VOC action levels are prescribed at a maximum of  
24 5,000 scfm increments (e.g., 30,000 scfm, 25,000 scfm, 20,000 scfm, 15,000 scfm, and 10,000  
25 scfm) to provide a means of assessment. When the measured flow rates falls between the  
26 increment values in the SOP, the lower flow rate is used for determining the adjusted VOC  
27 action level. The validated VOC monitoring data are compared to the action levels prescribed in  
28 the standard operating procedure and a decision flow path is provided to the Facility Shift  
29 Manager, or designee, to determine applicable actions.

30 These actions include, but are not limited to, commencing waste emplacement operations at a  
31 reduced active room ventilation flow rate based on the adjusted VOC action levels, commencing  
32 waste emplacement operations at a reduced active room ventilation flow rate with the use of  
33 PPE as described in OSHA standard 29 CFR 1910.134, or restricting access to the active  
34 disposal room until the ventilation flow rate requirements of Permit Part 4, Section 4.5.3.2. are  
35 met. As stated in the abnormal operating conditions procedure, implementing measures taken  
36 at the WIPP facility are recorded in the CMRO Log and reported to NMED as required by  
37 Section O-5a.

1 O-6 Quality Assurance

2 Quality assurance associated with the Mine Ventilation Rate Monitoring Plan shall comply with  
3 the requirements of the WIPP Quality Assurance Program Description (**QAPD**). The Permittees  
4 shall verify the qualification of personnel conducting ventilation flow measurements. The  
5 instrumentation used for monitoring active disposal rooms shall be calibrated in accordance with  
6 the applicable provisions of the WIPP procedures. The ventilation simulation software programs  
7 shall be controlled in accordance with the WIPP QAPD and WIPP computer software quality  
8 assurance plans.

9 Data generated by this plan, as well as records, and procedures to support this plan shall be  
10 maintained and managed in accordance with the WIPP QAPD. Nonconformance or conditions  
11 adverse to quality as identified in performance of this plan will be addressed and corrected as  
12 necessary in accordance with applicable WIPP Quality Assurance Procedures.

13

## REFERENCES

1

2 McPherson, M. J., 1993. *Subsurface Ventilation and Environmental Engineering*, Chapman &  
3 Hall, London, First Edition.

4

1  
2

(This page intentionally blank)

1

## **TABLES**

2

1  
2

(This page intentionally blank)

1  
 2  
 3

**TABLE O-1  
 Mine Ventilation Rate Testing Equipment**

Equipment Used to Conduct Test	Ventilation Test Performed		
	Test and Balance	Active Disposal Room(s)	
Calibrated Anemometer	X	X	
Calibrated Differential Pressure Sensor	X		
Pitot Tubes	X		
Tubing	X		
Temperature Sensing Device	X		
Relative Humidity Sensor	X		
Calibrated Barometers	X		
Electronic Manometer	X		