

**ATTACHMENT O**  
**WIPP MINE VENTILATION RATE MONITORING PLAN**

## ATTACHMENT O

### WIPP MINE VENTILATION RATE MONITORING PLAN

#### TABLE OF CONTENTS

O-1	Definitions .....	4
O-2	Objective .....	4
O-3	Design and Procedures.....	5
O-3a	Test and Balance .....	5
O-3a(1)	Test and Balance Process.....	5
O-3a(2)	Test and Balance Schedule.....	6
O-3b	Active Room Minimum Airflow.....	7
O-3b(1)	Verification of Active Room Minimum Airflow .....	7
O-3b(2)	Measurement and Calculation of the Active Disposal Room Airflow .....	7
O-4	Equipment Calibration and Maintenance .....	8
O-5	Reporting and Recordkeeping .....	8
O-5a	Reporting.....	8
O-5b	Recordkeeping .....	9
O-5c	Standard Operating Procedure Applicable to Abnormal Operating Conditions for Active Room Ventilation Flow Rate .....	9
O-6	Quality Assurance .....	10
O-7	References .....	10

1		<b>List of Tables</b>
2	<b>Table</b>	<b>Title</b>
3	<u>Table</u> O-1	Mine Ventilation Rate Testing Equipment

## ATTACHMENT O

### WIPP MINE VENTILATION RATE MONITORING PLAN

#### O-1 Definitions

Compliance with the mine ventilation requirements set forth in Permit Part 4 and Permit Attachment A2 requires the use and definition of the following terms:

**Actual cubic feet per minute (acfm):** The volume of air passing a fixed point in an excavation, normally determined as the product of the cross section of the excavation and the mean velocity of the air.

**Standard cubic feet per minute (scfm):** The actual cubic feet per minute passing a fixed point adjusted to standard conditions. In the Imperial measurement system, the standard condition for pressure is 14.7 pounds per square inch (**psi**) (sea level) and the standard condition for temperature is 492 degrees Rankine (freezing point of water or 32 degrees Fahrenheit). The greatest difference between acfm and scfm occurs in the summer when the pressure at the repository horizon is about 14.2 psi and the temperature is about 560 degrees Rankine (100 degrees Fahrenheit). Then

$$1 \text{ scfm} \times (560/492) \times (14.7/14.2) = 1.2 \text{ acfm}$$

A reasonably conservative conversion factor, therefore, is 1.2. Using this factor, 35,000 scfm is very nearly 35,000 x 1.2 or 42,000 acfm.

**Restricted Access:** If the required ventilation rate in an active disposal room when waste disposal is taking place cannot be achieved or cannot be supported due to operational needs, access is restricted by the use of barriers, signs and postings, or individuals stationed at the entrance to the active disposal room when ventilation rates are below 35,000 scfm unless measures as described in Section O-3b(1) are implemented. Note: As provided in Section O-3b(2) entry to restricted access active rooms for the purpose of establishing normal ventilation is allowed.

**Shift:** Those work shifts when there is normal access to the Waste Isolation Pilot Plant (**WIPP**) underground.

**Worker:** Anyone who has ~~normal~~unescorted access to the WIPP underground.

#### O-2 Objective

The objective of this plan is to describe how the ventilation requirements in the Permit will be met. This plan achieves this objective and documents the process by which the Permittees demonstrate compliance with the ventilation requirements by:

- Maintaining a minimum of 35,000 scfm of air through the active rooms when waste disposal is taking place and when workers are present in the rooms

- If an active room ventilation rate of 35,000 scfm cannot be met, actions as described in Section O-3b(1) shall be taken during waste disposal operations when workers are present.

~~This plan contains the following elements: Objective; Design and Procedures; Equipment Calibration and Maintenance; Reporting and Record Keeping; Quality Assurance.~~

### O-3 Design and Procedures

This section describes the three basic processes that make up the mine ventilation rate monitoring plan:

- Test and Balance, a periodic re-verification of the satisfactory performance of the entire underground ventilation system and associated components
- Monitoring of active disposal room(s) to ensure a minimum flow of 35,000 scfm whenever waste disposal is taking place and workers are present in the room
- If an active disposal room ventilation rate of 35,000 scfm cannot be met, actions as described in Section O-3b(1) shall be taken during waste disposal operations when workers are present.

### O-3a Test and Balance

#### O-3a(1) Test and Balance Process

The WIPP underground ventilation system and the underground ventilation modes of operation are described in Permit Attachment A2, Section A2-2a(3). The Permittees shall verify underground ventilation system performance by conducting a periodic Test and Balance. The Test and Balance is a comprehensive series of measurements and adjustments designed to ensure that the system is operating within acceptable design parameters. The Test and Balance is an appropriate method of verifying system flow because it provides consistent results based on good engineering practices. The testing of underground ventilation systems is described in McPherson, ~~2009~~1993. Once completed, the Test and Balance data become the baseline for underground ventilation system operation until the next Test and Balance is performed.

The “Test” portion of the process shall involve measuring the pressure drop and air quantity of every underground entry excluding alcoves or other dead end drifts. In addition, the tests shall verify resistance curves for each of the main regulators, measure shaft resistance, and measure main fan pressure and quantity. This is done at the highest achievable airflow to facilitate accurate measurements. From these measurements the frictional resistance of the system is determined.

Pressure shall be measured using the gage and tube method, which measures the pressure drop between two points using a calibrated pressure recording device and pitot tubes. Pressure drops across the shafts shall be measured by either calibrated barometers at the top and bottom of shafts or the gage and tube method. Airflow shall be measured using a calibrated ~~vane~~-anemometer to take a full entry traverse between system junctions. Fan pressure shall be measured using a calibrated pressure recording device and pitot tube to determine both static and velocity pressure components.

1 Multiple measurements shall be taken at each field location to ensure accurate results.  
2 Consecutive field values must fall within  $\pm 5\%$  to be acceptable. These data shall be verified  
3 during the testing process by checking that:

- 4 • the sum of airflows entering and leaving a junction is equal to zero; and,
- 5 • the sum of pressure drops around any closed loop is equal to zero.

6 Once the measurements are taken, data shall be used to calculate the resistance of every  
7 underground drift, as well as shafts and regulators using Atkinson's Square Law

$$8 \quad P=R \times Q^2$$

9 where the pressure drop of an entry (P) is equal to a resistance (R) times the square of the  
10 quantity of air flowing (Q) through the circuit.

11 The "Balance" portion of the process shall involve adjusting the settings of the system fans and  
12 regulators to achieve the desired airflow distribution in all parts of the facility for each mode of  
13 operation. The system baseline settings for the current Balance shall be established from the  
14 previous Test and Balance. Adjustments shall then be made to account for changes in system  
15 resistance due to excavation, convergence due to salt creep, approved system modifications, or  
16 operational changes.

17 The Permittees shall use ~~a commercially available~~an appropriate ventilation simulator to  
18 process Test and Balance field data. The simulator uses the Hardy-Cross Iteration Method  
19 (McPherson, ~~2009~~1993) to reduce field data into a balanced ventilation network, including the  
20 appropriate regulator settings necessary to achieve proper airflow distribution for the various  
21 operating modes. Once balanced, the same simulator shall be used to evaluate changes such  
22 as future repository development and potential system modification before they are  
23 implemented.

24 The Test and Balance process culminates in a final report which is retained on site. Following  
25 receipt of the Test and Balance Report, the Permittees shall revise the WIPP surface and  
26 underground ventilation system procedures to incorporate any required changes to the  
27 ventilation system configuration. The Test and Balance data shall be used to adjust the  
28 operating range of fan controls, waste tower pressure, auxiliary air intake tunnel regulator  
29 settings, underground regulator settings, and door configurations. The model data and  
30 procedure changes shall be used to establish normal configuration settings to achieve the  
31 desired airflow in the underground. These settings shall then be modified by operations  
32 personnel throughout the year to compensate for system fluctuations caused by seasonal  
33 changes in psychrometric properties, and to meet specific operational needs. This ensures that  
34 the facility is operated at the design airflow rate for each ventilation mode.

### 35 O-3a(2) Test and Balance Schedule

36 The Test and Balance is generally conducted on a 12- to 18-month interval, but in no case shall  
37 the interval between consecutive Test and Balance performances exceed 18 months. This  
38 interval is sufficient to account for changes in the mine configuration since over this period the  
39 ventilated volume changes very little. ~~The quality and maintenance of ventilation control~~  
40 ~~structures (e.g., bulkheads) is excellent, so leakage is small and relatively~~

1 ~~constant.~~ Maintenance of ventilation control structures (e.g., bulkheads) occurs periodically to  
2 ensure the ventilation structure performs as expected. Historic test and balance results confirm  
3 that changes between test and balances fall within anticipated values.

4 O-3b Active Room Minimum Airflow

5 O-3b(1) Verification of Active Room Minimum Airflow

6 Whenever workers are present, the Permittees shall verify the minimum airflow through active  
7 room(s) when waste disposal is taking place of 35,000 scfm at the start of each shift, any time  
8 there is an operational mode change, or if there is a change in the ventilation system  
9 configuration. If an active room ventilation rate of 35,000 scfm cannot be met, measures such  
10 as those described below shall be taken during waste disposal operations when workers are  
11 present.

12 Measures to allow waste emplacement in an active room when, under abnormal conditions,  
13 35,000 scfm cannot be achieved will be prescribed in standard operating procedure(s) (SOPs)  
14 described in Section O-5c. These measures may include, but are not limited to, the following:  
15 the adjustment of the volatile organic compound (**VOC**) immediately dangerous to life or health  
16 (**IDLH**)-based action levels in ~~the~~ Permit Part 4, Section 4.6.3.2 (these adjustments are directly  
17 proportional to the actual flow rate that is less than 35,000 scfm); or the use of personal  
18 protective equipment (**PPE**) as described in Occupational Safety and Health Administration  
19 (**OSHA**) Standard 29 CFR Code of Federal Regulations (CFR) 1910.134.

20 Implementing measures taken at the WIPP facility regarding the 35,000 scfm ventilation rate  
21 and associated details (i.e., date, start time, end time, and reason) will be recorded in the  
22 Central Monitoring Room Operator's (**CMRO**) Log and reported to the New Mexico Environment  
23 Department (**NMED**) as required by Section O-5a.

24 O-3b(2) Measurement and Calculation of the Active Disposal Room Airflow

25 The Permittees shall measure the airflow rate and use the disposal room cross-sectional area to  
26 calculate the volume of air flowing through a disposal room. The measurement of airflow shall  
27 use a calibrated anemometer and a moving traverse (McPherson, 20091993). Airflow  
28 measurements shall be collected at an appropriate location, chosen by the operator to minimize  
29 airflow disturbances, near the entrance of each active disposal room. The excavation  
30 dimensions at the measurement location are taken and the cross-sectional area is calculated.  
31 The flow rate is the product of the air velocity and the cross-section area. The value shall be  
32 entered on a log sheet and compared to the required minimum. The format and content of the  
33 log sheet may vary, but will always contain the following data and information as applicable:

- 34 • Date
- 35 • Time
- 36 • Ventilation flow rate reading
- 37 • If the required minimum ventilation rate was achieved
- 38 • If the room was restricted

- 1       • If Section O-3b(1) measures will be implemented (implementing procedure and revision
- 2       number, if applicable)
- 3       • The reason for waste emplacement under 35,000 scfm ventilation rate, if applicable
- 4       • Signature

5 Working values are in acfm and the conversion to scfm is described in Section O-1 above.  
6 Measurements shall be collected, recorded, and verified by qualified operators.

7 The operator shall compare the recorded acfm value with the minimum acfm value provided at  
8 the top of the log sheet. During waste disposal operations, the airflow shall be re-checked and  
9 recorded whenever there is an operational mode change or a change in ventilation system  
10 configuration. Once the ventilation rate has been recorded and verified to be at least the  
11 required minimum, personnel access to the room is unrestricted in accordance with normal  
12 underground operating procedures. If the required ventilation rate cannot be achieved, or  
13 cannot be supported due to operational needs, access to the room shall be restricted. Those  
14 periods when active disposal room access is restricted shall be documented on the log sheet for  
15 that active disposal room. Entry to restricted access active rooms for the purpose of establishing  
16 normal ventilation or for emplacing waste under the conditions identified in Section O-3b(1) is  
17 allowed. Such entry shall be documented on the log sheet including a reference to the SOP  
18 used.

#### 19 O-4 Equipment Calibration and Maintenance

20 The list of equipment used to conduct the Test and Balance and to determine the airflow  
21 through the active disposal room(s) is provided in Table O-1.

22 ~~Equipment used for the periodic Test and Balance, and daily verification of active disposal room~~  
23 ~~flow rate~~ shall be calibrated, as appropriate, in accordance with ~~appropriate~~ WIPP facility  
24 calibration and data collection procedures. Work performed by subcontractors shall also be  
25 calibrated to an equivalent standard. Equipment shall be inspected before each use to ensure  
26 that it is functioning properly and that the equipment calibration is current. Maintenance of  
27 equipment shall be completed by qualified individuals or by qualified off-site service vendors.

28 ~~Equipment used to conduct the Test and Balance, and to determine the airflow through the~~  
29 ~~active disposal room(s) are provided in Table O-1.~~

#### 30 O-5 Reporting and Recordkeeping

##### 31 O-5a Reporting

32 The Permittees shall submit an annual report to NMED presenting the results of the data and  
33 analysis of the Mine Ventilation Rate Monitoring Plan. In the years that the Test and Balance is  
34 performed, the Permittees will provide a summary of the results in the annual report.

35 The Permittees shall evaluate compliance with the minimum ventilation rate for an active room  
36 specified in Permit Part 4, Section 4.5.3.2 on a monthly basis. The Permittees shall report to the  
37 Secretary in the annual report specified in Permit Part 4, Section 4.6.4.2 whenever the  
38 evaluation of the mine ventilation monitoring program data identifies that the ventilation rate



1 specified in Permit Part 4, Section 4.5.3.2 has not been achieved. The Permittees will identify  
2 the implementing measures as described in Section O-3b(1) used to allow waste handling  
3 activities to proceed when the 35,000 scfm ventilation rate is not achieved. These implementing  
4 measures and associated details (i.e., date, start time, end time, and reason) will be reported to  
5 NMED in the annual Mine Ventilation Rate Monitoring Report required by this section.

6 The Permittees shall also notify NMED by e-mail within 15 calendar days of commencement of  
7 waste emplacement operations taking place below 35,000 scfm. The notification shall include  
8 the date, start time, end time, reason and implementing measure taken, as applicable. If the  
9 Permittees have not completed the waste emplacement activity by the time of this notification, a  
10 follow-up e-mail shall be provided within 15 calendar days to notify NMED of the end of the  
11 waste emplacement activity and other relevant information not previously provided.

#### 12 O-5b Recordkeeping

13 The Permittees shall retain the following information in the Operating Record:

- 14 • The CMRO Log documenting the ventilation system operating mode.
- 15 • Active disposal room log sheet documenting the ventilation flow rate readings and  
16 applicable information listed in Section O-3b(2).

17 These records will be maintained in the facility Operating Record until closure of the WIPP  
18 facility.

#### 19 O-5c Standard Operating Procedure Applicable to Abnormal Operating Conditions for 20 Active Room Ventilation Flow Rate

21 The abnormal operating conditions procedure provides instructions necessary to evaluate VOC  
22 concentrations in an adjacent filled room prior to commencing waste emplacement operations in  
23 an active disposal room when workers are present at a reduced active room ventilation flow  
24 rate. Abnormal conditions that may prevent 35,000 scfm from being met, may include, but are  
25 not limited to, barometric pressure changes, maintenance activities, and equipment  
26 malfunctions. VOC data in the adjacent filled room are collected and analyzed in accordance  
27 with Permit Part 4, Section 4.6.3. Adjusted VOC action levels are prescribed at a maximum of  
28 5,000 scfm increments (e.g., 30,000 scfm, 25,000 scfm, 20,000 scfm, 15,000 scfm, and 10,000  
29 scfm) to provide a means of assessment. When the measured flow rates falls between the  
30 increment values in the SOP, the lower flow rate is used for determining the adjusted VOC  
31 action level. The validated VOC monitoring data are compared to the action levels prescribed in  
32 the standard operating procedure and a decision flow path is provided to the Facility Shift  
33 Manager, or designee, to determine applicable actions.

34 These actions include, but are not limited to, commencing waste emplacement operations at a  
35 reduced active room ventilation flow rate based on the adjusted VOC action levels, commencing  
36 waste emplacement operations at a reduced active room ventilation flow rate with the use of  
37 PPE as described in OSHA standard 29 CFR 1910.134, or restricting access to the active  
38 disposal room until the ventilation flow rate requirements of Permit Part 4, Section 4.5.3.2 are  
39 met. As stated in the abnormal operating conditions procedure, implementing measures taken  
40 at the WIPP facility are recorded in the CMRO Log and reported to NMED as required by  
41 Section O-5a.

1 O-6 Quality Assurance

2 Quality assurance associated with the Mine Ventilation Rate Monitoring Plan shall comply with  
3 the requirements of the WIPP Quality Assurance Program Description (**QAPD**). The Permittees  
4 shall verify the qualification of personnel conducting ventilation flow measurements. The  
5 instrumentation used for monitoring active disposal rooms shall be calibrated in accordance with  
6 the applicable provisions of the WIPP procedures. The ventilation simulation software programs  
7 shall be controlled in accordance with the WIPP QAPD and WIPP computer software quality  
8 assurance plans.

9 Data generated by this plan, as well as records, and procedures to support this plan shall be  
10 maintained and managed in accordance with the WIPP QAPD. Nonconformance or conditions  
11 adverse to quality as identified in performance of this plan will be addressed and corrected as  
12 necessary in accordance with applicable WIPP Quality Assurance procedures.

13 O-7 References

14 McPherson, Malcolm J. 2009. *Subsurface Ventilation Engineering*. 2nd. Fresno, California: Mine  
15 Ventilation Services Inc.~~McPherson, M. J., 1993. *Subsurface Ventilation and Environmental*~~  
16 ~~*Engineering*, Chapman & Hall, London, First Edition.~~

1

## TABLES

2

1  
2

**Table O-1  
 Mine Ventilation Rate Testing Equipment**

Equipment Used to Conduct Test	Ventilation Test Performed	
	Test and Balance	Active Disposal Room(s)
Calibrated Anemometer	X	X
Calibrated Differential Pressure Sensor	X	
Pitot Tubes	X	
Tubing	X	
Temperature Sensing Device	X	
Relative Humidity Sensor	X	
Calibrated Barometers	X	
Electronic Manometer	X	

3