

MESSAGE SCAN FOR STEVE ZAPPE

ENTREPRENEUR

To steve zappe@edser:smtp
CC sniderc@wipp.carlsbad.nm.us:smtp

From: Strob1J@wipp.carlsbad.nm.us:smtp
Postmark: Nov 12,97 7:52 AM Delivered: Nov 12,97 7:52 AM

Subject: Response to Monday's Questions

Comments:
See document for message.

-----X-----

I'm writing you in response to your two questions from our telephone conversation on Monday.

1. You asked what type of device do we want you to specify to place the site derived waste container(s) on in the Waste Handling Building.

Answer: We plan to use a standard drum pallet (similar to a containment pallet) that will hold a SWB, four drums, or two 85 gallon drums for site derived waste. If you need to define an area, I recommend you specify 6 feet by 8 feet.

2. You asked how many rounds of groundwater monitoring samples have we taken.

Answer: We have taken 4 groundwater samples.

If you have further questions, please call me at 505-234-8256.

Thanks,

J. R. Stroble

J. R. Stroble

