

COMMUNICATION RECORD

Job No.

Phone: Randy Schmaltz

Route to:

Date: 1-14-10

NMED: Hope Monzeglio

Time: ~1:45 pm

Phone No.

Recorded By: hm

Subject: Western Bloomfield

Randy called to inform NMED that the monthly sample collected from Tank 33 had a detection of benzene at 54 ppm. Tank 33 is water collected from East Outfall #1. East Outfall 1 is a relief system under the Hammond Ditch; the water collected from East Outfall #1 is piped to Tank 38 and then pumped to Tank 33 which then enters the Raw Water Ponds. Because to the benzene detection, the water collected in Tank 38 will be collected in vac trucks and routed to the API separator and will not enter to Tank 33 or the Raw Water Ponds. Water from East Outfall #1 cannot reach the San Juan River. Western suspects the contamination maybe from Tank 13, located south of East Outfall #1 and was suspected of leaking. Tank 13 has been pulled of the service and is being inspected. Randy will send NMED an update through email when he has more information.