



**Monzeglio, Hope, NMENV**

**From:** Schmaltz, Randy [Randy.Schmaltz@wnr.com]  
**Sent:** Friday, January 22, 2010 11:49 AM  
**To:** Monzeglio, Hope, NMENV; Chavez, Carl J, EMNRD  
**Subject:** Tank #33 Discharge Water

This email is a follow up to the phone calls made on 1/14/2010 to NMED and OCD concerning the Tank # 33 discharge.

On January 14, 2010 Western received analytical results showing the discharge water from Tank #33 to be out of compliance. Tank #33 discharge water was immediately rerouted to the frontend of the API Separator and through the wastewater system. This is accomplished by using a vacuum truck to pump out Tank #33 as it fills. Key Energy, a local trucking company has been employed to be on-site continuously to transfer the Tank #33 water to the API Separator.

Randy Schmaltz  
Western Refining Southwest, Inc.  
Bloomfield Refinery

Main (505) 632-8013  
Direct (505) 632-4171  
email: randy.schmaltz@wnr.com

---

This inbound email has been scanned for malicious software and transmitted safely to you using Webroot Email Security.

---