

Monzeglio, Hope, NMENV

From: Ed Riege [eriege@giant.com]
Sent: Thursday, February 02, 2006 8:38 AM
To: Chavez, Carl J, EMNRD
Cc: Monzeglio, Hope, NMENV; Price, Wayne, EMNRD; Foust, Denny, EMNRD; Steve Morris
Subject: Pilot Station Effluent Summary



_0117081617_001.RESPONSE LETTER
pdf (668 KB) OCD BOD jan06....

<<_0117081617_001.pdf>> <<RESPONSE LETTER OCD BOD jan06.doc>>

DISCLAIMER: The information contained in this e-mail message may be privileged, confidential and protected from disclosure. If you are not the intended recipient, any further disclosure, use, dissemination, distribution or copying of this message or any attachment is strictly prohibited. If you think you have received this e-mail message in error, please e-mail the sender at the above address and permanently delete the e-mail. Although this e-mail and any attachments are believed to be free of any virus or other defect that might affect any computer system into which they are received and opened, it is the responsibility of the recipient to ensure that they are virus free and no responsibility is accepted by Giant Industries, Inc. or its affiliates for any loss or damage arising in any way from their use.

February 2, 2006

Mr. Carl Chavez
NM Oil Conservation Division
1220 South St. Francis Drive
Santa Fe, NM 87505

Dear Mr. Chavez:

In response to your e-mail dated December 28, 2005, Giant Industries, Inc., Ciniza Refinery (Ciniza), has examined the contribution from the Pilot Station Effluent (PSE) to the aeration lagoon with respect to biological oxygen demand (BOD) and other constituents. As you may remember, the Pilot Station was previously known as the Travel Center and was owned and operated by Giant Industries.

In order to determine the anticipated loading from the PSE, we first looked at the history of the relationship between the refinery and the station and then at the discharges that were anticipated from the facility. The travel center was under construction in 1986 and on December 12, 1986, Bob McClenahan, the Environmental Coordinator for Giant, wrote to Richard Stamets, the Director of New Mexico Oil Conservation Division (NMOCD), to notify him of the construction and the additional discharges to the aeration basin from the facility (see Attachment 1).

In 1986, the design flow from the Travel Center was 35 gallons per minute at a BOD₅ value of 200 mg/L. This amounted to about 85 pounds per day loading to the system. Also at that time, the refinery load was 700 mg/L BOD at about 82 gallons per minute, resulting in approximately 690 pounds of BOD per day.

The biokinetic data and subsequent calculations for refinery wastewaters in the 1986 letter stated that the BOD removal rate coefficient (K_e) was 0.0004 to 0.0009 L/mg-hr, the sludge synthesis coefficient (Y) was 0.35 to 0.46 pounds sludge per pound BOD_r, the O₂ demand for synthesis (a') was 0.91 to 1.06, and the O₂ demand for endogenous respiration (b) was 0.16 to 0.21. Based on these numbers and an average lagoon temperature in summer of 24°C, the following numbers were calculated:

	Cell #1	Cell #2
Volume (Mgal)	0.51	0.85
BOD removal summer (Lbs)	1353	135
O ₂ demand (lbs/hr)	70	24

As you are aware, current conditions are slightly different – the contribution to the aeration lagoons from the Pilot Station is much less in volume but higher in concentration. The average flow to the aeration lagoon from the Pilot Station is approximately 5 gallons per minute and BOD samples ranged from 504 mg/L to 10,500 mg/L during 2005. This has resulted in a BOD loading ranging from 30 to 630 pounds per day.

If the refinery load is approximately 700 mg/L at an average flow of 105 gpm, the loading would be 882 pounds per day. This would mean the total loading could be as high as 1,330 pounds

per day from sources, the refinery and the PSE. This number is almost the exact loading calculated in 1986.

Samples taken at the inlet to aeration lagoon (AL) 2 on January 6, 2006 had a BOD concentration of 369 mg/l, which is 300 mg/L higher than the calculations in 1986. The flows from AL 1 to AL 2 will be dependent upon evaporation from AL 1 and any additional flows to either the new API unit or the oil-water separator to AL 1. Because of this, calculations to determine loading and BOD removal rates at AL 1 are incomplete. However, it does appear that the loading to AL 1 is no greater than that initially predicted in 1986.

Because there is a unique relationship between Ciniza and the Pilot Station, we would like to take some time to determine if there actually is an issue, since the total BOD loading for the facility is within the original anticipated design for the existing number of aeration units and lagoons. In order to close the loop Giant would like to fill in some of the data gaps and obtain the following information:

- ◆ BOD going into aeration lagoon 1 (per stream or an aggregate number);
- ◆ BOD exiting aeration lagoon 2;
- ◆ Flow rate between aeration lagoon 1 and aeration lagoon 2; and
- ◆ Total water reporting to aeration lagoon 1 – including the API and stormwater separator units.
- ◆ Work with operations and engineering to determine what the anticipated increase in flow rate will be due to increase in production.

We have also followed through with the sampling requested in your e-mail on November 30, 2005 and found that the effluent from the travel center does not exceed the RCRA toxicity standards as the quarterly sampling also indicates.

We propose to continue our investigation and, if we determine that the load placed on our AL by the PSE is too great, we would like the opportunity to work with our neighbor to find a cost-effective and acceptable solution for both of us. Since the winter months actually require the greater amount of oxygen, and we are more than half way through the winter, we request additional time to work on this problem and come to a mutually acceptable resolution within a nine-month period. In July 2006 we propose to send you documentation of our findings and any plans to remedy the loading, as appropriate and necessary.

Please let me know your thoughts on the data presented and our proposal.

Sincerely,

Ed Riege

GIANT

REFINING COMPANY

ROUTE 3, BOX 7 • GALLUP, NEW MEXICO 87301
(505) 722-3833 • TWX 910-981-0504

December 12, 1986

Richard L. Stamets
Director
NMOCD
P.O. Box 2088
Land Office Building
Santa Fe, NM 87501

RE: Addition to Giant's Ciniza Refinery Discharge Plan,
GW-32

Dear Mr. Stamets:

As your staff is aware, Giant is building a new Travel Center near our Refinery. We would like to use the new Aeration Basin for biological treatment of the waste water generated from that facility. Enclosed are some pertinent data related to this proposed addition.

The facility is scheduled to commence operations in May of 1987. Waste streams will be generated at four general locations: the truck service area, the truck fuel center, the R.V. dump station, and the main building, which houses restaurants, showers and restroom facilities. Each of these sources will run through at least one 2,000 gallon septic tank for solids and grease removal, in addition to some biological treatment. The waste water will gravity flow from the septic tanks to a lift station. The lift station is designed to pump the water to the Parchell flume at the inlet of the aeration basin (pond #1). The system is designed to gravity flow to pond #9, in case of mechanical problems. (See attached sewer layout for details).

The designed flow from the Travel Center is 35 GPM (50,400 GPD), at a BOD₅ value of 200 mg/l. This will result in 85 pounds per day of BOD being treated. The refinery organic load was calculated to be 700 mg/l BOD at 117,800 GPD, or 690 #/day BOD. The total anticipated load to the basin therefore is 775 #/day at 168,200 GPD. The aeration equipment (See Appendix A attached) is designed to provide oxygen for up to 1500 #/day of BOD and result in an annualize average evaporation rate of 16,300 GPD (11.3 GPM). The net increase in water to our evaporation ponds would be 34,100 GPD. Utilizing the equations from Table 6-1 (enclosed) of our Discharge plan application report, the total yearly discharge would increase by 12.4 million gallons (MG), for a total of

Richard L. Stamets
December 12, 1986
Page 2

71.2 MG/yr (218.6 AF/yr). Using the calculated pond evaporation capacity of 228.6 AF/yr, results in a conservative pan evaporation rate capacity of 105%. It should be noted that by lake evaporation rates, the pond's capacity is calculated to be 156%. However, due to the marginal amount of calculated excess capacity, several water conservation projects are being considered.

I hope this provides you with adequate information on this proposed change. If you have any questions, please don't hesitate to call me.

Sincerely,




Bob McClenahan, Jr.
Environmental Coordinator
Giant Refining Company

RLM:ds

Enclosures

cc: Carl Shook
Trent Thomas, Geoscience Consultants, Ltd.
Carlos Guerra, Giant Industries
Frank Chavez, OCD, Aztec, NM



APPROX. Sewer
Layout with
Lift Station
1/4

*cleared
y in
mainway*

*Light
structure
cabin
at
station*

115N
114N
113N
112N
111N
110N

33 4
34 3

TABLE 6-1

WATER BALANCE FOR EVAPORATION PONDS

MONTH	PRECIP. (IN.)	PAN EVAP. (IN.)	DIFFERENCE (IN.)
Jan	.56	.38	+1.18
Feb	.50	.50	0.00
Mar	.61	.84	-.23
Apr	.43	2.05	-1.62
May	.43	3.82	-3.39
June	.52	5.81	-5.29
July	1.83	7.11	-5.28
Aug	1.65	5.92	-4.27
Sep	.99	3.89	-2.90
Oct	1.17	2.03	-.86
Nov	.62	.70	-.08
Dec	.68	.39	+.29
	<hr/> 9.99	<hr/> 33.44	<hr/> -23.45

30.63
91.6%

Average discharge = 161,000 gallons/day

Yearly Discharge = 365 days x 161,000 gallons/day = 58,765,000 gallons/year

58,765,000 gallons/year x 1 Acre-Foot/325,742 gallons = 180.4 AF/year

Net Pond Evaporation = 23.45 in/year = 1.954 ft/year

Pond Evaporative Capacity = 117 Acres x 1.954 ft/year = 228.6 AF/year

Relative Capacity = $\frac{228.6 \text{ AF/year}}{180.4 \text{ AF/year}}$ = 127%

TC 50,400

RECEIVED AUG 14 1986

SLUDGE POND VOLUMETRICS
TRIAL #3
JULY 18 1986

SIDESLOPES = 2:1
TOP OF DIKE = 10'

Appendix A

CELL	DRAIN POINT ELEV	BOTTOM ELEV	SPILL ELEV	BOTTOM ELEV AREA (SF)	TOP OF POND CONTOUR AREA (SF)	TOP OF FREEBOARD CONTOUR AREA (SF)	POND VOLUME (CF)	FREEBOARD VOLUME (CF)	TOTAL CELL VOLUME (CF)
1	92.0	93.0	100.0	10,521	14,694	16,770	68,297(0.51MG)	31,464	99,761
2	86.0	87.0	96.0	12,141	18,410	20,754	112,998(0.85MG)	39,164	152,162
3	85.0	86.0	96.0	34,402	48,631	51,753	349,933	100,384	450,317
VOLUME TOTALS:							531,228	171,012	702,240

The following biokinetic data for refinery wastewaters are taken from Reference #1:

- a. BOD Removal Rate Coefficient, (K_e) = 0.0004 to 0.0009 L/mg-hr
- b. Sludge Synthesis Coefficient, (Y) = 0.35-0.46 lbs. Sludge/lb. BOD_r
- c. O₂ Demand for Synthesis, (a') = 0.91-1.06
- d. O₂ Demand for Endogenous Respiration, (b') = 0.16-0.21

Since the above data are based on a bench scale experimental study in the laboratory, 20°C (68°F) temperature will be assumed.

Cell #1: Lagoon Temperature: 24°C* (Summer)

Lagoon Temperature: 13.5°C* (Winter)

*REFER TO COMPUTER PRINTOUT FOR COOLING CALCULATIONS.

Correct BOD Removal Rate Coefficient, K_e for temperature,

$$\begin{aligned} K_{eT^{\circ}\text{C}} &= K_{e20^{\circ}\text{C}} \times 1.04^{(T-20^{\circ}\text{C})} \\ &= 0.00065 \text{ L/mg-hr (Avg.)} \times 1.04^{25-20} \\ &= 0.0008 \text{ L/mg-hr (Summer)} \\ &= 0.019 \text{ L/mg-day} \end{aligned}$$

$$\begin{aligned} K_{ewinter} &= 0.00065 \text{ L/mg-hr} \times 1.04^{13.5-20} \\ &= 0.0005 \text{ L/mg-day} \\ &= 0.012 \text{ L/mg-day} \end{aligned}$$

$$\text{Basin Volume} = 0.51 \text{ MG}$$

REFER TO COMPUTER PRINTOUT TRIAL ERROR MLVSS v BOD_r
NOTE: Summer conditions control.

$$\text{BOD}_5 \text{ removal} = 714 \text{ mg/l} - 70 \text{ mg/l} = 644 \text{ mg/l}$$

$$\begin{aligned} \text{lbs BOD}_5 \text{ removed} &= 644 \text{ mg/l} (8.34) 0.252 \text{ MGD} \\ &= 1353 \frac{\text{lbs}}{\text{day}} \end{aligned}$$

$$\text{Maximum } O_2 \text{ Demand} = a' (\text{BOD removal}) + b' (\text{lbs MLVSS})$$

$$\begin{aligned} \text{lbs MLVSS} &= 245 \text{ mg/l} \times 0.5 \text{ MG} \times 8.34 \\ &= 1022 \text{ lbs MLVSS} \end{aligned}$$

$$\begin{aligned} \text{lbs } O_2 &= 1.06 \frac{\text{lbs } O_2}{\text{lb BOD}_r} (1353 \text{ lbs } \frac{\text{BOD}}{\text{day}}) + 0.21 \frac{1}{\text{day}} (1022 \text{ lbs}) \\ &= 1649 \text{ lbs } \frac{O_2}{\text{day}} \\ &= 70 \text{ lbs/hr} \end{aligned}$$

REFER TO COMPUTER PRINTOUT FOR FIELD O_2 TRANSFER RATE CALCULATIONS.

Three (3) - 15HP Aqua Jet aerators with anti-erosion assemblies in Cell are recommended.

Cell #2:

Lagoon Temperature = 22.3°C* (Summer)

Lagoon Temperature = 4.9°C* (Winter)

*REFER TO COMPUTER PRINTOUT FOR COOLING CALCULATIONS

Basin Volume = 0.85 MG

Summer:

REFER TO COMPUTER PRINTOUT TRIAL ERROR MLVSS vs BOD_r.

$$\text{BOD}_5 \text{ removal} = 70 \text{ mg/l} - 6 \text{ mg/l} = 64 \text{ mg/l}$$

$$\begin{aligned} \text{lbs BOD}_5 \text{ removed} &= 64 \text{ mg/l} (8.34) 0.252 \text{ MGD} \\ &= 135 \text{ lbs/day} \end{aligned}$$

Winter:

$$\text{BOD}_5 \text{ removal} = 109 \text{ mg/l} - 12 \text{ mg/l} = 97 \text{ mg/l}$$

$$\begin{aligned} \text{lbs BOD}_5 \text{ removed} &= 97 \text{ mg/l} (8.34) 0.252 \text{ MGD} \\ &= 204 \text{ lbs/day} \end{aligned}$$

Winter removal requires largest oxygen supply.

$$\begin{aligned} \text{lbs MLVSS} &= 248 \text{ mg/l} \times 0.85 \text{ MG} \times 8.34 \\ &= 1758 \text{ lbs MLVSS} \end{aligned}$$

$$\begin{aligned} \text{lbs O}_2 &= 1.06 \frac{\text{lbs O}_2}{\text{lb BOD}_5} (204 \frac{\text{lbs}}{\text{day}}) + 0.21 \frac{1}{\text{day}} (1758 \frac{\text{lbs}}{\text{day}}) \\ &= 585 \frac{\text{lbs O}_2}{\text{day}} \\ &= 24 \frac{\text{lbs O}_2}{\text{hr}} \end{aligned}$$

REFER TO COMPUTER PRINTOUT FOR FTR CALCULATIONS.

Two (2) - 15 HP Aqua-Jet aerators with anti-erosion assemblies in Cell #2 are recommended.

NOTE: An effluent TSS level of = 300 mg/l should be expected. If the level of discharge is not acceptable, a settling pond (2-3 day) will be required.

Also using two - 15 HP aerators in Cell #2 should produce an effluent D.O. level of about 5 mg/l based on the information given. Refer to computer printout.

Reference:

1. Ronald L. Dickenson; John T. Giboney; "Stabilization of Refinery Wastewaters with the Activated Sludge Process: Determination of Design Parameters"; A paper presented at 25th Industrial Waste Conference at the Purdue University, Lafayette, Indiana, May 1970.

SEC/sp
10/22/86