

Monzeglio, Hope, NMENV

From: Jim Lieb [jlieb@giant.com]
Sent: Wednesday, August 09, 2006 4:19 PM
To: Monzeglio, Hope, NMENV
Cc: Steve Morris; Ed Riege
Subject: RE: Non contact cooling water

Hope:

Steve discussed this with our operators and an estimate of 25000 gallons per week of the backflush water occurs.

This is non-contact water so it does not mix with petroleum hydrocarbons. It is basically just plain water from our water wells.

Jim Lieb
Giant- Ciniza

From: Monzeglio, Hope, NMENV [mailto:hope.monzeglio@state.nm.us]
Sent: Thursday, August 03, 2006 3:01 PM
To: Ed Riege; Jim Lieb; Steve Morris
Cc: Cobrain, Dave, NMENV; Price, Wayne, EMNRD; Chavez, Carl J, EMNRD
Subject: Non contact cooling water

Ed, Jim, and Steve

I have a few questions pertaining to the non contact cooling water.

1. Does Giant know the flow rate at which the non contact cooling water has been entering the stormwater sewer system or the Old API separator?
2. What system(s) (flow path) does the non-contact cooling water come in contact with before it enters the stormwater sewer system?

Thanks

Hope

Hope Monzeglio
Environmental Specialist
New Mexico Environment Department
Hazardous Waste Bureau
2905 Rodeo Park Drive East, BLDG 1
Santa Fe NM 87505
Phone: (505) 428-2545
Fax: (505)-428-2567
hope.monzeglio@state.nm.us

Confidentiality Notice: This e-mail, including all attachments is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure or distribution is prohibited unless specifically provided under the New Mexico Inspection of Public Records Act. If you are not the intended recipient, please contact the sender and destroy all copies of this message. -- This email has been scanned by the Sybari - Antigen Email System.

8/11/2006