

**Monzeglio, Hope, NMENV**

**From:** Chavez, Carl J, EMNRD  
**Sent:** Monday, January 01, 2007 11:21 AM  
**To:** Jim Lieb  
**Cc:** Monzeglio, Hope, NMENV; Ed Riege; Steve Morris; Loren Pritzel; Ed Rios; Price, Wayne, EMNRD  
**Subject:** RE: C-141 Form for 12/27/06 Fire at Giant- Ciniza Refinery

Jim:

Due to the late notification of the fire, diesel release; and due to bad weather conditions, the OCD was unable to conduct a timely follow-up site visit/inspection. It was estimated by Steve Morris last Thursday that about 200 to 300 gallons of raw diesel went into the drainage system or eventually ended up at the NAPIS for treatment by the benzene stripper, aeration lagoons, and evaporation pond treatment systems. Steve indicated that no diesel was released outside of the curbed containment area and drainage system.

To assess the impacts to the treatment system, the OCD requires a couple of water samples (VOCs, SVOCs, PAHs, Phenol, and Metals), one from EP1 and EP2. Giant shall physically inspect the treatment system by physically extracting surface water samples to evaluate floating product thickness and to evaluate impacts to the EP shorelines. Giant shall immediately implement skimming and shoreline cleanup procedures similar to the last impact to the treatment system. I will contact you as soon as I am in the office. Thank you.

**From:** Jim Lieb [mailto:jl Lieb@giant.com]  
**Sent:** Fri 12/29/2006 3:48 PM  
**To:** Chavez, Carl J, EMNRD  
**Cc:** Monzeglio, Hope, NMENV; Ed Riege; Steve Morris; Loren Pritzel; Ed Rios  
**Subject:** C-141 Form for 12/27/06 Fire at Giant- Ciniza Refinery

Carl:

The OCD's C-141 Form for the recent fire incident is attached. Once again we apologize a more faster notification was not made due to the circumstances (Holiday)

Regards,  
Jim Lieb

Environmental Engineer  
Giant Industries, Inc.  
Ciniza Refinery  
I-40, Exit 39  
Jamestown, NM 87347  
(505) 722-0227  
fax (505) 722-0210  
jl Lieb@giant.com

3/8/2007