

GRCC

Monzeglio, Hope, NMENV

From: Steve Morris [smorris@giant.com]
Sent: Thursday, March 08, 2007 4:14 PM
To: Monzeglio, Hope, NMENV; Chavez, Carl J, EMNRD
Cc: Ed Riege; Jim Lieb
Subject: NAPIS Oil Sump Level Device

Hope, Carl, and All,
After checking into the level device at the oil sump in the new API Separator, it turns out the switch was left in the "off" position.
A new switch is being ordered with only Hand and Auto selections.
This new switch will eliminate the chance of the pump being inadvertently left in the off position.
Thanks, Steve Morris

This inbound email has been scanned by the MessageLabs Email Security System.
