

Gallup

July 2011

ENTERED

WWTS / T-35

VanHorn, Kristen, NMENV

From: Larsen, Thurman [Thurman.Larsen@wnr.com]
Sent: Thursday, July 07, 2011 3:50 PM
To: VanHorn, Kristen, NMENV
Subject: FW: API - Benzene sample 07-07-11 (CORRECTION)

Kristen,
This e-mail was sent to a bad address. The corrections were made to the e-mail for item #3 (in RED).
Thanks,

Beck Larsen; CHMM, REM, RPG
Environmental Engineer

Western Refining Company- Gallup Refinery
Route 3, Box 7
Gallup, NM 87301
Office:(505) 722-0258
Fax: (505) 722-0210
Cell: (505) 862-1749
Email: thurman.larsen@wnr.com

From: Larsen, Thurman
Sent: Thursday, July 07, 2011 2:01 PM
To: 'Van Horn, Kristen, NMENV'
Cc: Tso, Janice; Dorsey, Alvin; Riege, Ed
Subject: API - Benzene sample 07-07-11 (CORRECTION)

Dear Kristen,

I made a correction to a previous submittal for T-35 diversion.

Item #3 (below): Under normal conditions, all flow goes directly to T-35 first. Flow from T-35 will then go to the East/West Bay of the API, through all benzene strippers, and finally to AL-1. When the API and benzene strippers are shut down for maintenance activities, flow will continue to T-35 as normal but will not be allowed to continue to the API and strippers until the API and strippers are back online.

Thanks,

Beck Larsen; CHMM, REM, RPG
Environmental Engineer

Western Refining Company- Gallup Refinery
Route 3, Box 7
Gallup, NM 87301
Office:(505) 722-0258
Fax: (505) 722-0210
Cell: (505) 862-1749
Email: thurman.larsen@wnr.com

From: Dorsey, Alvin
Sent: Thursday, July 07, 2011 12:18 PM
To: Larsen, Thurman; Riege, Ed; 'Van Horn, Kristen, NMENV'
Cc: Tso, Janice
Subject: API - Benzene sample 07-07-11

1. The north benzene tower blower is locked out/tagged out so Mechanics can check why blower is making noise.
2. All three benzene strippers will be shut down until this work is completed.
3. **BZ 1-2 out Flow diverted to Tank T35**
4. No Sample collected for Thursday 07-07-11

Alvin Dorsey

Environmental Specialist

Western Refining
Gallup Refinery
Rt. 3 Box 7
Gallup, NM 87301
(505) 722-3833 ext. 3211
(505) 722-0268 (fax)

Alvin.Dorsey@wnr.com

www.wnr.com