

District I
1625 N. French Dr., Hobbs, NM 88240
District II
811 S. First St., Artesia, NM 88210
District III
1000 Rio Brazos Road, Aztec, NM 87410
District IV
1220 S. St. Francis Dr., Santa Fe, NM 87505

State of New Mexico
Energy Minerals and Natural Resources



Form C-141
Revised August 8, 2011

Oil Conservation Division
1220 South St. Francis Dr.
Santa Fe, NM 87505

Submit 1 Copy to appropriate District Office in
accordance with 19.15.29 NMAC.

Release Notification and Corrective Action

OPERATOR

Initial Report Final Report

| | |
|---|-----------------------------------|
| Name of Company: WESTERN REFINING | Contact: Beck Larsen |
| Address: I-40 / EXIT 39, JAMES TOWN, NM 87347 | Telephone No. (505) 722-0258 |
| Facility Name: WESTERN REFINING (GALLUP REFINERY) | Facility Type: Petroleum Refinery |

| | | |
|---------------|---------------|---------|
| Surface Owner | Mineral Owner | API No. |
|---------------|---------------|---------|

LOCATION OF RELEASE

| Unit Letter | Section | Township | Range | Feet from the | North/South Line | Feet from the | East/West Line | County |
|-------------|---------|----------|-------|---------------|------------------|---------------|----------------|----------|
| | 28 | 15 N | 15 W | | | | | MCKINLEY |

Latitude 35° 02' 024" Longitude 108° 02' 024"

NATURE OF RELEASE

| | | |
|--|---|---|
| Type of Release: Dyed Diesel Tank Overflow | Volume of Release Pending | Volume Recovered: N/A |
| Source of Release: T1001 Marketing Tank Overflow (Dyed Diesel) | Date and Hour of Occurrence 09/23/15 @ 0815 hrs | Date and Hour of Discovery 09/23/15 @ 0815 hrs |
| Was Immediate Notice Given? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Not Required | If YES, To Whom? OCD (B. Powell/ C. Chavez); NMED (K. Vanhorn) | |
| By Whom? Beck Larsen | Date and Hour: 09/25/15 (0929- msg/0925-msg); 0934 | |
| Was a Watercourse Reached? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | If YES, Volume Impacting the Watercourse. N/A | |

If a Watercourse was Impacted, Describe Fully.* No

Describe Cause of Problem and Remedial Action Taken.* Marketing Tank (T1001), a dyed diesel tank, overflowed at 0815 through a 2 inch over-fill line at the top of the tank. The fill valve to the tank was blocked in to prevent further diesel spilling onto the ground and Kurtz Fire Department was called to place about 3 gallons/20 gallon of foam/water mixture on the affected area. Maintenance and the Environmental departments were both notified in order to assess the situation and to commence cleanup operations. Work Order # 2614539 was issue for maintenance personnel to begin cleanup operations.

Describe Area Affected and Cleanup Action Taken.* T1001 is located on a concrete slab within a secondary earthen dike. An onsite vacuum truck was dispatched to begin removing all accumulated free liquid. Cleanup operations began on Thursday, October 1, to remove the potentially contaminated TPH soil from the affected area. Approximately 15 to 18 cubic yards (30,920 lbs) of contaminated soil have been removed from the affected area to date. Cleanup operations are currently in progress. The released quantity of diesel is currently undetermined pending further investigation.

I hereby certify that the information given above is true and complete to the best of my knowledge and understand that pursuant to NMOCD rules and regulations all operators are required to report and/or file certain release notifications and perform corrective actions for releases which may endanger public health or the environment. The acceptance of a C-141 report by the NMOCD marked as "Final Report" does not relieve the operator of liability should their operations have failed to adequately investigate and remediate contamination that pose a threat to ground water, surface water, human health or the environment. In addition, NMOCD acceptance of a C-141 report does not relieve the operator of responsibility for compliance with any other federal, state, or local laws and/or regulations.

| | | | |
|--|---------------------------------------|------------------|-----------------------------------|
| Signature: | OIL CONSERVATION DIVISION | | |
| Printed Name: Beck Larsen | Approved by Environmental Specialist: | | |
| Title: Environmental Engineer | Approval Date: | Expiration Date: | |
| E-mail Address: thurman.larsen@wnr.com | Conditions of Approval: | | Attached <input type="checkbox"/> |
| Date: 10/07/2015 | Phone: (505) 722-0258 | | |

* Attach Additional Sheets If Necessary